Meter outside East side of the house. Export meter will be below Equipment Location: revenue meter. Ensure both meters are at correct height. Combiner and utility disconnect will be adjacent to meters.

Combiner	
Garage Disconnect will be located	
and the Allentha side of the anguerra	

Array Array Pitch

18°

#

Mag True Azim. Azim. 180° 183°

PV SqFt 250

1237 Pilgrim Road Plymouth WI, 53073

SOLAR THE ENERGY EXPERTS

Phone: (920) 838-6610 www.archelec.com

Sahagun- 5.04 kWdc, 3.78 kWac, Milwaukee


Garage Disconnect

on the North side of the garage.

Main service panel in basement.



Plot Plan: Scale - NTS



5.04 kWdc 23R-120

Mike Gietman

Site Plan Date: 7.31.23 Revision: 1

Page A.2