



# CERTIFICATE OF APPROPRIATENESS APPLICATION FORM

Incomplete applications will not be processed for Commission review.  
Please print legibly.

1. **HISTORIC NAME OF PROPERTY OR HISTORIC DISTRICT: (if known)**

St Anthony Catholic Church

**ADDRESS OF PROPERTY:**

1911 S 9th Street, Milwaukee, WI 53204

2. **NAME AND ADDRESS OF OWNER:**

Name(s): Fr. Hugo Londono

Address: 1911 S 9th Street

City: Milwaukee

State: WI

ZIP: 53204

Email: londonoh@stanthonymilwaukee.org

Telephone number (area code & number) Daytime: 414-645-1455

Evening:

3. **APPLICANT, AGENT OR CONTRACTOR: (if different from owner)**

Name(s): Daniel Weber

Address: 1727 S 9th Street

City: Milwaukee

State: WI

ZIP Code: 53204

Email: weberd@stanthonymilwaukee.org

Telephone number (area code & number) Daytime: 414-384-6612

Evening: 252-646-5326

4. **ATTACHMENTS: (Because projects can vary in size and scope, please call the HPC Office at 414-286-5712 for submittal requirements)**

**A. REQUIRED FOR MAJOR PROJECTS:**

Photographs of affected areas & all sides of the building (annotated photos recommended)

Sketches and Elevation Drawings (1 full size and 1 reduced to 11" x 17" or 8 1/2" x 11")

A digital copy of the photos and drawings is also requested.

Material and Design Specifications (see next page)

**B. NEW CONSTRUCTION ALSO REQUIRES:**

Floor Plans (1 full size and 1 reduced to a maximum of 11" x 17")

Site Plan showing location of project and adjoining structures and fences

**PLEASE NOTE: YOUR APPLICATION CANNOT BE PROCESSED UNLESS  
BOTH PAGES OF THIS FORM ARE PROPERLY COMPLETED  
AND SIGNED.**


**5. DESCRIPTION OF PROJECT:**

Tell us what you want to do. Describe all proposed work including materials, design, and dimensions. Additional pages may be attached via email.

St Anthony has contracted Zien Mechanical to install a new HVAC Cooling system for the Church Nave, Sanctuary, Sacristy, and room above the Sacristy

1. Provide equipment, materials, and labor.
2. Install new multitier baseboard heating. The new baseboard heating will be installed in coordination with the new VRF fan coil units.
3. Install (2) 4-ton floor mount fan coil units on the back wall of the Sanctuary.
4. Install (6) 4-ton floor mount fan coil units in the Church Nave. The north wall will have (3) units and the south wall will have (3) units.
5. Install (1) 1.5-ton fan coil unit in the Priest's Sacristy.
6. Install (1) 1-5-ton fan coil unit and (1) 1-KW strip heater in the storage room above the Sacristy.
7. The new outdoor condensers will sit on the west south side of the church.
8. Includes controls with (1) central controller with display.
9. Total cooling capacity of phase I system will be 35-tons.
10. Includes upgrading the electrical service with a new power feed to the building and new transformers.
11. Includes electrical wiring for all the cooling equipment.
12. The refrigeration distribution lines will be installed in the church basement.
13. Perform startup and verify operation.

**6. SIGNATURE OF APPLICANT:**

  
Signature

Daniel Weber  
Please print or type name

5/23/2019  
Date

This form and all supporting documentation MUST arrive by 4:00 pm (11:59 pm via email) on the deadline date established to be considered at the next Historic Preservation Commission Meeting. Any information not provided to staff in advance of the meeting will not be considered by the Commission during their deliberation. Please call if you have any questions and staff will assist you.

**Mail or Email Form to:**  
Historic Preservation Commission  
City Clerk's Office  
841 N. Broadway, Rm. B1  
Milwaukee, WI 53202

**PHONE: (414) 286-5712 or 286-5722**

[hpc@milwaukee.gov](mailto:hpc@milwaukee.gov)

[www.milwaukee.gov/hpc](http://www.milwaukee.gov/hpc)

Or click the **SUBMIT** button to automatically email this form for submission.

**SUBMIT**