

Roeglin, Tanya <TROEGL@milwaukee.gov>

To:Matthew Bohlmann

Cc:Roeglin, Tanya

Oct 7 at 10:03 AM

Hi Matt

The revised illumination meets the criteria to be considered a type A sign, which would be permitted once Historic Preservation approves the COA. Please forward a copy once you have obtained it to get the sign permit issued.

The only other question regarding the sign is if the existing planter has a footing, and the inspector will need to verify this during the construction of the sign. The sign will need to be compliant with the MCO 244-5 Wind Pressure, Allowable Stresses, and Materials which can be found at :

<https://city.milwaukee.gov/ImageLibrary/Groups/ccClerk/Ordinances/Volume-2/CH244.pdf>

Thank you

Tanya Roeglin

Plan Examiner Specialist

City of Milwaukee

Department of Neighborhood Services

809 N Broadway

Milwaukee, WI 53202-3617

troegl@milwaukee.gov

(414) 286-2680 (voice)