



Certificate of Appropriateness

Milwaukee Historic Preservation Commission/200 E. Wells Street/Milwaukee, WI 53202/phone 414-286-5712/fax 414-286-3004

Property 333 W. STATE Milwaukee Journal Complex
Description of work Wall sign reading “Journal Commons” as described on following pages. Vehicle clearance signs also as shown.
Date issued 7/22/2022 PTS ID 115294 COA: WALL SIGN

In accordance with the provisions of Section 320-21 (11) and (12) of the Milwaukee Code of Ordinances, the Milwaukee Historic Preservation Commission has issued a certificate of appropriateness for the work listed above. The work was found to be consistent with preservation guidelines. The following conditions apply to this certificate of appropriateness:

n/a

All work must be done in a craftsman-like manner, and must be completed within one year of the date this certificate was issued. Staff must approve any changes or additions to this certificate before work begins. Work that is not completed in accordance with this certificate may be subject to correction orders or citations. If you require technical assistance, please contact hpc@milwaukee.gov.

If permits are required, you are responsible for obtaining them from the Milwaukee Development Center. If you have questions about permit requirements, please consult the Development Center’s web site, www.milwaukee.gov/build, or call (414) 286-8210.

City of Milwaukee Historic Preservation Staff

Copies to: Development Center, Ald. Robert Bauman, Contractor , Inspector Dave Pedersen (286-2540)



PROPOSED FRONT ELEVATION VIEW W/ NEW CHANNEL LETTERS
SCALE: NTS



NIGHT VIEW
SCALE: NTS



FRONT VIEW
3/8" = 1'-0"





SIDE VIEW
NTS

FACE-LIT / HALO-LIT CHANNEL LETTERS

191.3 SQ FT

- FABRICATED CHANNEL LETTERS W/ 5" PREFINISHED BLACK RETURNS
- TRANSLUCENT FACES W/ V1 VINYL APPLIED 1ST SURFACE SECURED TO RETURNS W/ PREFINISHED BLACK TRIMCAP
- FACE-LIT & HALO-LIT W/ WHITE LED'S
- LETTER MOUNTED TO BUILDING W/ FASTENERS BEST SUITED FOR CONDITION & 2" STANDOFFS
- ELECTRICAL TO TIE INTO EXISTING

-  V1 BLACK PERFORATED VINYL (LIGHTS WHITE AT NIGHT)
-  BLACK (RETURNS & TRIMCAP)

SIZES ARE APPROXIMATE - SITE SURVEY REQUIRED



Hanging Clearance Marker 1 / CM1, 7" Dia. Tube, 120" Long, Text & Chain Length TBD
 QTY: 2 - 1 North Entrance, 1 South Entrance



Clearance Marker Wall Sign 1 / WS1, 12"H x 120"W, ACM w/ Vinyl Face, Text TBD
 QTY: 1 - 1 North Entrance