



Certificate of Appropriateness

Milwaukee Historic Preservation Commission/200 E. Wells Street/Milwaukee, WI 53202/phone 414-286-5712/fax 414-286-3004

Property	2590 S. SUPERIOR ST.
Description of work	Replace roof with Pabco Cascade, Signature Cut, Diamond Shaped A-R, a fiberblasse composite shingle in either Oakwood or Pewter Gray. Replace gutters with new zinc half-round gutters. Repair or replace skylight with new flat-top skylight. A new skylight size may vary 1-2” in dimensions from the original if it allows a stock size to be used, however, the opening may not be enlarged. Membrane roofing may be used in extremely low slope areas that will have no visibility from ground level (balcony, window hoods, etc).
Date issued	The best available evidence indicates that a diamond roof has been present since at least 1937. 7/23/2020 PTS ID 114976 COA: diamond roof

In accordance with the provisions of Section 320-21 (11) and (12) of the Milwaukee Code of Ordinances, the Milwaukee Historic Preservation Commission has issued a certificate of appropriateness for the work listed above. The work was found to be consistent with preservation guidelines. The following conditions apply to this certificate of appropriateness:

No dormers, chimneys, moldings parapets, or other permanent features will be altered or removed. No box vents, if used, will be visible from the street. If they are installed, they must be on a rear slope not visible from the street and they must be painted to blend with the color of the roofing material. A continuous ridge vent can be installed in place of box vents, but the vent must extend across the entire ridge and not stop short. Built-in rain gutters will be retained and sealed where needed. Valleys must be metal W-shape with no interweaving of shingles. Valleys and flashing must be painted or factory-finished to match the roofing color, unless copper. When installing new flashing at a masonry feature, the flashing must be stepped or cut into the mortar joints. The bricks may not be cut to install flashing at an angle.

We strongly recommend that that the Wisconsin Historical Society's best practices for re-roofing be used to extend the life of your new roof. (Synthetic underlayment is an acceptable alternative to 30lb felt.) <https://www.wisconsinhistory.org/Records/Article/CS4260>

All work must be done in a craftsman-like manner, and must be completed within one year of the date this certificate was issued. Staff must approve any changes or additions to this certificate before work begins. Work that is not completed in accordance with this certificate may be subject to correction orders or citations. If you require technical assistance, please contact Historic Preservation staff as follows: Phone: (414) 286-5712 E-mail: hpc@milwaukee.gov.



If permits are required, you are responsible for obtaining them from the Milwaukee Development Center. If you have questions about permit requirements, please consult the Development Center's web site, www.milwaukee.gov/build, or call (414) 286-8210.



City of Milwaukee Historic Preservation Staff

Copies to: Development Center, Ald. M. Dimitrijevic, Contractor, Inspector Victor Drake

Approved roofing options



Repair or replace skylight



OPENING SKYLIGHT
FOR VENTILATION
"CHICKEN WIRE" REINFORCED
GLASS

BUILDING DESCRIPTION 51