


## CSM Water Tower Parking Structure Lighting Options




Pedestrian view from North East along  
North Terrace Avenue

## Option 1 – Light Poles only along center of Top Tier


- The wattage utilized in this option is approximately **2,000 Watts**.
- This meets IES recommendations for illumination of the parking deck.
- This lighting provides the best min/max ratios and average illumination.



Option 1 – Light Poles only.  
Street level view from North-East



Option 1 – Light Poles only.  
High view from North



Option 1 – Light Poles only.  
Aerial view from East

