

Product Certification Letter

KEEP GOING. KEEP MOVING. KEEP WORKING.™

SPEC MIX

January 14, 2014

Product Description: 80 lb. SPEC MIX® Tuckpoint Mortar

3000 lb. Tuckpoint Mortar

Item Number: 19031

SM19031

Manufacturing Plant: QUIKRETE® - Wisconsin

**COLOR TO BE
FROST 3510**

To: Whom It May Concern

This letter certifies that SPEC MIX Tuckpoint Mortar as referenced above meets the requirements of ASTM C 1714 and the performance requirements of an ASTM C 270 Type O mortar. Please reference the Material Test Report for Item Number 19031 for test results of the design.

The raw materials used in this product formulation meeting the standard specifications include: Type I Portland Cement meeting ASTM C 150, *Standard Specification for Portland Cement*, Hydrated Lime Type S meeting ASTM C 207, *Standard Specification for Hydrated Lime for Masonry Purposes*, and Mason Sand meeting ASTM C 144, *Standard Specification for Aggregate for Masonry Mortar*.

It is available as a standard gray, as well as in a variety of standard and custom colors. For custom colors, or versions with integral water repellent, the finished product item number will vary from the base design item number above depending upon the integral water repellent and / or specific pigment. These versions will also meet the specifications described above.

Mortar property characteristics including compressive strength are specified according to ASTM C 270 with laboratory testing. ASTM C 270 (property specification) is not for use to specify minimum compressive strengths to be achieved by field mixed mortars. Field mixed mortar may be tested according to ASTM C 780 to evaluate mortar properties such as mortar water content or consistency. As defined in ASTM C 1586, compressive strength values determined through ASTM C 780 in the field are **not expected nor required** to achieve the compressive strengths of laboratory tested ASTM C 270 specification mortars.

We are pleased to be of service to you. If you have any questions, please let us know.



Wendy Henry
Quality Assurance Manager

WMH: DM

THE QUIKRETE® COMPANIES Inc.
Technical and Engineering Center
500 Marathon Parkway
Lawrenceville, GA 30046
770.216.9580 • www.quikrete.com
651.994.7120 • www.specmix.com

Material Test Report

KEEP GOING. KEEP MOVING. KEEP WORKING.™



Product Description: 80 lb. SPEC MIX® Mortar
 Item Number: 19031
 Manufacturing Plant: QUIKRETE® of Wisconsin, Inc.

Sample Identification

Test Date:	2/6/2013
Lab Code:	12-2789

Initial Testing

Test	Specification	Results
Water (%)	As required	17
Consistency	105 - 115% @25d	106
Unit Weight	1	120
Set Time		
Air (%)		

Strength Testing

Test Age	Compressive Strength (psi)		Flexural Strength (psi)	
	Specification	Result	Specification	Result
1 day				
3 day				
7 day	1	1140		
28 day	350	1340		

Other Testing

Test	Specification	Test Results
Water Retention	>= 75%	92

Certified by:

Wendy Henry
 Quality Assurance Manager

THE QUIKRETE® COMPANIES Inc.
 Technical and Engineering Center
 500 Marathon Parkway
 Lawrenceville, GA 30046
 770.216.9580 • www.quikrete.com
 651.994.7120 • www.specmix.com