



CCF 101217

224 W Washington St

4-4-2011

Looking north at west sidewalk area of S 2nd St and projecting sign at entrance off of S 2nd St.



CCF 101217

224 W Washington St

4-4-2011

Looking west at the sign projecting into the west sidewalk area of S 2nd St. At 8 feet 6 inches above the sidewalk grade, there is less than the 10 feet of clearance required by Section 244-10 of the Milwaukee Code of Ordinances.