



Tom Barrett
Mayor

Jeanette Kowalik, PhD, MPH, MCHES
Commissioner of Health

www.milwaukee.gov/health

Frank P. Zeidler Municipal Building, 841 North Broadway, 3rd Floor, Milwaukee, WI 53202-3653

phone (414) 286-3521

fax (414) 286-5990

September 27th, 2019

Milwaukee Academy of Science
2000 West Kilbourn Avenue
Milwaukee, WI 53233

The City of Milwaukee Health Department (MHD) conducted water sampling as stated in Common Council Resolution File Number 171520. The collected water samples were analyzed for lead to determine if there were any detected lead levels in the water outlets. All sampling procedures were done according to the United States Environmental Protection Agency (EPA) *3Ts for Reducing Lead in Drinking Water in Schools Guidance* (3Ts).

Sampling and Testing

The collection of the samples took place on the morning of May 11, 2019. A total of 136 water outlets were sampled in the school. After the water was stagnant for a minimum of 8 hours, 250 milliliter (mL) water samples were collected before the water was used in the building. Each outlet was tested twice, the second sample was taken after the water was run for 30 seconds after the first draw. Each sample was labeled with the location, date, and time sampled. After finishing the sample collection, the samples were submitted to the City of Milwaukee Health Department Laboratory, a certified drinking water laboratory (ID: 241311290) with the Wisconsin Department of Natural Resources, for lead analysis.

Results

Please see the attached Water Sample Results Table for a summary of the water sample results. 58 samples had detectable levels of lead ranging from 1.0 µg/L (micrograms per liter) to 4.9 µg/L. However, the 12 samples had detectable levels of lead greater than 5.0 µg/L. The rest of the outlets had lead levels below 1.0 µg/L.

There is no safe level of lead in water. MHD provides recommendations for each outlet on the attached Water Sample Results Table. Any water outlet designed specifically for drinking (e.g. bubbler, water fountain, etc.) that has detectable levels of lead should be taken out of service, install a certified drinking water filter for lead removal, or provide bottled water from a lead-free source. Any water outlet that is not designed specifically for drinking (e.g., sink, washbasin, etc.) that has detectable levels of lead should be considered for placarding if the lead level is less than 5.0 µg/L, and must be placarded (or, alternatively, filtered or removed from service) for levels higher than 5.0 µg/L. Any remediation activities or additional water samples that may need to be completed will be done at the cost of the school and/or the property owner.

The only way to determine if a child has been lead poisoned is to have their blood tested. Parents/Guardians can have their child tested at their primary care physician. MHD recommends that a child be tested for lead three times before the age of three. If children weren't tested before the age of three, MHD recommends testing children up to the age of six. For older children, parents should talk to their medical provider about their child's exposure risk.

Please share these results with Parents/Guardians, staff, and students. As stated in the 3Ts, Parents/Guardians, staff, and students should be notified of the water testing and the testing results. If there are any questions regarding lead poisoning, please contact the MHD Childhood Lead Poisoning Prevention Program at 414-286-2165 or go to www.lead-safeMKE.com. If there are any questions or concerns about your results or remediation options, please call me at (414) 286-3451.

Sincerely,


Ofelia R. Mondragon, BBM
Home Environment Health Manager

Encl: Water Sample Results Table, Lead in Drinking Water Chain of Custody and Requisition Forms, and MHD Laboratory Results



Milwaukee Academy of Science 2000 West Kilbourn Avenue		Lead Results (µg/L)				MHD Recommendations as of 5/11/2019
Sample Number	Sample Description	~5/20/2017	10/13/2018	5/11/2019	5/11/2019 30 sec flush	
1	Room B10 Laboratory Sink	9.5	21.0	22.0	<1.0	Placard
2	Cafeteria Dish Sink	<1.0	1.4	<1.0	<1.0	No Action
3	Cafeteria Hand Sink	<1.0	<1.0	1.7	<1.0	No Action
4	Cafeteria Men's Room Sink	<1.0	--	<1.0	<1.0	No Action
5	Cafeteria Women's Room Sink	1.0	<1.0	1.0	<1.0	Consider Placard
6	Gym Bubblers Tall	<1.0	<1.0	<1.0	<1.0	No Action
7	Gym Bubblers Short	<1.0	<1.0	<1.0	<1.0	No Action
8	Women's Gym Locker Room Sink	<1.0	<1.0	<1.0	<1.0	No Action
9	Men's Gym Locker Room Sink	<1.0	<1.0	<1.0	<1.0	No Action
10	Elementary Entrance Bubblers Tall	<1.0	<1.0	<1.0	<1.0	No Action
11	Elementary Entrance Bubblers Short	<1.0	<1.0	<1.0	<1.0	No Action
12	Elementary Entrance Office Sink Short	<1.0	<1.0	--	--	No Action
13	Elementary Entrance Office Sink Tall	<1.0	1.4	7.6	<1.0	Placard
14	Women's Room By 106 Left	1.1	<1.0	1.1	<1.0	Consider Placard
15	Women's Room By 106 Left Middle 1	1.1	<1.0	1.0	<1.0	Consider Placard
16	Women's Room By 106 Left Middle 2	<1.0	<1.0	1.0	<1.0	Consider Placard
17	Women's Room By 106 Middle Right	<1.0	<1.0	1.1	<1.0	Consider Placard
18	Women's Room By 106 Right	<1.0	<1.0	<1.0	<1.0	No Action
19	Bubblers Stairs - B Tall	<1.0	<1.0	<1.0	<1.0	No Action
20	Bubblers Stairs - B Short	<1.0	<1.0	<1.0	<1.0	No Action
21	Men's Room Sink Across From Room 104 Left	<1.0	<1.0	<1.0	<1.0	No Action
22	Men's Room Sink Across From Room 104 Middle	<1.0	<1.0	<1.0	<1.0	No Action
23	Men's Room Sink Across From Room 104 Right	<1.0	<1.0	<1.0	1.3	Consider Placard
24	Unisex Bathroom Sink Across From Room 104	<1.0	<1.0	1.1	1.0	Consider Placard
25	Room 104 Island Sink Station 5	<1.0	<1.0	2.5	<1.0	Consider Placard
26	Room 104 Island Sink Station 4	<1.0	<1.0	1.1	<1.0	Consider Placard
27	Room 104 Sink Station 3	1.2	3.0	3.4	1.1	Consider Placard
28	Room 104 Station 2	<1.0	<1.0	8.0	1.7	Placard
29	Room 104 Station 1	<1.0	<1.0	2.4	<1.0	Consider Placard
30	Room 104 Eye Wash	--	--	--	--	Re-test before Back in Service
31	Office Staff Restroom Sink Next to 100B	1.4	<1.0	--	--	Re-test before Back in Service
32	Staff Kitchen Sink	<1.0	<1.0	1.2	1.0	Consider Placard
33	Staff Kitchen Fridge	--	--	--	--	Re-test before Back in Service
34	Cafeteria Bubblers Tall	<1.0	<1.0	1.0	<1.0	Consider Placard
35	Cafeteria Bubblers Short	<1.0	<1.0	<1.0	<1.0	No Action
36	Cafeteria Sink Left	<1.0	1.2	1.4	1.0	Consider Placard
37	Cafeteria Sink Right	17	1.5	1.0	2.0	Consider Placard
38	Cafeteria Janitor Sink	--	--	2.0	2.0	Consider Placard
39	Auditorium Hall Bubblers	--	--	--	--	Re-test before Back in Service
40	Room 101 Sink	2.0	1.5	1.9	<1.0	Consider Placard
41	Room 102 Bathroom Sink	<1.0	1.1	1.4	<1.0	Consider Placard
42	Hallway Bubblers Tall	<1.0	<1.0	<1.0	1.2	Consider Placard
43	Hallway Bubblers Short	<1.0	<1.0	1.1	<1.0	Consider Placard
44	Staff and Visitor Bathroom Sink (Deanna Utsey)	1.0	1.5	1.3	<1.0	Consider Placard
45	Hallway Women's Room Sink Near Entrance Left	<1.0	<1.0	<1.0	<1.0	No Action
46	Hallway Women's Room Sink Near Entrance Right	<1.0	<1.0	1.0	<1.0	Consider Placard
47	Hallway Women's Room Sink Near Entrance	<1.0	--	<1.0	<1.0	No Action
48	Janitors Closet Slop Sink Near Entrance	<1.0	<1.0	<1.0	<1.0	No Action
49	Hallway Men's Room Sink Near Entrance Left	<1.0	--	<1.0	<1.0	No Action
50	Hallway Men's Room Sink Near Entrance Middle	<1.0	<1.0	<1.0	<1.0	No Action
51	Hallway Men's Room Sink Near Entrance Right	<1.0	<1.0	<1.0	<1.0	No Action
52	Room 114 Bathroom Sink	<1.0	1.6	2.5	1.4	Consider Placard
53	Room 115 Sink	<1.0	1.3	1.1	<1.0	Consider Placard
54	Bubblers Outside Room 139	<1.0	<1.0	<1.0	<1.0	No Action
55	Slop Sink Between Washer and Dryer	<1.0	2.4	<1.0	<1.0	No Action
56	Restroom Next to Room 135 Sink	1.4	<1.0	1.2	<1.0	Consider Placard

Milwaukee Academy of Science 2000 West Kilbourn Avenue		Lead Results (µg/L)		5/11/2019	5/11/2019 30 sec flush	MHD Recommendations as of 5/11/2019
Sample Number	Sample Description	~5/20/2017	10/13/2018			
57	Teacher Room 135 Kitchen Sink	<1.0	1.2	1.2	<1.0	Consider Placard
58	Teacher Room 135 Bathroom Sink Left	<1.0	1.3	1.2	<1.0	Consider Placard
59	Teacher Room 135 Bathroom Sink Right	2.6	3.0	3.7	<1.0	Consider Placard
60	Bubbler Across From Room 135 Tall	<1.0	<1.0	<1.0	<1.0	No Action
61	Bubbler Across From Room 135 Short	<1.0	<1.0	<1.0	<1.0	No Action
62	Room 136 Bathroom Sink	2.9	<1.0	1.3	<1.0	Consider Placard
63	Room 120 Sink	1.3	2.2	3.4	2.0	Consider Placard
64	Room 120 Bathroom Sink Girls	<1.0	2.0	3.3	<1.0	Consider Placard
65	Room 120 Bathroom Sink Boys	1.5	1.7	2.0	<1.0	Consider Placard
66	Bubbler Across From Service Elevator Connecting Hall Tall	<1.0	<1.0	<1.0	<1.0	No Action
67	Bubbler Across From Service Elevator Connecting Hall Short	<1.0	<1.0	<1.0	<1.0	No Action
68	Room 110 Sink	<1.0	78.0	520.0	4.4	Placard
69	Room 110 Bathroom Sink	1.1	2.3	2.1	<1.0	Consider Placard
70	Mr. McHenry Office Sink Foot Pedal	<1.0	<1.0	<1.0	<1.0	No Action
71	Mr. McHenry Office Sink	--	--	--	--	Re-test before Back in Service
72	Mr. McHenry Bathroom Sink	<1.0	<1.0	<1.0	<1.0	No Action
73	Room 124 Sink	160	--	--	--	Re-test before Back in Service
74	Room 124 Bathroom Sink	260	3.1	2.5	<1.0	Consider Placard
75	Room 125 Sink	<1.0	<1.0	2.4	<1.0	Consider Placard
76	Room 125 Bathroom Sink	1.1	<1.0	2.6	<1.0	Consider Placard
77	Bubbler Outside Room 130 Tall	<1.0	<1.0	<1.0	<1.0	No Action
78	Bubbler Outside Room 130 Short	<1.0	<1.0	<1.0	<1.0	No Action
79	Room 209 Sink	<1.0	<1.0	<1.0	<1.0	No Action
80	Men's Room Sink (Trustworthiness) Right	--	<1.0	<1.0	<1.0	No Action
81	Men's Room Sink (Trustworthiness) Middle	<1.0	<1.0	<1.0	<1.0	No Action
82	Men's Room Sink (Trustworthiness) Left	<1.0	<1.0	<1.0	<1.0	No Action
83	Janitor's Closet Slop Sink	33	<1.0	<1.0	1.3	Consider Placard
84	Women's Room Sink (Fairness) Right	<1.0	<1.0	<1.0	<1.0	No Action
85	Women's Room Sink (Fairness) Middle	<1.0	<1.0	<1.0	<1.0	No Action
86	Women's Room Sink (Fairness) Left	<1.0	<1.0	<1.0	<1.0	No Action
87	Room 203 Sink	1.6	1.8	2.2	1.2	Consider Placard
88	Bubbler Between Room 202 and 203	1.1	--	--	--	Re-test before Back in Service
89	STEM Computer Lab Room 219 Sink	6.2	2.1	3.9	2.3	Consider Placard
90	Room 220 Sink	<1.0	1.4	2.3	<1.0	Consider Placard
91	Bubbler Outside Room 220 Tall Left	<1.0	<1.0	<1.0	<1.0	No Action
92	Bubbler Outside Room 220 Tall Right	<1.0	1.3	--	--	Take Out of Service or Install a Certified Drinking Water Filter
93	Bubbler Outside Room 220 Short	<1.0	<1.0	--	--	Re-test before Back in Service
94	Room 201 Sink	2.2	2.9	4.5	<1.0	Consider Placard
95	Bubbler Between Room 209 and 231	<1.0	--	--	--	Re-test before Back in Service
96	Room 232 Sink	<1.0	<1.0	<1.0	<1.0	No Action
97	Janitor's Closet Slop Sink Past Room 232	--	92.0	3.6	37.0	Placard
98	Room 230 Sink	<1.0	2.7	<1.0	<1.0	No Action
99	Room 234 Sink	<1.0	<1.0	<1.0	<1.0	No Action
100	Bubbler Between Room 235 and 239	2.0	<1.0	2.7	25	Placard
101	Room 228 Sink	<1.0	<1.0	<1.0	<1.0	No Action
102	Bubbler Across From Service Elevator Tall	<1.0	<1.0	<1.0	<1.0	No Action
103	Bubbler Across From Service Elevator Short	<1.0	<1.0	<1.0	<1.0	No Action
104	Room 215 Sink	4.6	<1.0	1.0	<1.0	Consider Placard
105	Room 223 Sink	<1.0	<1.0	<1.0	<1.0	No Action
106	Room 240 Sink	1.1	<1.0	<1.0	<1.0	No Action
107	Bubbler Outside Room 241 Tall Left	<1.0	<1.0	<1.0	<1.0	No Action
108	Bubbler Outside Room 241 Tall Right	<1.0	<1.0	<1.0	<1.0	No Action
109	Bubbler Outside Room 241 Short	<1.0	<1.0	<1.0	<1.0	No Action
110	Women's Room Sink By Blue Doors	6.4	4.3	6.3	<1.0	Placard
111	Bubbler Between Restrooms	<1.0	<1.0	3.7	12	Placard
112	Men's Room Sink By Blue Doors	7.3	4.6	8.5	<1.0	Placard
113	Room 211 Science Lab Sink (Badger Door)	35	--	--	--	Re-test before Back in Service
114	Women's Room Sink Across From Stairs-B Left	--	9.0	6.8	5.7	Placard

Milwaukee Academy of Science 2000 West Kilbourn Avenue		Lead Results (µg/L)		5/11/2019	5/11/2019 30 sec flush	MHD Recommendations as of 5/11/2019
Sample Number	Sample Description	~5/20/2017	10/13/2018			
115	Women's Room Sink Across From Stairs-B Middle	<1.0	<1.0	<1.0	<1.0	No Action
116	Women's Room Sink Across From Stairs-B Right	<1.0	<1.0	<1.0	<1.0	No Action
117	Bubbler Between Bathroom Tall	<1.0	<1.0	<1.0	<1.0	No Action
118	Bubbler Between Bathroom Short	<1.0	<1.0	<1.0	<1.0	No Action
119	Men's Room Sink (Locker 180) Left	<1.0	3.3	<1.0	1.1	Consider Placard
120	Men's Room Sink (Locker 180) Right	1.1	1.5	<1.0	<1.0	No Action
121	Room 206 Science Lab Station 1	<1.0	2.2	10.0	7.9	Placard
122	Room 206 Science Lab Station 2	6.5	2.4	4.8	3.2	Consider Placard
123	Room 206 Science Lab Station 3	3.1	1.4	1.2	<1.0	Consider Placard
124	Room 206 Science Lab Station 4	6.1	1.5	1.7	<1.0	Consider Placard
125	Room 206 Science Lab Station 5	<1.0	<1.0	1.0	1.3	Consider Placard
126	Room 206 Science Lab Station 6	<1.0	2.4	2.3	1.1	Consider Placard
127	Room 206 Science Lab Station 7 (Island Sink)	3.9	19.0	--	--	Re-test before Back in Service
128	Hood	250	--	--	--	Re-test before Back in Service
129	Eye Wash	--	--	--	--	Re-test before Back in Service
130	Room 205 Nurses Room Sink	2.0	1.0	1.6	<1.0	Consider Placard
131	Staff Only Sink Next to Room 205	2.3	<1.0	1.5	<1.0	Consider Placard
132	Room 311 Sink	2.4	2.7	2.8	2.1	Consider Placard
133	Men's Room Sink Near Room 311 (JA Drop Box) Left	<1.0	<1.0	<1.0	<1.0	No Action
134	Men's Room Sink Near Room 311 (JA Drop Box) Middle	<1.0	<1.0	<1.0	<1.0	No Action
135	Men's Room Sink Near Room 311 Right	<1.0	<1.0	<1.0	<1.0	No Action
136	Janitor's Closet Slop Sink	--	<1.0	2.0	1.3	Consider Placard
137	Bubbler Tall	<1.0	<1.0	<1.0	<1.0	No Action
138	Bubbler Short	<1.0	<1.0	1.1	<1.0	Consider Placard
139	Women's Room Sink Right	<1.0	<1.0	<1.0	<1.0	No Action
140	Women's Room Sink Middle	<1.0	<1.0	<1.0	<1.0	No Action
141	Women's Room Sink Left	<1.0	<1.0	1.0	<1.0	Consider Placard
142	Room 319 Sink (Ziegelbauer)	<1.0	<1.0	--	--	Re-test before Back in Service
143	Bubbler Across From Room 320 Tall	--	--	--	--	Re-test before Back in Service
144	Bubbler Across From Room 320 Short	--	--	--	--	Re-test before Back in Service
145	Room 320 Computer Lab Bathroom Sink Right	1.8	1.2	3.8	<1.0	Consider Placard
146	Room 320 Computer Lab Bathroom Sink Left	5.0	1.5	2.2	<1.0	Consider Placard
147	Bubbler Next to Room 304	<1.0	<1.0	<1.0	<1.0	No Action
148	Bubbler Across From Room 322 Library	<1.0	<1.0	<1.0	<1.0	No Action
149	Room 334 Sink	<1.0	<1.0	<1.0	<1.0	No Action
150	Bubbler Across From Room 329 Tall	<1.0	<1.0	--	--	Re-test before Back in Service
151	Bubbler Across From Room 329 Short	<1.0	<1.0	--	--	Re-test before Back in Service
152	Room 329 Sink	<1.0	<1.0	<1.0	<1.0	No Action
153	Bubbler Between Room 331 and 312 Tall (Locker 171)	<1.0	<1.0	<1.0	<1.0	No Action
154	Bubbler Between Room 331 and 312 Short (Locker 171)	<1.0	<1.0	<1.0	<1.0	No Action
155	Room 104 Island Sink	2.4	5.0	--	--	Re-test before Back in Service
156	Cafeteria Dish Sink 2	--	<1.0	<1.0	<1.0	No Action
157	Room B10 Laboratory Sink Middle	--	2.9	5.6	<1.0	Placard
158	Room 228 Bathroom Sink	--	--	2.7	<1.0	Consider Placard
159	Room 215 Bathroom Sink	--	--	1.6	<1.0	Consider Placard

Results indicated in red exceed the 5 parts per billion (ppb) standard established by the City of Milwaukee Common Council in Resolution File Number 171520

The 2018 samples were collected by the City of Milwaukee Health Department and analyzed by the City of Milwaukee Health Department Laboratory

Definitions:

1 µg/L = 1 ppb

~ Samples collected by Milwaukee Water Works (MWW) and analyzed by Eurofins. MWW utilized 15 ppb as the lead in drinking water standard.

--: No Sample Taken. Outlet Out of Service

* Outlet was not found. No Sample Taken.

Outlet replaced by the school.

Placard: City of Milwaukee May Contain Lead Not Safe For Drinking Sign

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1280062
LRN : 0000279771
Auxiliary ID : Sample #1
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Closest to sink B10

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*22.0			ug Pb/L	05/29/19 10:38
Test Method	*see below				05/29/19 10:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1280064
LRN : 0000279771
Auxiliary ID : Sample #2
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Closest to sink B10 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:38
Test Method	*see below				05/29/19 10:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1280066
LRN : 0000279771
Auxiliary ID : Sample #3
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Small sink B10 rear

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*5.6			ug Pb/L	05/29/19 10:38
Test Method	*see below				05/29/19 10:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280068
 LRN : 0000279771
 Auxiliary ID : Sample #4
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Small sink B10 rear 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:38
Test Method	*see below				05/29/19 10:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280076
 LRN : 0000279771
 Auxiliary ID : Sample #5
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Cafeteria Dish sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:38
Test Method	*see below				05/29/19 10:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280078
 LRN : 0000279771
 Auxiliary ID : Sample #6
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Cafeteria dish sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:38
Test Method	*see below				05/29/19 10:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280080
 LRN : 0000279771
 Auxiliary ID : Sample #7
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Cafeteria hand sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.7			ug Pb/L	05/29/19 10:38
Test Method	*see below				05/29/19 10:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280082
 LRN : 0000279771
 Auxiliary ID : Sample #8
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Cafeteria hand sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:38
Test Method	*see below				05/29/19 10:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280083
 LRN : 0000279771
 Auxiliary ID : Sample #9
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Cafeteria men's room sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:39
Test Method	*see below				05/29/19 10:39

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280084
 LRN : 0000279771
 Auxiliary ID : Sample #10
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Cafeteria men's room sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:39
Test Method	*see below				05/29/19 10:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280085
 LRN : 0000279771
 Auxiliary ID : Sample #11
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Cafeteria women's room sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.0			ug Pb/L	05/29/19 10:39
Test Method	*see below				05/29/19 10:39

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280086
 LRN : 0000279771
 Auxiliary ID : Sample #12
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Cafeteria women's room sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:39
Test Method	*see below				05/29/19 10:39

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1280091
LRN : 0000279771
Auxiliary ID : Sample #13
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Gym bubbler tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	05/29/19 10:39
Test Method	*see below				05/29/19 10:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1280093
LRN : 0000279771
Auxiliary ID : Sample #14
Date Collected: 05/01/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
Gym bubbler tall 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:39
Test Method	*see below				05/29/19 10:39

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280094
 LRN : 0000279771
 Auxiliary ID : Sample #15
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Gym bubbler short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:39
Test Method	*see below				05/29/19 10:39

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280095
 LRN : 0000279771
 Auxiliary ID : Sample #16
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Gym bubbler short 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:39
Test Method	*see below				05/29/19 10:39

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1280102
LRN : 0000279771
Auxiliary ID : Sample #17
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Women's Gym Locker Room Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	05/29/19 10:39
Test Method	*see below				05/29/19 10:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280110
 LRN : 0000279771
 Auxiliary ID : Sample #18
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Gym Locker Room Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:40
Test Method	*see below				05/29/19 10:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280111
 LRN : 0000279771
 Auxiliary ID : Sample #19
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Men's Gym Locker Room Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:40
Test Method	*see below				05/29/19 10:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High; AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280112
 LRN : 0000279771
 Auxiliary ID : Sample #20
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Men's Gym Locker Room Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	05/29/19 10:40
Test Method	*see below				05/29/19 10:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1280113
LRN : 0000279771
Auxiliary ID : Sample #21
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Elementary Entrance Bubbler Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:40
Test Method	*see below				05/29/19 10:40

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1280114
LRN : 0000279771
Auxiliary ID : Sample #22
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Elementary Entrance Bubbler Tall
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	05/29/19 10:40
Test Method	*see below				05/29/19 10:40

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280115
 LRN : 0000279771
 Auxiliary ID : Sample #23
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Elementary Entrance Bubbler Short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:40
Test Method	*see below				05/29/19 10:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1280118
LRN : 0000279771
Auxiliary ID : Sample #24
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Elementary Entrance Bubbler Short.
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:40
Test Method	*see below				05/29/19 10:40

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280120
 LRN : 0000279771
 Auxiliary ID : Sample #25
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Elementary Entrance Office Sink Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*7.6			ug Pb/L	05/29/19 10:40
Test Method	*see below				05/29/19 10:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280121
 LRN : 0000279771
 Auxiliary ID : Sample #26
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Elementary Entrance Office Sink Tall
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	05/29/19 10:40
Test Method	*see below				05/29/19 10:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280122
 LRN : 0000279771
 Auxiliary ID : Sample #27
 Date Collected: 05/01/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room By 106 Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.1			ug Pb/L	05/29/19 10:41
Test Method	*see below				05/29/19 10:41

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1280123
 LRN : 0000279771
 Auxiliary ID : Sample #28
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURN AV, 2000	DOB:	Age:	Sex:
--------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Women's Room By 106 Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/29/19 10:41
Test Method	*see below				05/29/19 10:41

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1290171
 LRN : 0000279771
 Auxiliary ID : Sample #29
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room By 106 Left Middle 1

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.0			ug Pb/L	05/30/19 10:58
Test Method	*see below				05/30/19 10:58

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1290173
 LRN : 0000279771
 Auxiliary ID : Sample #30
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room By 106 Left Middle 1
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/30/19 10:59
Test Method	*see below				05/30/19 10:59

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1290175
 LRN : 0000279771
 Auxiliary ID : Sample #31
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room By 106 Left Middle 2

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.0			ug Pb/L	05/30/19 10:59
Test Method	*see below				05/30/19 10:59

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1290180
LRN : 0000279771
Auxiliary ID : Sample #32
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
Women's Room By 106 Left Middle 2
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/30/19 10:59
Test Method	*see below				05/30/19 10:59

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1290181
LRN : 0000279771
Auxiliary ID : Sample #33
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Women's Room By 106 Middle Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.1			ug Pb/L	05/30/19 10:59
Test Method	*see below				05/30/19 10:59

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1290182
 LRN : 0000279771
 Auxiliary ID : Sample #34
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Women's Room By 106 Middle Right
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/30/19 10:59
Test Method	*see below				05/30/19 10:59

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1290183
 LRN : 0000279771
 Auxiliary ID : Sample #35
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Women's Room By 106 Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/30/19 10:59
Test Method	*see below				05/30/19 10:59

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1290184
 LRN : 0000279771
 Auxiliary ID : Sample #36
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Women's Room By 106 Right
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/30/19 11:01
Test Method	*see below				05/30/19 11:01

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300008
 LRN : 0000279771
 Auxiliary ID : Sample #37
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubblers Stairs - B Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/30/19 11:01
Test Method	*see below				05/30/19 11:01

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300009
 LRN : 0000279771
 Auxiliary ID : Sample #38
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubblers Stairs - B Tall
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/30/19 11:02
Test Method	*see below				05/30/19 11:02

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1300010
LRN : 0000279771
Auxiliary ID : Sample #39
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
Bubbler Stairs - B Short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	05/30/19 11:02
Test Method	*see below				05/30/19 11:02

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300011
 LRN : 0000279771
 Auxiliary ID : Sample #40
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubblers Stairs - B Short
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/30/19 11:02
Test Method	*see below				05/30/19 11:02

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

Sanjib Bhattacharyya, Ph.D.

Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300013
 LRN : 0000279771
 Auxiliary ID : Sample #41
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink Across From Room 104 Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/30/19 11:02
Test Method	*see below				05/30/19 11:02

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1300014
LRN : 0000279771
Auxiliary ID : Sample #42
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Men's Room Sink Across From Room 104 Left
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	05/30/19 11:02
Test Method	*see below				05/30/19 11:02

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1300015
LRN : 0000279771
Auxiliary ID : Sample #43
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Men's Room Sink Across From Room 104 Middle

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/30/19 11:02
Test Method	*see below				05/30/19 11:02

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300016
 LRN : 0000279771
 Auxiliary ID : Sample #44
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink Across From Room 104 Middle
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	05/30/19 11:02
Test Method	*see below				05/30/19 11:02

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1300017
LRN : 0000279771
Auxiliary ID : Sample #45
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Men's Room Sink Across From Room 104 Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	05/30/19 11:02
Test Method	*see below				05/30/19 11:02

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300018
 LRN : 0000279771
 Auxiliary ID : Sample #46
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink Across From Room 104 Right
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.3			ug Pb/L	05/30/19 11:03
Test Method	*see below				05/30/19 11:03

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300019
 LRN : 0000279771
 Auxiliary ID : Sample #47
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Unisex Bathroom Sink Across From Room 104

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.1			ug Pb/L	05/30/19 11:03
Test Method	*see below				05/30/19 11:03

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300020
 LRN : 0000279771
 Auxiliary ID : Sample #48
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Unisex Bathroom Sink Across From Room 104
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.0			ug Pb/L	05/30/19 11:03
Test Method	*see below				05/30/19 11:03

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300021
 LRN : 0000279771
 Auxiliary ID : Sample #49
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 104 Island Sink Station 5

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.5			ug Pb/L	06/03/19 16:14
Test Method	*see below				06/03/19 16:14

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300022
 LRN : 0000279771
 Auxiliary ID : Sample #50
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 104 Island Sink Station 5
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/03/19 16:15
Test Method	*see below				06/03/19 16:15

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300023
 LRN : 0000279771
 Auxiliary ID : Sample #51
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 104 Island Sink Station 4

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.1			ug Pb/L	06/03/19 16:15
Test Method	*see below				06/03/19 16:15

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300024
 LRN : 0000279771
 Auxiliary ID : Sample #52
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 104 Island Sink Station 4
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/03/19 16:15
Test Method	*see below				06/03/19 16:15

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300025
 LRN : 0000279771
 Auxiliary ID : Sample #53
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 104 Sink Station 3

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*3.4			ug Pb/L	06/03/19 16:15
Test Method	*see below				06/03/19 16:15

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300026
 LRN : 0000279771
 Auxiliary ID : Sample #54
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 104 Sink Station 3
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.1			ug Pb/L	06/03/19 16:15
Test Method	*see below				06/03/19 16:15

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300027
 LRN : 0000279771
 Auxiliary ID : Sample #55
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 104 Station 2

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*8.0			ug Pb/L	06/03/19 16:16
Test Method	*see below				06/03/19 16:16

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300028
 LRN : 0000279771
 Auxiliary ID : Sample #56
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 104 Station 2
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.7			ug Pb/L	06/03/19 16:16
Test Method	*see below				06/03/19 16:16

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300029
 LRN : 0000279771
 Auxiliary ID : Sample #57
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 104 Station 1

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.4			ug Pb/L	06/03/19 16:16
Test Method	*see below				06/03/19 16:16

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1300030
LRN : 0000279771
Auxiliary ID : Sample #58
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Room 104 Station 1
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/03/19 16:16
Test Method	*see below				06/03/19 16:16

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1300031
LRN : 0000279771
Auxiliary ID : Sample #59
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Staff Kitchen Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.2			ug Pb/L	06/03/19 16:16
Test Method	*see below				06/03/19 16:16

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300032
 LRN : 0000279771
 Auxiliary ID : Sample #60
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Staff Kitchen Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.0			ug Pb/L	06/03/19 16:16
Test Method	*see below				06/03/19 16:16

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300033
 LRN : 0000279771
 Auxiliary ID : Sample #61
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Cafeteria Bubblers Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/03/19 16:16
Test Method	*see below				06/03/19 16:16

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300034
 LRN : 0000279771
 Auxiliary ID : Sample #62
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Cafeteria Bubblers Tall
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/03/19 16:17
Test Method	*see below				06/03/19 16:17

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300035
 LRN : 0000279771
 Auxiliary ID : Sample #63
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Cafeteria Bubblers Short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/03/19 16:17
Test Method	*see below				06/03/19 16:17

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300036
 LRN : 0000279771
 Auxiliary ID : Sample #64
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Cafeteria Bubblers Short
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/03/19 16:17
Test Method	*see below				06/03/19 16:17

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1300067
LRN : 0000279771
Auxiliary ID : Sample #65
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
Cafeteria Sink Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.4			ug Pb/L	06/03/19 16:17
Test Method	*see below				06/03/19 16:17

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300068
 LRN : 0000279771
 Auxiliary ID : Sample #66
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Cafeteria Sink Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.0			ug Pb/L	06/03/19 16:17
Test Method	*see below				06/03/19 16:17

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1300070
LRN : 0000279771
Auxiliary ID : Sample #67
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Cafeteria Janitor Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.0			ug Pb/L	06/03/19 16:17
Test Method	*see below				06/03/19 16:17

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1300072
LRN : 0000279771
Auxiliary ID : Sample #68
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Cafeteria Janitor Sink
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.0			ug Pb/L	06/03/19 16:17
Test Method	*see below				06/03/19 16:17

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300077
 LRN : 0000279771
 Auxiliary ID : Sample #69
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 101 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.9			ug Pb/L	06/03/19 16:18
Test Method	*see below				06/03/19 16:18

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300078
 LRN : 0000279771
 Auxiliary ID : Sample #70
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 101 Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/03/19 16:18
Test Method	*see below				06/03/19 16:18

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S1300079
LRN : 0000279771
Auxiliary ID : Sample #71
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
Room 102 Bathroom Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.4			ug Pb/L	06/03/19 16:19
CORRECTED RESULT: Previously reported as 5.6 on 06/03/19 at 16:18.					
Test Method	*see below				06/03/19 16:18

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S1300080
 LRN : 0000279771
 Auxiliary ID : Sample #72
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 102 Bathroom Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/03/19 16:20
Test Method	*see below				06/03/19 16:20

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030051
 LRN : 0000279771
 Auxiliary ID : Sample #73
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Hallway Bubbler Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/03/19 16:21
Test Method	*see below				06/03/19 16:21

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030052
 LRN : 0000279771
 Auxiliary ID : Sample #74
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Hallway Bubbler Tall
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.2			ug Pb/L	06/03/19 16:21
Test Method	*see below				06/03/19 16:21

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030054
 LRN : 0000279771
 Auxiliary ID : Sample #75
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Hallway Bubbler Short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.1			ug Pb/L	06/03/19 16:21
Test Method	*see below				06/03/19 16:21

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030059
 LRN : 0000279771
 Auxiliary ID : Sample #76
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Hallway Bubblers Short
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/03/19 16:23
Test Method	*see below				06/03/19 16:23

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030064
 LRN : 0000279771
 Auxiliary ID : Sample #77
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Staff and Visitor Bathroom Sink (Deanna Utsey)

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.3			ug Pb/L	06/03/19 16:23
Test Method	*see below				06/03/19 16:23

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2030065
LRN : 0000279771
Auxiliary ID : Sample #78
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Staff and Visitor Bathroom Sink (Deanna Utsey)
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/03/19 16:23
Test Method	*see below				06/03/19 16:23

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030066
 LRN : 0000279771
 Auxiliary ID : Sample #79
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Hallway Women's Room Sink Near Entrance Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/03/19 16:23
Test Method	*see below				06/03/19 16:23

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030068
 LRN : 0000279771
 Auxiliary ID : Sample #80
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Hallway Women's Room Sink Near Entrance Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/03/19 16:24
Test Method	*see below				06/03/19 16:24

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2030069
LRN : 0000279771
Auxiliary ID : Sample #81
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
Hallway Women's Room Sink Near Entrance Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.0			ug Pb/L	06/03/19 16:24
Test Method	*see below				06/03/19 16:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

Sanjib Bhattacharyya, Ph.D.

Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030070
 LRN : 0000279771
 Auxiliary ID : Sample #82
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Hallway Women's Room Sink Near Entrance Right
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/03/19 16:24
Test Method	*see below				06/03/19 16:24

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030072
 LRN : 0000279771
 Auxiliary ID : Sample #83
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Hallway Women's Room Sink Near Entrance

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/03/19 16:24
Test Method	*see below				06/03/19 16:24

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030073
 LRN : 0000279771
 Auxiliary ID : Sample #84
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Hallway Women's Room Sink Near Entrance
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/03/19 16:24
Test Method	*see below				06/03/19 16:24

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030075
 LRN : 0000279771
 Auxiliary ID : Sample #85
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Janitors Closet Slop Sink Near Entrance

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/03/19 16:24
Test Method	*see below				06/03/19 16:24

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030076
 LRN : 0000279771
 Auxiliary ID : Sample #86
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Janitors Closet Slop Sink Near Entrance
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/04/19 14:32
Test Method	*see below				06/04/19 14:32

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030078
 LRN : 0000279771
 Auxiliary ID : Sample #87
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Hallway Men's Room Sink Near Entrance Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:32
Test Method	*see below				06/04/19 14:32

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030080
 LRN : 0000279771
 Auxiliary ID : Sample #88
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Hallway Men's Room Sink Near Entrance Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/04/19 14:32
Test Method	*see below				06/04/19 14:32

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030081
 LRN : 0000279771
 Auxiliary ID : Sample #89
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Hallway Men's Room Sink Near Entrance Middle

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/04/19 14:32
Test Method	*see below				06/04/19 14:32

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030082
 LRN : 0000279771
 Auxiliary ID : Sample #90
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Hallway Men's Room Sink Near Entrance Middle
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:32
Test Method	*see below				06/04/19 14:32

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030083
 LRN : 0000279771
 Auxiliary ID : Sample #91
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Hallway Men's Room Sink Near Entrance Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/04/19 14:32
Test Method	*see below				06/04/19 14:32

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2030084
LRN : 0000279771
Auxiliary ID : Samplw #92
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
Hallway Men's Room Sink Near Entrance Right
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB. NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>				
Sample	*<1.0		ug Pb/L	06/04/19 14:32
Test Method	*see below			06/04/19 14:32

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030094
 LRN : 0000279771
 Auxiliary ID : Sample #93
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 114 Bathroom Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.5			ug Pb/L	06/04/19 14:33
Test Method	*see below				06/04/19 14:33

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2030095
LRN : 0000279771
Auxiliary ID : Sample #94
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
Room 114 Bathroom Sink
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.4			ug Pb/L	06/04/19 14:33
Test Method	*see below				06/04/19 14:33

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030097
 LRN : 0000279771
 Auxiliary ID : Sample #95
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 115 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.1			ug Pb/L	06/04/19 14:33
Test Method	*see below				06/04/19 14:33

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030098
 LRN : 0000279771
 Auxiliary ID : Sample #96
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 115 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:33
Test Method	*see below				06/04/19 14:33

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030099
 LRN : 0000279771
 Auxiliary ID : Sample #97
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Outside Room 139

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/04/19 14:33
Test Method	*see below				06/04/19 14:33

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030100
 LRN : 0000279771
 Auxiliary ID : Sample #98
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubblor Outside Room 139
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:33
Test Method	*see below				06/04/19 14:33

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2030101
LRN : 0000279771
Auxiliary ID : Sample #99
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
Slop Sink Between Washer and Dryer

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/04/19 14:33
Test Method	*see below				06/04/19 14:33

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: Order ID : S2030102
 DCEH-ENVIRONMENTAL HEALTH SECTION LRN : 0000279771
 841 N. BROADWAY Auxiliary ID : Sample #100
 THIRD FLOOR Date Collected: 05/11/19
 MILWAUKEE, WI 53202 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Slop Sink Between Washer and Dryer
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:33
Test Method	*see below				06/04/19 14:33

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030105
 LRN : 0000279771
 Auxiliary ID : Sample #101
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
 Restroom Next to Room 135 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.2			ug Pb/L	06/04/19 14:34
Test Method	*see below				06/04/19 14:34

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030106
 LRN : 0000279771
 Auxiliary ID : Sample #102
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Restroom Next to Room 135 Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:34
Test Method	*see below				06/04/19 14:34

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2030107
LRN : 0000279771
Auxiliary ID : Sample #103
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
Teacher Room 135 Kitchen Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.2			ug Pb/L	06/04/19 14:34
Test Method	*see below				06/04/19 14:34

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2030109
 LRN : 0000279771
 Auxiliary ID : Sample #104
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Teacher Room 135 Kitchen Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:34
Test Method	*see below				06/04/19 14:34

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040026
 LRN : 0000279771
 Auxiliary ID : Sample #105
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Teacher Room 135 Bathroom Sink Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.2			ug Pb/L	06/04/19 14:34
Test Method	*see below				06/04/19 14:34

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040027
 LRN : 0000279771
 Auxiliary ID : Sample #106
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Teacher Room 135 Bathroom Sink Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:34
Test Method	*see below				06/04/19 14:34

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040028
 LRN : 0000279771
 Auxiliary ID : Sample #107
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Teacher Room 135 Bathroom Sink Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*3.7			ug Pb/L	06/04/19 14:35
Test Method	*see below				06/04/19 14:35

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: Order ID : S2040029
 DCEH-ENVIRONMENTAL HEALTH SECTION LRN : 0000279771
 841 N. BROADWAY Auxiliary ID : Sample #108
 THIRD FLOOR Date Collected: 05/11/19
 MILWAUKEE, WI 53202 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Teacher Room 135 Bathroom Sink Right
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:35
Test Method	*see below				06/04/19 14:35

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: Order ID : S2040030
 DCEH-ENVIRONMENTAL HEALTH SECTION LRN : 0000279771
 841 N. BROADWAY Auxiliary ID : Sample #109
 THIRD FLOOR Date Collected: 05/11/19
 MILWAUKEE, WI 53202 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubblers Across From Room 135 Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:35
Test Method	*see below				06/04/19 14:35

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: Order ID : S2040031
 DCEH-ENVIRONMENTAL HEALTH SECTION LRN : 0000279771
 841 N. BROADWAY Auxiliary ID : Sample #110
 THIRD FLOOR Date Collected: 05/11/19
 MILWAUKEE, WI 53202 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubblers Across From Room 135 Tall
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:35
Test Method	*see below				06/04/19 14:35

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040032
 LRN : 0000279771
 Auxiliary ID : Sample #111
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubblers Across From Room 135 Short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:35
Test Method	*see below				06/04/19 14:35

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040034
 LRN : 0000279771
 Auxiliary ID : Sample #112
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubblers Across From Room 135 Short
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:35
Test Method	*see below				06/04/19 14:35

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040039
 LRN : 0000279771
 Auxiliary ID : Sample #113
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 136 Bathroom Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.3			ug Pb/L	06/04/19 14:35
Test Method	*see below				06/04/19 14:35

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040040
 LRN : 0000279771
 Auxiliary ID : Sample #114
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 136 Bathroom Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:36
Test Method	*see below				06/04/19 14:36

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040042
 LRN : 0000279771
 Auxiliary ID : Sample #115
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000**

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 120 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*3.4			ug Pb/L	06/04/19 14:36
Test Method	*see below				06/04/19 14:36

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040046
 LRN : 0000279771
 Auxiliary ID : Sample #116
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 120 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.0			ug Pb/L	06/04/19 14:36
Test Method	*see below				06/04/19 14:36

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040050
 LRN : 0000279771
 Auxiliary ID : Sample #117
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 120 Bathroom Sink Girls

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*3.3			ug Pb/L	06/04/19 14:36
Test Method	*see below				06/04/19 14:36

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040053
 LRN : 0000279771
 Auxiliary ID : Sample #118
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 120 Bathroom Sink Girls
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:36
Test Method	*see below				06/04/19 14:36

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040056
 LRN : 0000279771
 Auxiliary ID : Sample #119
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 120 Bathroom Sink Boys

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.0			ug Pb/L	06/04/19 14:36
Test Method	*see below				06/04/19 14:36

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040059
 LRN : 0000279771
 Auxiliary ID : Sample #120
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 120 Bathroom Sink Boys
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:36
Test Method	*see below				06/04/19 14:36

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040137
 LRN : 0000279771
 Auxiliary ID : Sample #121
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubblers Across From Service Elevator Connecting Hall Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/04/19 14:37
Test Method	*see below				06/04/19 14:37

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040139
 LRN : 0000279771
 Auxiliary ID : Sample #122
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Across From Service Elevator Connecting Hall Tall
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/04/19 -14:37
Test Method	*see below				06/04/19 14:37

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040140
 LRN : 0000279771
 Auxiliary ID : Sample #123
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Across From Service Elevator Connecting Hall Short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/04/19 14:37
Test Method	*see below				06/04/19 14:37

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040141
 LRN : 0000279771
 Auxiliary ID : Sample #124
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Across From Service Elevator Connecting Hall Short
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/04/19 14:37
Test Method	*see below				06/04/19 14:37

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040142
 LRN : 0000279771
 Auxiliary ID : Sample #125
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 110 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*520.0			ug Pb/L	06/04/19 14:37
Test Method	*see below				06/04/19 14:37

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040143
 LRN : 0000279771
 Auxiliary ID : Sample #126
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 110 Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*4.4			ug Pb/L	06/07/19 14:45
Test Method	*see below				06/07/19 14:45

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040144
 LRN : 0000279771
 Auxiliary ID : Sample #127
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 110 Bathroom Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.1			ug Pb/L	06/07/19 14:45
Test Method	*see below				06/07/19 14:45

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040146
 LRN : 0000279771
 Auxiliary ID : Sample #128
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 110 Bathroom Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/07/19 14:45
Test Method	*see below				06/07/19 14:45

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040149
 LRN : 0000279771
 Auxiliary ID : Sample #129
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Mr. McHenry Office Sink Foot Pedal

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:45
Test Method	*see below				06/07/19 14:45

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040150
 LRN : 0000279771
 Auxiliary ID : Sample #130
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Mr. McHenry Office Sink Foot Pedal
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:45
Test Method	*see below				06/07/19 14:45

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: Order ID : S2040153
 DCEH-ENVIRONMENTAL HEALTH SECTION LRN : 0000279771
 841 N. BROADWAY Auxiliary ID : Sample #131
 THIRD FLOOR Date Collected: 05/11/19
 MILWAUKEE, WI 53202 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Mr. McHenry Bathroom Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:45
Test Method	*see below				06/07/19 14:45

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040155
 LRN : 0000279771
 Auxiliary ID : Sample #132
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Mr. McHenry Bathroom Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	06/07/19 14:45
Test Method	*see below				06/07/19 14:45

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: DCEH-ENVIRONMENTAL HEALTH SECTION 841 N. BROADWAY THIRD FLOOR MILWAUKEE, WI 53202	Order ID : S2040165 LRN : 0000279771 Auxiliary ID : Sample #133 Date Collected: 05/11/19 Date Received : 05/22/19
--	---

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 124 Bathroom Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.5			ug Pb/L	06/07/19 14:45
Test Method	*see below				06/07/19 14:45

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040166
 LRN : 0000279771
 Auxiliary ID : Sample #134
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 124 Bathroom Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:46
Test Method	*see below				06/07/19 14:46

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040167
 LRN : 0000279771
 Auxiliary ID : Sample #135
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 125 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.4			ug Pb/L	06/07/19 14:46
Test Method	*see below				06/07/19 14:46

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040185
 LRN : 0000279771
 Auxiliary ID : Sample #137
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 125 Bathroom Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.6			ug Pb/L	06/07/19 14:46
Test Method	*see below				06/07/19 14:46

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2040186
LRN : 0000279771
Auxiliary ID : Sample #138
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Room 125 Bathroom Sink
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:46
Test Method	*see below				06/07/19 14:46

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: Order ID : S2040187
 DCEH-ENVIRONMENTAL HEALTH SECTION LRN : 0000279771
 841 N. BROADWAY Auxiliary ID : Sample #139
 THIRD FLOOR Date Collected: 05/11/19
 MILWAUKEE, WI 53202 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Outside Room 130 Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:46
Test Method	*see below				06/07/19 14:46

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040188
 LRN : 0000279771
 Auxiliary ID : Sample #140
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Outside Room 130 Tall
 30 sce flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/07/19 14:46
Test Method	*see below				06/07/19 14:46

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: DCEH-ENVIRONMENTAL HEALTH SECTION 841 N. BROADWAY THIRD FLOOR MILWAUKEE, WI 53202	Order ID : S2040189 LRN : 0000279771 Auxiliary ID : Sample #141 Date Collected: 05/11/19 Date Received : 05/22/19
--	---

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubbler Outside Room 130 Short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/07/19 14:47
Test Method	*see below				06/07/19 14:47

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040190
 LRN : 0000279771
 Auxiliary ID : Sample #142
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Outside Room 130 Short
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/07/19 14:47
Test Method	*see below				06/07/19 14:47

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040191
 LRN : 0000279771
 Auxiliary ID : Sample #143
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 209 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:47
Test Method	*see below				06/07/19 14:47

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040192
 LRN : 0000279771
 Auxiliary ID : Sample #144
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 209 Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:47
Test Method	*see below				06/07/19 14:47

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: Order ID : S2040201
LRN : 0000279771
DCEH-ENVIRONMENTAL HEALTH SECTION Auxiliary ID : Sample #145
841 N. BROADWAY Date Collected: 05/11/19
THIRD FLOOR Date Received : 05/22/19
MILWAUKEE, WI 53202

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Men's Room Sink (Trustworthiness) Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:47
Test Method	*see below				06/07/19 14:47

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040202
 LRN : 0000279771
 Auxiliary ID : Sample #146
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink (Trustworthiness) Right
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/07/19 14:47
Test Method	*see below				06/07/19 14:47

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040203
 LRN : 0000279771
 Auxiliary ID : Sample #147
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink (Trustworthiness) Middle

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:47
Test Method	*see below				06/07/19 14:47

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2040205
LRN : 0000279771
Auxiliary ID : Sample #149
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Men's Room Sink (Trustworthiness) Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/07/19 14:48
Test Method	*see below				06/07/19 14:48

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040206
 LRN : 0000279771
 Auxiliary ID : Sample #150
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink (Trustworthiness) Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/07/19 14:48
Test Method	*see below				06/07/19 14:48

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040207
 LRN : 0000279771
 Auxiliary ID : Sample #151
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Janitor's Closet Slop Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:48
Test Method	*see below				06/07/19 14:48

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040208
 LRN : 0000279771
 Auxiliary ID : Sample #152
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Janitor's Closet Slop Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.3			ug Pb/L	06/07/19 14:48
Test Method	*see below				06/07/19 14:48

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: Order ID : S2040210
 DCEH-ENVIRONMENTAL HEALTH SECTION LRN : 0000279771
 841 N. BROADWAY Auxiliary ID : Sample #153
 THIRD FLOOR Date Collected: 05/11/19
 MILWAUKEE, WI 53202 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink (Fairness) Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:48
Test Method	*see below				06/07/19 14:48

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040212
 LRN : 0000279771
 Auxiliary ID : Sample #154
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink (Fairness) Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:48
Test Method	*see below				06/07/19 14:48

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: Order ID : S2040214
 DCEH-ENVIRONMENTAL HEALTH SECTION LRN : 0000279771
 841 N. BROADWAY Auxiliary ID : Sample #155
 THIRD FLOOR Date Collected: 05/11/19
 MILWAUKEE, WI 53202 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink (Fairness) Middle

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/07/19 14:48
Test Method	*see below				06/07/19 14:48

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040216
 LRN : 0000279771
 Auxiliary ID : Sample #156
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink (Fairness) Middle
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:48
Test Method	*see below				06/07/19 14:48

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040218
 LRN : 0000279771
 Auxiliary ID : Sample #157
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink (Fairness) Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:49
Test Method	*see below				06/07/19 14:49

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: Order ID : S2040219
 DCEH-ENVIRONMENTAL HEALTH SECTION LRN : 0000279771
 841 N. BROADWAY Auxiliary ID : Sample #158
 THIRD FLOOR Date Collected: 05/11/19
 MILWAUKEE, WI 53202 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink (Fairness) Right
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:49
Test Method	*see below				06/07/19 14:49

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040220
 LRN : 0000279771
 Auxiliary ID : Sample #159
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 203 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.2			ug Pb/L	06/07/19 14:49
Test Method	*see below				06/07/19 14:49

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040221
 LRN : 0000279771
 Auxiliary ID : Sample #160
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 203 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.2			ug Pb/L	06/07/19 14:49
Test Method	*see below				06/07/19 14:49

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2040224
LRN : 0000279771
Auxiliary ID : Sample #161
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
STEM Computer Lab Room 219 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*3.9			ug Pb/L	06/07/19 14:49
Test Method	*see below				06/07/19 14:49

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040226
 LRN : 0000279771
 Auxiliary ID : Sample #162
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 STEM Computer Lab Room 219 Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.3			ug Pb/L	06/07/19 14:49
Test Method	*see below				06/07/19 14:49

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040227
 LRN : 0000279771
 Auxiliary ID : Sample #163
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 220 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.3			ug Pb/L	06/07/19 14:49
Test Method	*see below				06/07/19 14:49

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040228
 LRN : 0000279771
 Auxiliary ID : Sample #164
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 220 Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:49
Test Method	*see below				06/07/19 14:49

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040230
 LRN : 0000279771
 Auxiliary ID : Sample #165
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubblers Outside Room 220 Tall Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/07/19 14:49
Test Method	*see below				06/07/19 14:49

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040231
 LRN : 0000279771
 Auxiliary ID : Sample #166
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubbler Outside Room 220 Tall Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/10/19 15:38
Test Method	*see below				06/10/19 15:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040232
 LRN : 0000279771
 Auxiliary ID : Sample #167
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 201 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*4.5			ug Pb/L	06/10/19 15:38
Test Method	*see below				06/10/19 15:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040233
 LRN : 0000279771
 Auxiliary ID : Sample #168
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 201 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/10/19 15:38
Test Method	*see below				06/10/19 15:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040237
 LRN : 0000279771
 Auxiliary ID : Sample #169
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 232 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/10/19 15:38
Test Method	*see below				06/10/19 15:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040238
 LRN : 0000279771
 Auxiliary ID : Sample #170
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 232 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/10/19 15:38
Test Method	*see below				06/10/19 15:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: DCEH-ENVIRONMENTAL HEALTH SECTION 841 N. BROADWAY THIRD FLOOR MILWAUKEE, WI 53202	Order ID : S2040239 LRN : 0000279771 Auxiliary ID : Sample #171 Date Collected: 05/11/19 Date Received : 05/22/19
Requested by: SCHULTZ, JEAN	FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Janitor's Closet Slop Sink Past Room 232

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*3.6			ug Pb/L	06/10/19 15:38
Test Method	*see below				06/10/19 15:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2040240
 LRN : 0000279771
 Auxiliary ID : Sample #172
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Janitor's Closet Slop Sink Past Room 232
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*37.0			ug Pb/L	06/10/19 15:39
Test Method	*see below				06/10/19 15:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050005
 LRN : 0000279771
 Auxiliary ID : Sample #173
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 230 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/10/19 15:39
Test Method	*see below				06/10/19 15:39

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050007
 LRN : 0000279771
 Auxiliary ID : Sample #174
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 230 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/10/19 15:39
Test Method	*see below				06/10/19 15:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

Sanjib Bhattacharyya, Ph.D.

Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050008
 LRN : 0000279771
 Auxiliary ID : Sample #175
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 234 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/10/19 15:39
Test Method	*see below				06/10/19 15:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050010
 LRN : 0000279771
 Auxiliary ID : Sample #176
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 234 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/10/19 15:39
Test Method	*see below				06/10/19 15:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050014
 LRN : 0000279771
 Auxiliary ID : Sample #177
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubbler Between Room 235 and 239

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.7			ug Pb/L	06/10/19 15:39
Test Method	*see below				06/10/19 15:39

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050016
 LRN : 0000279771
 Auxiliary ID : Sample #178
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubbler Between Room 235 and 239
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*25.0			ug Pb/L	06/10/19 15:40
Test Method	*see below				06/10/19 15:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050019
 LRN : 0000279771
 Auxiliary ID : Sample #179
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 228 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/10/19 15:40
Test Method	*see below				06/10/19 15:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050020
 LRN : 0000279771
 Auxiliary ID : Sample #180
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 228 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/10/19 15:40
Test Method	*see below				06/10/19 15:40

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050031
 LRN : 0000279771
 Auxiliary ID : Sample #181
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 228 Bathroom sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.7			ug Pb/L	06/10/19 15:41
Test Method	*see below				06/10/19 15:41

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2050039
LRN : 0000279771
Auxiliary ID : Sample #182
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Room 228 Bathroom sink
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/10/19 15:42
Test Method	*see below				06/10/19 15:42

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050041
 LRN : 0000279771
 Auxiliary ID : Sample #183
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Across From Service Elevator Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/10/19 15:42
Test Method	*see below				06/10/19 15:42

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050043
 LRN : 0000279771
 Auxiliary ID : Sample #184
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubbler Across From Service Elevator Tall
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/10/19 15:42
Test Method	*see below				06/10/19 15:42

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050047
 LRN : 0000279771
 Auxiliary ID : Sample #185
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Across From Service Elevator Short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/10/19 15:42
Test Method	*see below				06/10/19 15:42

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050049
 LRN : 0000279771
 Auxiliary ID : Sample #186
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Across From Service Elevator Short
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/10/19 15:42
Test Method	*see below				06/10/19 15:42

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050051
 LRN : 0000279771
 Auxiliary ID : Sample #187
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 215 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.0			ug Pb/L	06/10/19 15:42
Test Method	*see below				06/10/19 15:42

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050055
 LRN : 0000279771
 Auxiliary ID : Sample #188
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 215 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:53
Test Method	*see below				06/12/19 12:53

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050057
 LRN : 0000279771
 Auxiliary ID : Sample #189
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 215 bathroom sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.6			ug Pb/L	06/12/19 12:53
Test Method	*see below				06/12/19 12:53

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050060
 LRN : 0000279771
 Auxiliary ID : Sample #190
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 215 bathroom sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:53
Test Method	*see below				06/12/19 12:53

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050063
 LRN : 0000279771
 Auxiliary ID : Sample #191
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 223 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:54
Test Method	*see below				06/12/19 12:54

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050065
 LRN : 0000279771
 Auxiliary ID : Sample #192
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 223 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:54
Test Method	*see below				06/12/19 12:54

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050074
 LRN : 0000279771
 Auxiliary ID : Sample #193
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 240 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:54
Test Method	*see below				06/12/19 12:54

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050076
 LRN : 0000279771
 Auxiliary ID : Sample #194
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 240 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:55
Test Method	*see below				06/12/19 12:55

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050079
 LRN : 0000279771
 Auxiliary ID : Sample #195
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubblers Outside Room 241 Tall Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:55
Test Method	*see below				06/12/19 12:55

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050081
 LRN : 0000279771
 Auxiliary ID : Sample #196
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Outside Room 241 Tall Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:55
Test Method	*see below				06/12/19 12:55

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050088
 LRN : 0000279771
 Auxiliary ID : Sample #197
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubblers Outside Room 241 Tall Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:55
Test Method	*see below				06/12/19 12:55

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050089
 LRN : 0000279771
 Auxiliary ID : Sample #198
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubbler Outside Room 241 Tall Right
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:55
Test Method	*see below				06/12/19 12:55

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050092
 LRN : 0000279771
 Auxiliary ID : Sample #199
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubblers Outside Room 241 Short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/12/19 12:55
Test Method	*see below				06/12/19 12:55

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: DCEH-ENVIRONMENTAL HEALTH SECTION 841 N. BROADWAY THIRD FLOOR MILWAUKEE, WI 53202	Order ID : S2050095 LRN : 0000279771 Auxiliary ID : Sample #200 Date Collected: 05/11/19 Date Received : 05/22/19
--	---

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubbler Outside Room 241 Short
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:56
Test Method	*see below				06/12/19 12:56

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050099
 LRN : 0000279771
 Auxiliary ID : Sample #201
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink By Blue Doors

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*6.3			ug Pb/L	06/12/19 12:56
Test Method	*see below				06/12/19 12:56

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050101
 LRN : 0000279771
 Auxiliary ID : Sample #202
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink By Blue Doors
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:56
Test Method	*see below				06/12/19 12:56

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050102
 LRN : 0000279771
 Auxiliary ID : Sample #203
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubblers Between Restrooms

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*3.7			ug Pb/L	06/12/19 12:56
Test Method	*see below				06/12/19 12:56

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050103
 LRN : 0000279771
 Auxiliary ID : Sample #204
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubblers Between Restrooms
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*12.0			ug Pb/L	06/12/19 12:56
Test Method	*see below				06/12/19 12:56

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050107
 LRN : 0000279771
 Auxiliary ID : Sample #205
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink By Blue Doors

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*8.5			ug Pb/L	06/12/19 12:56
Test Method	*see below				06/12/19 12:56

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050112
 LRN : 0000279771
 Auxiliary ID : Sample #206
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink By Blue Doors
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:56
Test Method	*see below				06/12/19 12:56

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050113
 LRN : 0000279771
 Auxiliary ID : Sample #207
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink Across From Stairs-B Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*6.8			ug Pb/L	06/12/19 12:56
Test Method	*see below				06/12/19 12:56

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050114
 LRN : 0000279771
 Auxiliary ID : Sample #208
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink Across From Stairs-B Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*5.7			ug Pb/L	06/12/19 12:57
Test Method	*see below				06/12/19 12:57

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050115
 LRN : 0000279771
 Auxiliary ID : Sample #209
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink Across From Stairs-B Middle

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/12/19 12:57
Test Method	*see below				06/12/19 12:57

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2050116
 LRN : 0000279771
 Auxiliary ID : Sample #210
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink Across From Stairs-B Middle
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/12/19 12:57
Test Method	*see below				06/12/19 12:57

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060005
 LRN : 0000279771
 Auxiliary ID : Sample #211
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink Across From Stairs-B right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/13/19 15:38
Test Method	*see below				06/13/19 15:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060007
 LRN : 0000279771
 Auxiliary ID : Sample #212
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink Across From Stairs-B right
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.1			ug Pb/L	06/13/19 15:38
Test Method	*see below				06/13/19 15:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060008
 LRN : 0000279771
 Auxiliary ID : Sample #213
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubler Between Bathroom Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/13/19 15:38
Test Method	*see below				06/13/19 15:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060010
 LRN : 0000279771
 Auxiliary ID : Sample #214
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubbler Between Bathroom Tall
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/13/19 15:38
Test Method	*see below				06/13/19 15:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060011
 LRN : 0000279771
 Auxiliary ID : Sample #215
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubblr Between Bathroom Short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/13/19 15:38
Test Method	*see below				06/13/19 15:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060012
 LRN : 0000279771
 Auxiliary ID : Sample #216
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubblers Between Bathroom Short
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/13/19 15:38
Test Method	*see below				06/13/19 15:38

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060013
 LRN : 0000279771
 Auxiliary ID : Sample #217
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink (Locker 180) Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/13/19 15:39
Test Method	*see below				06/13/19 15:39

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060015
 LRN : 0000279771
 Auxiliary ID : Sample #218
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink (Locker 180) Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.1			ug Pb/L	06/13/19 15:39
Test Method	*see below				06/13/19 15:39

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060016
 LRN : 0000279771
 Auxiliary ID : Sample #219
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink (Locker 180) Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/13/19 15:39
Test Method	*see below				06/13/19 15:39

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060017
 LRN : 0000279771
 Auxiliary ID : Sample #220
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink (Locker 180) Right
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/13/19 15:39
Test Method	*see below				06/13/19 15:39

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2060018
LRN : 0000279771
Auxiliary ID : Sample #221
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Room 206 Science Lab Station 1

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*10.0			ug Pb/L	06/13/19 15:39
Test Method	*see below				06/13/19 15:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 06/13/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060019
 LRN : 0000279771
 Auxiliary ID : Sample #222
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 206 Science Lab Station 1
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*7.9			ug Pb/L	06/13/19 15:39
Test Method	*see below				06/13/19 15:39

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: Order ID : S2060020
LRN : 0000279771
DCEH-ENVIRONMENTAL HEALTH SECTION Auxiliary ID : Sample #223
841 N. BROADWAY Date Collected: 05/11/19
THIRD FLOOR Date Received : 05/22/19
MILWAUKEE, WI 53202

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Room 206 Science Lab Station 2

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*4.8			ug Pb/L	06/13/19 15:39
Test Method	*see below				06/13/19 15:39

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060021
 LRN : 0000279771
 Auxiliary ID : Sample #224
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 206 Science Lab Station 2
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*3.2			ug Pb/L	06/13/19 15:40
Test Method	*see below				06/13/19 15:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060022
 LRN : 0000279771
 Auxiliary ID : Sample #225
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 206 Science Lab Station 3

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.2			ug Pb/L	06/13/19 15:40
Test Method	*see below				06/13/19 15:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060023
 LRN : 0000279771
 Auxiliary ID : Sample #226
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 206 Science Lab Station 3
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/13/19 15:40
Test Method	*see below				06/13/19 15:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060024
 LRN : 0000279771
 Auxiliary ID : Sample #227
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 206 Science Lab Station 4

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.7			ug Pb/L	06/13/19 15:40
Test Method	*see below				06/13/19 15:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060025
 LRN : 0000279771
 Auxiliary ID : Sample #228
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 206 Science Lab Station 4
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/13/19 15:40
Test Method	*see below				06/13/19 15:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060061
 LRN : 0000279771
 Auxiliary ID : Sample #229
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 206 Science Lab Station 5

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.0			ug Pb/L	06/13/19 15:40
Test Method	*see below				06/13/19 15:40

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2060062
LRN : 0000279771
Auxiliary ID : Sample #230
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Room 206 Science Lab Station 5
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.3			ug Pb/L	06/13/19 15:40
Test Method	*see below				06/13/19 15:40

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060063
 LRN : 0000279771
 Auxiliary ID : Sample #231
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 206 Science Lab Station 6

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.3			ug Pb/L	06/13/19 15:41
Test Method	*see below				06/13/19 15:41

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060065
 LRN : 0000279771
 Auxiliary ID : Sample #232
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 206 Science Lab Station 6
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.1			ug Pb/L	06/13/19 15:41
Test Method	*see below				06/13/19 15:41

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060066
 LRN : 0000279771
 Auxiliary ID : Sample #233
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 205 Nurses Room Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.6			ug Pb/L	06/13/19 15:41
Test Method	*see below				06/13/19 15:41

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060067
 LRN : 0000279771
 Auxiliary ID : Sample #234
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 205 Nurses Room Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/13/19 15:41
Test Method	*see below				06/13/19 15:41

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060068
 LRN : 0000279771
 Auxiliary ID : Sample #235
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Staff Only Sink Next to Room 205

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.5			ug Pb/L	06/13/19 15:41
Test Method	*see below				06/13/19 15:41

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060069
 LRN : 0000279771
 Auxiliary ID : Sample #236
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Staff Only Sink Next to Room 205
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:42
Test Method	*see below				06/14/19 13:42

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060070
 LRN : 0000279771
 Auxiliary ID : Sample #237
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 311 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.8			ug Pb/L	06/14/19 13:42
Test Method	*see below				06/14/19 13:42

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060071
 LRN : 0000279771
 Auxiliary ID : Sample #238
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 311 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.1			ug Pb/L	06/14/19 13:42
Test Method	*see below				06/14/19 13:42

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060072
 LRN : 0000279771
 Auxiliary ID : Sample #239
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink Near Room 311 (JA Drop Box) Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:42
Test Method	*see below				06/14/19 13:42

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2060073
 LRN : 0000279771
 Auxiliary ID : Sample #240
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink Near Room 311 (JA Drop Box) Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:43
Test Method	*see below				06/14/19 13:43

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2070056
 LRN : 0000279771
 Auxiliary ID : Sample #241
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink Near Room 311 (JA Drop Box) Middle

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:43
Test Method	*see below				06/14/19 13:43

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2070058
 LRN : 0000279771
 Auxiliary ID : Sample #242
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink Near Room 311 (JA Drop Box) Middle
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:43
Test Method	*see below				06/14/19 13:43

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2070060
 LRN : 0000279771
 Auxiliary ID : Sample #243
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink Near Room 311 Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:43
Test Method	*see below				06/14/19 13:43

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2070062
 LRN : 0000279771
 Auxiliary ID : Sample #244
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Men's Room Sink Near Room 311 Right
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:43
Test Method	*see below				06/14/19 13:43

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2070076
 LRN : 0000279771
 Auxiliary ID : Sample #245
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Janitor's Closet Slop Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.0			ug Pb/L	06/14/19 13:43
Test Method	*see below				06/14/19 13:43

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2070079
 LRN : 0000279771
 Auxiliary ID : Sample #246
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Janitor's Closet Slop Sink
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.3			ug Pb/L	06/14/19 13:43
Test Method	*see below				06/14/19 13:43

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2070081
 LRN : 0000279771
 Auxiliary ID : Sample #247
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubblers Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:44
Test Method	*see below				06/14/19 13:44

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2070083
 LRN : 0000279771
 Auxiliary ID : Sample #248
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubblers Tall 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:44
Test Method	*see below				06/14/19 13:44

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2070085
 LRN : 0000279771
 Auxiliary ID : Sample #249
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubblers Short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.1			ug Pb/L	06/14/19 13:44
Test Method	*see below				06/14/19 13:44

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2070089
 LRN : 0000279771
 Auxiliary ID : Sample #250
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
-------------------------------------	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Bubblers Short 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:44
Test Method	*see below				06/14/19 13:44

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2070092
 LRN : 0000279771
 Auxiliary ID : Sample #251
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:44
Test Method	*see below				06/14/19 13:44

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2070096
 LRN : 0000279771
 Auxiliary ID : Sample #252
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink Right
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:44
Test Method	*see below				06/14/19 13:44

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130023
 LRN : 0000279771
 Auxiliary ID : Sample #253
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink Middle

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:44
Test Method	*see below				06/14/19 13:44

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130027
 LRN : 0000279771
 Auxiliary ID : Sample #254
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink Middle
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/14/19 13:44
Test Method	*see below				06/14/19 13:44

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2130031
LRN : 0000279771
Auxiliary ID : Sample #255
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Women's Room Sink Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.0			ug Pb/L	06/14/19 13:44
Test Method	*see below				06/14/19 13:44

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130034
 LRN : 0000279771
 Auxiliary ID : Sample #256
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Women's Room Sink Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/14/19 13:45
Test Method	*see below				06/14/19 13:45

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130040
 LRN : 0000279771
 Auxiliary ID : Sample #257
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 320 Computer Lab Bathroom Sink Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*3.8			ug Pb/L	06/14/19 13:45
Test Method	*see below				06/14/19 13:45

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130043
 LRN : 0000279771
 Auxiliary ID : Sample #258
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 320 Computer Lab Bathroom Sink Right
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	06/14/19 13:45
Test Method	*see below				06/14/19 13:45

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130046
 LRN : 0000279771
 Auxiliary ID : Sample #259
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 320 Computer Lab Bathroom Sink Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.2			ug Pb/L	06/14/19 13:45
Test Method	*see below				06/14/19 13:45

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130049
 LRN : 0000279771
 Auxiliary ID : Sample #260
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000**

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 320 Computer Lab Bathroom Sink Left
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:45
Test Method	*see below				06/14/19 13:45

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130051
 LRN : 0000279771
 Auxiliary ID : Sample #261
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Next to Room 304

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:45
Test Method	*see below				06/14/19 13:45

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130052
 LRN : 0000279771
 Auxiliary ID : Sample #262
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Next to Room 304
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:45
Test Method	*see below				06/14/19 13:45

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:
 DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130053
 LRN : 0000279771
 Auxiliary ID : Sample #263
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Across From Room 322 Library

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:46
Test Method	*see below				06/14/19 13:46

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: Order ID : S2130054
LRN : 0000279771
DCEH-ENVIRONMENTAL HEALTH SECTION Auxiliary ID : Sample #264
841 N. BROADWAY Date Collected: 05/11/19
THIRD FLOOR Date Received : 05/22/19
MILWAUKEE, WI 53202

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
Bubbler Across From Room 322 Library
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:46
Test Method	*see below				06/14/19 13:46

Reference Method of Analysis: SM 3113B
LOD: 0.31 ppb (ug/L)
LOQ: 1.03 ppb (ug/L)
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098

FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S2130079
LRN : 0000279771
Auxiliary ID : Sample #265
Date Collected: 05/11/19
Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000

DOB:

Age:

Sex:

Ord. Comm: Milwaukee Academy of Science
Room 334 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	06/14/19 13:46
Test Method	*see below				06/14/19 13:46

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

Sanjib Bhattacharyya, Ph.D.

Laboratory Director

Printed: 06/14/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130080
 LRN : 0000279771
 Auxiliary ID : Sample #266
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Milwaukee Academy of Science
 Room 334 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:46
Test Method	*see below				06/14/19 13:46

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130081
 LRN : 0000279771
 Auxiliary ID : Sample #267
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 329 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:46
Test Method	*see below				06/14/19 13:46

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to: Order ID : S2130082
 DCEH-ENVIRONMENTAL HEALTH SECTION LRN : 0000279771
 841 N. BROADWAY Auxiliary ID : Sample #268
 THIRD FLOOR Date Collected: 05/11/19
 MILWAUKEE, WI 53202 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN **FINAL**

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Room 329 Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:46
Test Method	*see below				06/14/19 13:46

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130084
 LRN : 0000279771
 Auxiliary ID : Sample #269
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Between Room 331 and 312 Tall (Locker 171)

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:46
Test Method	*see below				06/14/19 13:46

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130087
 LRN : 0000279771
 Auxiliary ID : Sample #270
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/W/KILBOURNAV, 2000 DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Between Room 331 and 312 Tall (Locker 171)
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:46
Test Method	*see below				06/14/19 13:46

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)
 DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130089
 LRN : 0000279771
 Auxiliary ID : Sample #271
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Between Room 331 and 312 Short (Locker 171)

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:46
Test Method	*see below				06/14/19 13:46

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
 841 North Broadway, Room 205 Milwaukee, WI 53202-3653
 Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
 841 N. BROADWAY
 THIRD FLOOR
 MILWAUKEE, WI 53202

Order ID : S2130090
 LRN : 0000279771
 Auxiliary ID : Sample #272
 Date Collected: 05/11/19
 Date Received : 05/22/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/W/KILBOURNAV, 2000** DOB: Age: Sex:

Ord. Comm: Milwaukee Academy of Science
 Bubbler Between Room 331 and 312 Short (Locker 171)
 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	06/14/19 13:46
Test Method	*see below				06/14/19 13:46

Reference Method of Analysis: SM 3113B
 LOD: 0.31 ppb (ug/L)
 LOQ: 1.03 ppb (ug/L)
 EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
 Sanjib Bhattacharyya, Ph.D.
 Laboratory Director