

EVAN C. GOYKE
City Attorney

MARY L. SCHANNING
ROBIN A. PEDERSON
NAOMI E. SANDERS
JULIE P. WILSON
Deputy City Attorneys



Milwaukee City Hall Suite 800 • 200 East Wells Street • Milwaukee, Wisconsin 53202-3551
Telephone: 414.286.2601 • TDD: 414.286.2025 • Fax: 414.286.8550

KATHRYN Z. BLOCK
THOMAS D. MILLER
PETER J. BLOCK
ANDREA J. FOWLER
JOANNA FRACZEK
HANNAH R. JAHN
MEIGHAN M. ANGER
ALEXANDER R. CARSON
GREGORY P. KRUSE
ALEX T. MUELLER
ALEXANDER D. COSSI
KATHERINE A. HEADLEY
SHEILA THOBANI
STACY J. MILLER
JORDAN M. SCHELLER
THERESA A. MONTAG
ALEXANDER E. FOUNDOS
TRAVIS J. GRESHAM
KYLE W. BAILEY
JOSEPH M. DOBBS
WILLIAM K. HOTCHKISS
CLINT B. MUCHE
TYLER M. HELSEL
ZACHARY A. HATFIELD
MEGHAN C. MCCABE
CYNTHIA HARRIS ORTEGA SANTANA
OLUWASEUN CHRIS IBITOYE
KEVIN P. TODT
NATHANIEL E. ADAMSON
MATTEO REGINATO
JOSHUA B. CRONIN
ROBERT W. SANDERS
ELIZABETH K. MILES
LAURI A. ROLLINGS
Assistant City Attorneys

February 24, 2026

To the Honorable Common Council
Of the City of Milwaukee
Room 205 - City Hall

RE: Communication from MARY LOU SIEVERT
C.I. File No. 2025-002224

Dear Council Members:

Enclosed please find a proposed resolution. We ask that it be introduced and referred to the Committee on Judiciary & Legislation, with the following recommendation.

Mary Lou Sievert alleges that on July 31, 2025, she experienced sewer back up that caused damage to the basement of her property at 6100 South 37th Street, in Greenfield, Wisconsin. Ms. Sievert submitted a damage claim for water mitigation, loss of appliances, sewer repairs and restoration repairs for her finished basement in the amount of \$46,715.38.

Our investigation, conducted in coordination with Milwaukee Water Works, determined that the water main failure caused damage to the sewer lateral at 6042 South 37th Street. This damage created an entry point through which debris entered the sewer main. Following the utility's coordination with DPW-Greenfield to clear the sewer, the restoration of water service to the failed main allowed additional debris—including rock and sand—to flow into the sewer system. This influx of material subsequently contributed to flooding that impacted multiple properties in the surrounding area of 6000-6100 blocks of South 37th Street and 3700 block of West Kimberly Avenue in Greenfield, Wisconsin.



To the Honorable Common Council
Of the City of Milwaukee
February 24, 2026
Page Two

Based on the findings, it is our assessment that the utility did not exercise reasonable care when restoring water service. Additionally, the failure to maintain the original water shutoff contributed to the extent of the resulting damages. Accordingly, we recommend approval of the claim, with adjustments totaling \$45,423.55

Very truly yours,

A handwritten signature in blue ink, appearing to read "E. Gojke", with a long horizontal line extending to the right.

EVAN C. GOYKE
City Attorney

A handwritten signature in blue ink, appearing to read "Naomi E. Sanders", with a long horizontal line extending to the right.

NAOMI E. SANDERS
Deputy City Attorney

ECG/NES/MTG/cdr

Enclosures

2025-002224/