



Certificate of Appropriateness

Milwaukee Historic Preservation Commission/841 N Broadway/Milwaukee, WI 53202/phone 414-286-5722

Property Description of work

1701 N. Humboldt Ave., Brady Street Historic District

After-the-fact approval of installation of furnace and AC system. Installation includes penetrations on the east façade for furnace exhaust and intake, dryer vent, and fresh air intake.

Date issued 12/23/2024

In accordance with the provisions of Section 320-21 (11) and (12) of the Milwaukee Code of Ordinances, the Milwaukee Historic Preservation Commission has issued a certificate of appropriateness for the work listed above. The work was found to be consistent with preservation guidelines. The following conditions apply to this certificate of appropriateness:

Sidewall vent pipes for heating equipment must be located through the raised foundation on the rear elevation or as far back as possible on a side elevation that does not face the street. All sidewall vent pipes must be painted out to blend with the color of the surrounding building material. Any sidewall venting must be at the rear of the house or as far back as possible on a non-street-facing side elevation. Regardless of location, the PVC vent pipes must be painted out to blend with the color of the surrounding building material. Central A/C must be installed in backyard if at all possible. Side yard installation is only permissible if the unit is obscured from public view by plantings or an opaque fence.

All work must be done in a craftsman-like manner. Staff must approve any changes or additions to this certificate before work begins. Work that is not completed in accordance with this certificate may be subject to correction orders or citations. If you require technical assistance, please contact Historic Preservation staff as follows: Phone: (414) 286-5722 E-mail: hpc@milwaukee.gov.

Permits and timeline

You are responsible for determining if permits are required and obtaining them prior to commencing work. Consult the Development Center on the web or by telephone for details: www.milwaukee.gov/lms - (414) 286-8210. If permits are not required, work must be completed within one year of the date this certificate was issued. If permits are required, permits must be obtained within one year of the date this certificate was issued.

City of Milwaukee Historic Preservation

Copies to: Development Center



Photos of install

STAINLESS STEEL SHINGLE,
ZINC FINISH, VERTICAL
PATTERN

Furnace Exhaust & Intake 4"Ø

4"Ø Fresh Air Intake

UNIT 103.1

K KOMFORT
1201 6TH AVENUE
GRAFTON, WI 53204

KEYSTONE ON BRADY
1701 N HUMBOLDT AVE,
MILWAUKEE, WI 53202

ECTIONS:		Description:	
Date:			

SCALE: 3/8" = 1'-0"

DESIGN ENGINEER: SLAVA KROL

DATE: 12/16/2024

SHEET TITLE:

PROJECT NO.: EAST ELEVATION
HVAC PLAN

DATE: 12/16/2024

M1