

# Emergency Power and Communications

## 403.1 PURPOSE AND SCOPE

The Milwaukee County Sheriff's Office facility must continue to operate as a safe and secure environment regardless of emergencies, including electrical outages. The purpose of this policy is to establish guidelines regarding back-up power and communication systems, and the inspection, preventive maintenance and testing of the systems to ensure a seamless transition in the event of a loss of power.

## 403.2 POLICY

It is the policy of this agency to ensure that power to critical systems and communications continues to operate within the facility in the event of a loss of power.

### 403.2.1 PREVENTIVE MAINTENANCE

It is the responsibility of the County Facilities Management to ensure that there is sufficient emergency power to operate all essential lighting, security equipment, safety equipment and communications systems. The emergency power system should have sufficient fuel to allow the facility to operate continuously for a three-day period, if necessary, without external resources.

The emergency power system should be inspected, tested and maintained as necessary. In the event that the system fails, the Jail Commander or the authorized designee should contact the designated maintenance authority, to obtain necessary repairs as soon as practicable. If the emergency power system cannot be repaired within eight hours, portable emergency generators should be secured as a temporary emergency power source until the repair or replacement of the primary system occurs.

### 403.2.2 SAFETY AND SECURITY

Inoperable or malfunctioning safety and/or security equipment shall be immediately repaired or replaced. In the event that safety and/or security equipment become inoperable or damaged and it is not safe to operate a secure portion of the facility, that portion of the facility should be vacated and the inmates housed elsewhere. Or, staffing should be increased sufficiently for the area to remain safe and secure until the repair can be completed.

### 403.2.3 INSPECTION AND TESTING

County Facilities Management is responsible for scheduled testing of emergency power systems. The power system manufacturer should be contacted for the required testing intervals and load information. The emergency power system should be load-tested in accordance with the manufacturer's recommendations or at least quarterly.

All emergency equipment and systems should be inspected by a qualified individual at least quarterly.

Power generators should be inspected and tested by a qualified individual at least quarterly.

# Milwaukee County Sheriff's Office

## Custody Manual

### *Emergency Power and Communications*

---

All testing and inspections shall be documented and the results included in a report to the Jail Commander.