

096391

ROY'S PLUMBING SERVICE, INC.

1830 West Hampton Avenue
MILWAUKEE, WISCONSIN 53209
(414) 264-2812
FAX (414) 264-7444

September 28, 2009


Ms. Emma Nash
2218 North 17th Street
Milwaukee, Wisconsin 53205

Dear Ms, Nash:

Roy's Plumbing, Inc. checked and snaked the sanitary sewer from the cast iron soil stack from the cleanout in the soil stack to the center of street main sewer. We found from the house to the street the main sewer was not connected properly. The wye connection on the main sewer where the hole was drilled in the main sewer was not lined up with the wye connection that connects to 2218 North 17th Street. The house sewer lateral connection was off about three to four inches which caused the main sewer drain line to constantly clog up with paper and other debris.

We snaked the sewer line about two hours until we finally got the water to go down then we ran the camera out to the main sewer. After approval from Mrs. Nash, we secured a permit and signed a contract with her and Milwaukee County Home Improvement. We then cut street, dug up ground and made repair on the connection to the main sewer and backfilled the trench back in place. This job was completed April 17, 2009.

Sincerely,



Rickey Nelson
President

RN:ez