



**GRAEFF
ANHALT
SCHLOEMER
and Associates Inc.**

One Honey Creek Corporate Center
125 South 84th Street, Suite 401
Menomonee, WI 53214-1470
TEL 259-1500
FAX 259-0037

Web Site: www.gsaof.com

Other offices located in:

Green Bay, Wisconsin
Madison, Wisconsin
Chicago, Illinois

PROJECT NAME:
**ST. LUKE'S MEDICAL CENTER
CARDIAC CENTER AND PATIENT
TOWER PROJECT**

SHEET TITLE:
**EXHIBIT 1
PETITION FOR SPECIAL PRIVILEGE
CITY OF MILWAUKEE, WI**

SITE PLAN

NO.	DATE	REVISIONS	BY

PROJECT NUMBER: 9990378.11
DATE: 06-Jul-01 07:05
DESIGNED BY: JAL
DRAWN BY: JAL
CHECKED BY: JTM
PROJECT MANAGER: JTM
FILE: G:\990378.11\ma\exhibits\ElecDuct\vsnd1.dgn
SCALE: HORZ. N.T.S.

SHEET NUMBER



GRAEF
ANHALT
SCHLOEMER
and Associates Inc.

One Honey Creek Corporate Center
 25 South 94th Street, Suite 401
 Milwaukee WI 53214-1470
 414 259-1500
 FAX 259-0037

Web Site: www.graef.com

Other offices located in:

Green Bay, Wisconsin
 Madison, Wisconsin
 Chicago, Illinois

PROJECT NAME:
 ST. LUKE'S MEDICAL CENTER
 CARDIAC CENTER AND PATIENT
 TOWER PROJECT

SHEET TITLE:
 EXHIBIT 2
 PETITION FOR SPECIAL PRIVILEGE
 CITY OF MILWAUKEE, WI

PROPOSED ELECTRIC DUCT BANK

NO.	DATE	REVISIONS	BY

PROJECT NUMBER: 9990378.11
 DATE: 06-JUL-01 07:13
 DESIGNED BY:
 DRAWN BY: JAL
 CHECKED BY:
 PROJECT MANAGER: JTM
 FILE: G:\990378.11\mva\exhibits\ElecDuct\venh02.dgn
 SCALE: HORZ. 1" = 60'

SHEET NUMBER

INSTALL AND MAINTAIN AN UNDERGROUND CONCRETE ELECTRIC DUCT BANK CONTAINING ELECTRICAL CONDUIT STARTING AT A POINT APPROXIMATELY 105 FEET WEST OF THE WEST LINE OF VACATED SOUTH 28TH STREET AND EXTENDING APPROXIMATELY 5.2 FEET TO AN EXISTING MANHOLE, AND THEN EAST AND PARALLEL TO THE NORTH LINE OF WEST OKLAHOMA AVENUE FOR APPROXIMATELY 225 FEET TO A MANHOLE LOCATED NORTH OF THE NORTH CURB OF WEST OKLAHOMA AVENUE, AND THEN EXTENDING APPROXIMATELY 195 FEET TO A MANHOLE LOCATED NORTH OF THE NORTH CURB OF WEST OKLAHOMA AVENUE, AND THEN EXTENDING NORTH TO THE NORTH LINE OF WEST OKLAHOMA AVENUE. SAID DUCT BANK IN THIS AREA IS A MINIMUM OF 2 FEET BELOW GRADE. SAID CONCRETE DUCT BANK IS APPROXIMATELY 48 INCHES WIDE AND 36 INCHES HIGH AND CONTAINS TWELVE PVC CONDUITS FOR POWER TRANSMISSION. THE AFORESAID MANHOLES LOCATED IN THE CONCRETE SIDEWALK AREA SHALL BE FLUSH WITH THE CONCRETE SURFACE SO AS NOT TO CAUSE A TRIPPING HAZARD.

