



# Certificate of Appropriateness

Milwaukee Historic Preservation Commission/841 N Broadway/Milwaukee, WI 53202/phone 414-286-5712

<b>Property</b>	<b>1701 N Humboldt</b>	<b>Brady Street</b>
<b>Description of work</b>	New internally lit wall sign per attached drawing, sign is <19 sf. Non-illuminated window signs/decals must be reduced to 25% coverage or less.	
<b>Date issued</b>	9/12/2024	

Under the provisions of Section 320-21 (11) and (12) of the Milwaukee Code of Ordinances, the Milwaukee Historic Preservation Commission has granted a certificate of appropriateness for the work listed above. The work was found to be consistent with preservation guidelines. The following conditions apply to this certificate of appropriateness:

**LED light strips attached to the window frame are NOT approved and must be removed. Window signage exceeding 25% coverage of any given pane must also be removed.**

All work must be done in a craftsman-like manner. Staff must approve any changes or additions to this certificate before work begins. Work that is not completed in accordance with this certificate may be subject to correction orders or citations. If you require technical assistance, please contact Historic Preservation staff as follows: Phone: (414) 286-5712 E-mail: [hpc@milwaukee.gov](mailto:hpc@milwaukee.gov).

### ***Permits and timeline***

You are responsible for determining if permits are required and obtaining them prior to commencing work. Consult the Development Center on the web or by telephone for details [www.milwaukee.gov/lms](http://www.milwaukee.gov/lms) (414) 286-8210. If permits are not required, work must be completed within one year of the date this certificate was issued. If permits are required, permits must be obtained within one year of the date this certificate was issued.

FINAL DESIGN






30"

SHAWARMA  
PALACE

87"

Sign 18.1 SQ. FT

MOCK-UP

-  3M 3630 - Color Code : 033
-  White Acrylic Face 7328
-  Return 4.3" Black
-  Black Trim
-  LED Light, white color 10K, IP65

Color description is for reference only.  
Samples provided upon request after order placement.



Before

After


INSTALLATION



ALL ELECTRICAL COMPONENTS ARE TO BE UL APPROVED


" Channel Letters are intended to be installed in accordance with the requirements of Article 600 of the National Electrical Code and/or other applicable local codes, including proper grounding and bonding of the entire sign. "

Power Supply: Simple LED Power Inc.  
AC INPUT: 100-277VAC, 50/60HZ, MAX 2.8A  
DC OUTPUT: +12V/16.5A/200W



Standard Face Lit - LED Illuminated w/ Raceway

Standard Front Lit Channel Letter



FRONT VIEW

1701 N Humboldt Ave Milwaukee, Wi 53202

DIMENSION

Wall Dimensions



365" W. x 27.75' H.

22" SHAWARMA  
87"

8" PALACE  
64"

Channel Letters