



Certificate of Appropriateness

Milwaukee Historic Preservation Commission/841 N Broadway/Milwaukee, WI 53202/phone 414-286-5722

**Property
Description of
work**

Date issued 5/6/2025

In accordance with the provisions of Section 320-21 (11) and (12) of the Milwaukee Code of Ordinances, the Milwaukee Historic Preservation Commission has issued a certificate of appropriateness for the work listed above. The work was found to be consistent with preservation guidelines. The following conditions apply to this certificate of appropriateness:

New mortar must match the original mortar in terms of color, texture, grain size, joint width, and joint finish/profile. The compressive strength of the repointing mortar shall be equal or less than the compressive strength of the original mortar and surrounding brick or stone. The replacement mortar shall contain approximately the same ingredient proportions of the original mortar. Mortar that is too hard is subject to premature failure and could damage the masonry. See the city's books *As Good As New or Good for Business*, Masonry Chapters, for more information. In most cases, this means a lime mortar with natural hydraulic cement rather than Portland cement. No joint of a width less than 3/8" may be cleaned of damaged/decomposed mortar with power disc grinders. No over-cutting of the joints is permitted. Remove decomposed mortar back into the wall 2.5 times the height of the joint before repointing. When installing new flashing at a masonry feature, the flashing must be stepped or cut into the mortar joints. The bricks may not be cut to install flashing at an angle.

New brick/stone/terra cotta must match as closely as possible the color texture, size, and finish of the original.

A sample panel of the masonry materials and their mortar must be reviewed and approved by HPC staff prior to general installation of the material.

UNDER NO CIRCUMSTANCES SHALL UNPAINTED MASONRY BE PAINTED, BE GIVEN A WATERPROOFING TREATMENT, OR CLEANED BY ABRASIVE MEANS; THIS STATEMENT SUPERSEDES ANY OTHER WORDING IN THIS DOCUMENT INDICATING THE CONTRARY.

All work must be done in a craftsman-like manner. Staff must approve any changes or additions to this certificate before work begins. Work that is not completed in accordance with this certificate may be subject to correction orders or citations. If you require technical assistance, please contact Historic Preservation staff as follows: Phone: (414) 286-5722 E-mail: hpc@milwaukee.gov.


Permits and timeline

You are responsible for determining if permits are required and obtaining them prior to commencing work. Consult the Development Center on the web or by telephone for details: www.milwaukee.gov/lms - (414) 286-8210. If permits are not required, work must be completed within one year of the date this certificate was issued. If permits are required, permits must be obtained within one year of the date this certificate was issued.



City of Milwaukee Historic Preservation

Copies to: Development Center



Two chimneys rebuild

| DESCRIPTION | QTY | UNIT PRICE | TOTAL |
|--|-----|-----------------|----------------------------|
| Estimate is to rebuild chimneys on house, (2) Cream City Brick - (Approx. 1,400 Brick) Full rebuild from roof line up. Current flashing to remain and be used again. Will re caulk existing flashing after rebuilding. | | | |
| Removal of both chimneys from roof line up (painted sections) Removal of chimney crown and any damaged flue tiles. Up to two tiles each section. | | | |
| Rebuild with Cream city brick and specified white mortar. (both chimneys) | | | |
| Pour new concrete crowns for both chimneys | | | |
| Cost per chimney - | | \$7,250.00 Each | |
| This contract is for both chimneys and includes specified yard clean up needed for brick wall construction and wooden fence replacement | | | Free with chimney rebuilds |
| Includes scaffolding, trucking, disposal, | | | |
| New materials will match old to best of ability and availability. | | | |
| 50% Down to start job and remaining 50% upon completion. | | | |
| SUBTOTAL | | | |

Scope of work