

RE: CCF 180094 COA for garage repairs



Top and bottom brick are original. Middle brick is approved for low-to-ground use on east and south elevations where new brick is needed. This would not be approved for highly visible elevations or significantly above grade.

A handwritten signature in black ink, appearing to read "Tom Arns". The signature is written in a cursive, flowing style.

6/27/18

---

City of Milwaukee Historic Preservation Staff