



Certificate of Appropriateness

Milwaukee Historic Preservation Commission/200 E. Wells Street/Milwaukee, WI 53202/phone 414-286-5712/fax 414-286-3004

Property	2051 W. WISCONSIN AV.	Pettibone-White House
Description of work	<ol style="list-style-type: none"> 1. Re-roof with Certainteed Landmark Burnt Sienna color 2. Rebuild built-in gutters on front structure with new soldered copper over new ice and water shield 3. Replace K-type gutters on rear section in-kind 4. Remove one chimney from rear section 	
Date issued	7/15/2020	PTS ID 114975 COA: roof, gutters, chimney removal

In accordance with the provisions of Section 320-21 (11) and (12) of the Milwaukee Code of Ordinances, the Milwaukee Historic Preservation Commission has issued a certificate of appropriateness for the work listed above. The work was found to be consistent with preservation guidelines. The following conditions apply to this certificate of appropriateness:

No dormers, chimneys, moldings parapets, or other permanent features will be altered or removed, unless explicitly approved elsewhere in this document. No box vents, if used, will be visible from the street. If they are installed, they must be on a rear slope not visible from the street and they must be painted to blend with the color of the roofing material. A continuous ridge vent can be installed in place of box vents, but the vent must extend across the entire ridge and not stop short. Built-in rain gutters will be retained and sealed where needed. Valleys must be metal W-shape with no interweaving of shingles. Valleys and flashing must be painted or factory-finished to match the roofing color, unless copper. When installing new flashing at a masonry feature, the flashing must be stepped or cut into the mortar joints. The bricks may not be cut to install flashing at an angle.

All work must be done in a craftsman-like manner, and must be completed within one year of the date this certificate was issued. Staff must approve any changes or additions to this certificate before work begins. Work that is not completed in accordance with this certificate may be subject to correction orders or citations. If you require technical assistance, contact Preservation staff as follows: Phone: (414) 286-5712 E-mail: hpc@milwaukee.gov.

Permits are required and you are responsible for obtaining them from the Milwaukee Development Center. If you have questions about permit requirements, please consult the Development Center's web site, www.milwaukee.gov/build, or call (414) 286-8210.



City of Milwaukee Historic Preservation Staff

Copies to: Development Center, Ald. Robert Bauman, Contractor






LANDMARK®

[COLORVIEW](#)

[GET AN ESTIMATE](#)



[OVERVIEW](#) [TECHNICAL INFO](#) [INSTALLATION](#) [WARRANTY](#) [FIND A PRO](#)

LANDMARK®

For homeowners seeking true peace of mind, Landmark® shingles are

PRODUCT OVERVIEW

- Landmark Series Brochure - Northwest
- Landmark Series Brochure - North

Approved shingle in approved color.