

Shelter Location - Permitted Sights

No.	Street Location	Existing Shelter	Power Source	Current Load	Possible Sources
1	16th St. at Wells	Yes			Marquette?
2	Wisconsin Ave. at 12th	Yes			Marquette/Wepco 548547
3	Wisconsin Ave. at 12th	Yes			Marquette/Wepco 130-137795/24-541-201
4	Wisconsin Ave. at 10th	Yes	Harp	1-2	City outlet
5	Wisconsin Ave. between 9th & 10th	Yes	Harp	1-2	City outlet
6	Wisconsin Ave. at 9th	Yes	Harp	1-2	City outlet
7	Wisconsin Ave. at 8th	Yes	Harp	1-2	City outlet
8	6th St. & Wells	Yes	Harp	6-2.3	City outlet
9	Wisconsin Ave. between 3rd & 4th	No	Harp	5-1-14.8	City outlet
10	Water St. at Wisconsin Ave.	Yes	Harp	1-4-3.3	City outlet
11	Wisconsin Ave. at Water	No	Harp	3-5-3.9	City outlet
12	Wisconsin Ave. between Milwaukee & Jefferson	Yes	Harp	12-14	Property owner street light circuitry
13	Wisconsin Ave. between Jackson & Jefferson	Yes	Harp	5-1-8.5	City outlet
14	Wisconsin Ave. between Jackson & VanBuren	Yes	Harp	8-3-16.4	Property owner street light circuitry
15	Wisconsin Ave. between Jackson & VanBuren	Yes	Harp	5-1-6.5	City outlet
16	Water St. at Kilbourn Ave.	Yes			City Hall street light circuitry
17	Water St. at State St.	Yes	Co. Parks		
18	Water St. at Juneau Ave.	No	Harp	8-11.5	City outlet
19	Wisconsin Ave. at 7th & 8th	Yes	Harp	8-9.5	City outlet
20	Water St. between Wisconsin & Michigan	No	Harp	3-5-3.9	City outlet
21	Wisconsin Ave. & Cass	Yes		9-16	Property owner street light circuitry
22	Prospect & Wells	Yes			University Club street light circuitry
23	48 3rd St. & Wells	No			Parking Structure
24	49 3rd St. & State	Yes	Co. Parks		
25	51 6th St. & Highland	Yes			Parking Structure
26	54 St. Paul & 4th	Yes			Amtak street light circuitry
27	55 Wisconsin Ave. & 6th	Yes			Harp/Widwest Exp. Auditorium
28	73 6th St. & State	Yes			Wepco 95-954-153
29	75 Plankinton at Wells	Yes			Wepco 63-801-527
30	78 Prospect & Mason	Yes			
31	81 Ogden & Farwell	Yes			
32	85 6th St. & Juneau	Yes			Parking Lot street light circuitry
33	87 6th St. & Wells	Yes			State Office Bldg
34	Wisconsin Ave. and 16th St.	Yes			Wepco 97-906-526
35	Layton (27th) and Evergreen	Yes	Co. Parks		
36	92 Oakland and Hampshire	Yes			Property owner street light circuitry
	Currently - 13 Harp lights, 3 Co. Parks.				
	Potential - 6 Marquette or Wepco.				
	Balance - 17 as noted				

Note: Harp lights have 15 amp design, should only be loaded up to 12 amp draw.