

Askin, Tim

From: Askin, Tim
Sent: Tuesday, May 28, 2019 11:36 AM
To: Tanner Sment
Cc: Hatala, Carlen
Subject: RE: Trinity Lutheran HPC Masonry Review

Thank you for noting that correction. Proceed as indicated with the pure lime NHL mortar (St. Astier NHL 3.5).

Tim Askin, Senior Planner
Historic Preservation Commission
City of Milwaukee
414-286-5712
Tim.Askin@Milwaukee.gov

From: Tanner Sment [mailto:TannerS@uihlein-wilson.com]
Sent: Tuesday, May 28, 2019 11:31 AM
To: Askin, Tim
Cc: Hatala, Carlen
Subject: RE: Trinity Lutheran HPC Masonry Review

(Apologies, see correction below)

Tim,

Following your suggestions, we want to proceed with a ~~Type O~~ **Type NHL** Mortar, Pure and Natural Hydraulic Lime Mortar containing no additives (St. Astier NHL 3.5 by Henry Frerk Sons)... suggested to us by our masonry expert contact. Contains no Portland Cement.

Hydraulic Lime: Sand Mix ratio for "poorly durable masonry"
Moderate exposure 1:3
Severe Exposure 2:5

I have provided you with the detailed information sheet and MSDS sheet attached if you are interested in more information.

We will follow with the same dye composition as discussed in a previous email.

Thank you,
-Tanner S

TANNER SMENT

Designer

UIHLEIN/WILSON - RAMLOW/STEIN ARCHITECTS

322 East Michigan Street, Milwaukee, WI 53202
Office - 414.271.8899 | www.uihlein-wilson.com

CHECK OUT OUR NEW WEBSITE - www.uihlein-wilson.com

Follow us on [LinkedIn](#), [Facebook](#), and [Instagram](#)