

TO: GRANT F. LANGLEY CITY OF MILWAUKEE MARCH 30, 2007
TO: ROBERT M. OVERHOLT 2007 APR -2 PM 1: 38

THIS LETTER IS IN REGARDS TO MY CLAIM THAT WAS DENIED. I WISH TO APPEAL THIS DECISION. I UNDERSTAND THE SEWER IN QUESTION IS ON A REGULAR 3 YEAR CLEANING SCHEDULE, PERHAPS THAT PERIOD HAS TO BE SHORTENED? I AM NOT AN EXPERT ON SEWERS, YOU HAVE CITY SEWER ENGINEERS FOR THAT. I DO KNOW THAT THE SEWER DID BACK UP INTO MY BASEMENT AND THE CITY IS RESPONSIBLE FOR SEWER MAINTENANCE AND THAT THE CITY IS RESPONSIBLE FOR THAT SEWER BACKING UP INTO MY BASEMENT.

CITY OF MILWAUKEE
RECEIVED

2007 APR 2 PM 3: 38

OFFICE OF
CITY ATTORNEY

SINCERELY,

Robert M. Buga

C.I. FILE # 07-S-49

To WHOM IT MAY CONCERN,

FEB 9, 2007

On December 14th, 2006 my son went (12 PM) downstairs to the basement and said it was flooded. When my daughter got out of work she came over with a portable pump. They pumped out the basement and we noticed the water was coming out of the floor drains. We called the City of Milwaukee and they came and checked inside and said they would do some work outside. They did some work on Euclid and South 41 street, and the drain stopped backing up. I am filing a claim against the city of Milwaukee for the following

New carpeting installed in basement was ruined	\$400 <u>00</u>
Personal items such as clothes, shoes and toys	\$150 <u>00</u>
Clean up expense	\$150 <u>00</u>
Total	700 <u>00</u>

Sincerely Isabel M. Puga

Isabel Puga
3174 S. 41 Street
Milwaukee, WI 53215

(414) 647-2173

OFFICE OF MILWAUKEE
2007 FEB 12 AM 10:19
RONALD O. LECHMANSKI
CITY CLERK

ATTORNEY

OFFICE OF
CITY ATTORNEY

2007 FEB 12 PM 3:37

CITY OF MILWAUKEE

CITY OF MILWAUKEE
 INFRASTRUCTURE
 ENVIRONMENTAL ENGINEERING
 SEWER MAINTENANCE

BACKWATER IN BASEMENT - CODE 1

Dispatched Location: 3124 S. 41st
 Received: (Date): 12-14-06 (Time): 10:15 AM (From): open
 Contact: (Person): ALBA (Phone #): 697-

FIELD INVESTIGATION
SEWER ENGINEERS
 AND REFERRED TO 10/13

Time Arrived: 11:40 PM Crew #: 5 Field Investigator: D.O. Assisted by: G.B.
 Sewer Type: SW Sewer Size: 8" Sewer Status: 206-Sewer Flow in Inches: _____
 Date of Backwater: 12/14/06 City Surcharge: Yes No MIS Surcharge: Yes No
 Highwater Mark from Top of Frame: _____ Lateral Clogged - Recommend Plumber

Sewer clog: 1. Obtain print when possible 2. Locate obstruction 3. Call proper equipment
 Time Found: 11:50 PM Time Began Cleaning: 1:25 AM Time Opened: 1:20 AM
 Opened By: 3153 S. 41st City Time Completed: 1:20 AM
 Location of Clog (note dry & backed-up manholes): 2.18
 Sewage Elevation (from top of manhole): 1/2 Top Obstruction Due To: CRACK
MIDDLE OF 320 Step/walk

Final Status & Additional Information: Hydroic Sewer was Closed -
However had some Damage to Personal
Items in Basement Due To Back-up. Carpeting,
etc. However said he would like to take
out carpets & throw out other items
that were damaged due to Back-up.
He said he plans on filing a claim
for damage. * we opened up 8" sewer
sewer with jet- club was due to
reverse in lines

MRS D.D. & G.B.
12-15-06







