

Askin, Tim

From: Joan Sweet <sweetjt@wi.rr.com>
Sent: Monday, March 27, 2017 11:07 AM
To: Askin, Tim
Cc: 'Nova'; 'Michael Grober'
Subject: submittal for Salon Nova
Attachments: 2581 N Downer COM-ALT-17-00071; Salon Nova window submittal.pdf; SalonNova (002).pdf; Mathcad - 2009 IBC (ASCE 7-05) Low Rise.pdf

Tim. Attached is the submittal for Salon Nova. We can NOT do the one pane of glass. We will not meet code for strength of system or the U value of the glass. Additionally it can not be manufactured at that size. Let me know if you need this printed out, or if PDF's will suffice.

Joan Sweet, Architect

Sweet Designs

1435 Stonefield Ct
Waukesha, WI 53186
262-227-1228

www.jsweetdesigns.com