

Certificate of Appropriateness

Milwaukee Historic Preservation Commission/200 E. Wells Street/Milwaukee, WI 53202/phone 414-286-5712/fax 414-286-3004

LIVING WITH HISTORY

Property3379 N. SHERMAN BL.Sherman Boulevard Historic DistrictDescription of workApplicant is replacing gas boiler.Date issued7/28/2016PTS IDPTS ID112543 COA New boiler

In accordance with the provisions of Section 320-21 (11) and (12) of the Milwaukee Code of Ordinances, the Milwaukee Historic Preservation Commission has issued a certificate of appropriateness for the work listed above. The work was found to be consistent with preservation guidelines. The following conditions apply to this certificate of appropriateness:

No venting of the boiler is to be done at the front of the house or along the sides where visible from the street. Venting at the rear of the property is appropriate. All PVC pipes will be painted out to match the house.

All work must be done in a craftsman-like manner, and must be completed within one year of the date this certificate was issued. Staff must approve any changes or additions to this certificate before work begins. Work that is not completed in accordance with this certificate may be subject to correction orders or citations. If you require technical assistance, please contact Carlen Hatala of the Historic Preservation staff as follows: Phone: (414) 286-5722 Fax: (414) 286-3004 E-mail: carlen.hatala@milwaukee.gov.

If permits are required, you are responsible for obtaining them from the Milwaukee Development Center. If you have questions about permit requirements, please consult the Development Center's web site, <u>www.milwaukee.gov/build</u>, or call (414) 286-8210.

Carlo Satal

City of Milwaukee Historic Preservation Staff

Copies to: Development Center, Ald. Willie Wade, Contractor, Inspector Cary Rafalski (286-2520)

