



Certificate of Appropriateness

Milwaukee Historic Preservation Commission/200 E. Wells Street/Milwaukee, WI 53202/phone 414-286-5712/fax 414-286-3004

Property	735 N. WATER ST.	First National Bank/First Wisconsin National Bank Building
Description of work	Install rooftop HVAC equipment per attached specifications at indicated locations.	
Date issued	3/27/2018	PTS ID 114487 COA: rooftop HVAC


In accordance with the provisions of Section 320-21 (11) and (12) of the Milwaukee Code of Ordinances, the Milwaukee Historic Preservation Commission has issued a certificate of appropriateness for the work listed above. The work was found to be consistent with preservation guidelines. The following conditions apply to this certificate of appropriateness:

All work must be done in a craftsman-like manner, and must be completed within one year of the date this certificate was issued. Staff must approve any changes or additions to this certificate before work begins. Work that is not completed in accordance with this certificate may be subject to correction orders or citations. If you require technical assistance, please contact Dean Doerrfeld of the Historic Preservation staff as follows: Phone: (414) 286-5712 E-mail: Dean.Doerrfeld@milwaukee.gov.

If permits are required, you are responsible for obtaining them from the Milwaukee Development Center. If you have questions about permit requirements, please consult the Development Center's web site, www.milwaukee.gov/build, or call (414) 286-8210.

City of Milwaukee Historic Preservation Staff


Copies to: Development Center, Ald. Robert Bauman, Contractor, Inspector John Cunningham (286-2538)





LIEBERT PFH

CABINET DIMENSIONAL DATA CONDENSING UNIT W/ HORIZONTAL AIR DISCHARGE




MODEL NUMBERS		DIMENSIONAL DATA IN. (mm)			MODULE WEIGHT
60 HZ	50HZ	A	B	C	lbs. (kg) net.
PFH014A-L	NA	40 (1016)	23 1/2 (597)	18 (457)	200 (91)
PFH020A-L	NA				
PFH027A-L	NA				



VERTIV.

LIEBERT PFH

CABINET DIMENSIONAL DATA CONDENSING UNIT W/ HORIZONTAL AIR DISCHARGE



MODEL NUMBERS	DIMENSIONAL DATA IN. (mm)			MODULE WEIGHT lbs. (kg) net.
	A	B	C	
60 HZ				
PFH014A-L	40 (1016)	23 1/2 (597)	18 (457)	200 (91)
PFH020A-L				
PFH027A-L				
PFH027A-H				
PFHZ27A-L	48 (1219)	31 (787)	18 (457)	241 (109)
PFH037A-L				
PFH037A-H				
PFH042A-L				
PFH042A-H				
PFH042A-L				
PFH042A-H				
PFH041A-L				
PFH041A-H				
PFH067A-L	53 (1343)	36 1/4 (918)	18 (457)	351 (159)
PFH066A-L				