



Tom Barrett
Mayor

Jeanette Kowalik, PhD, MPH, MCHES
Commissioner of Health

www.milwaukee.gov/health

Frank P. Zeidler Municipal Building, 841 North Broadway, 3rd Floor, Milwaukee, WI 53202-3653

phone (414) 286-3521

fax (414) 286-5990

September 27, 2019

Central City Cyberschool
4301 North 44th Street
Milwaukee, WI 53216

The City of Milwaukee Health Department (MHD) conducted water sampling as stated in Common Council Resolution File Number 171520. The collected water samples were analyzed for lead to determine if there were any detected lead levels in the water outlets. All sampling procedures were done according to the United States Environmental Protection Agency (EPA) *3Ts for Reducing Lead in Drinking Water in Schools Guidance* (3Ts).

Sampling and Testing

The collection of the samples took place on the morning of March 23, 2019 and April 10, 2019. A total of 93 water outlets were sampled in the school. Each outlet was tested twice, the second sample was taken after the water was run for 30 seconds after the first draw. The water was stagnant for a minimum of 8 hours, 250 milliliter (mL) water samples were collected before the water was used in the building. Each sample was labeled with the location, date, and time sampled. After finishing the sample collection, the samples were submitted to the City of Milwaukee Health Department Laboratory, a certified drinking water laboratory (ID: 241311290) with the Wisconsin Department of Natural Resources, for lead analysis.

Results

Please see the attached Water Sample Results Table for a summary of the water sample results. 26 samples had detectable levels of lead ranging from 1.0 µg/L (micrograms per liter) to 4.9 µg/L. However, 13 samples had detectable levels of lead ranging greater than 5.0 µg/L. The rest of the outlets had lead levels below 1.0 µg/L.

There is no safe level of lead in water. MHD provides recommendations for each outlet on the attached Water Sample Results Table. Any water outlet designed specifically for drinking (e.g. bubbler, water fountain, etc.) that has detectable levels of lead should be taken out of service, install a certified drinking water filter for lead removal, or provide bottled water from a lead-free source. Any water outlet that is not designed specifically for drinking (e.g., sink, washbasin, etc.) that has detectable levels of lead should be considered for placarding if the lead level is less than 5.0 µg/L, and must be placarded (or, alternatively, filtered or removed from service) for levels higher than 5.0 µg/L. Any remediation activities or additional water samples that may need to be completed will be done at the cost of the school and/or the property owner.

The only way to determine if a child has been lead poisoned is to have their blood tested. Parents/Guardians can have their child tested at their primary care physician. MHD recommends that a child be tested for lead three times before the age of three. If children weren't tested before the age of three, MHD recommends testing children up to the age of six. For older children, parents should talk to their medical provider about their child's exposure risk.

Please share these results with Parents/Guardians, staff, and students. As stated in the 3Ts, Parents/Guardians, staff, and students should be notified of the water testing and the testing results. If there are any questions regarding lead poisoning, please contact the MHD Childhood Lead Poisoning Prevention Program at 414-286-2165 or go to www.leadsafeMKE.com. If there are any questions or concerns about your results or remediation options, please call me at (414) 286-3451.

Sincerely,

Ofelia R. Mondragon, BBM
Home Environment Health Manager

Encl: Water Sample Results Table, Lead in Drinking Water Chain of Custody and Requisition Forms, and MHD Laboratory Results



Central City Cyberschool Preschool Building 4301 North 44th Street		Lead Results (µg/L)				MHD Recommendations as of 5/1/2019
Sample Number	Sample Description	~5/25/2017	9/22/2018	4/10/2019	4/10/2019 30 sec Flush	
1	Laundry Room Slop Sink (Long Run)	1.3	1.5	2.9	<1.0	Consider Placard
2	Laundry Room Middle Sink	8.2	<1.0	<1.0	<1.0	No Action
3	Kitchen Middle Sink	130	6.9	13.0	3.6	Placard
4	Kitchen Wall Sink 45th Street	51	150.0	44.0	5.1	Placard
5	Kitchen Sink East	--	6.1	13.0	1.2	Placard
6	Room 423 Sink	3.6	2.2	4.7	<1.0	Consider Placard
7	Room 423 Bathroom East	11	7.5	170.0	1.9	Placard
8	Room 423 Bathroom West	2.2	1.3	2.0	<1.0	Consider Placard
9	Room 424	3.0	<1.0	4.00	<1.0	Consider Placard
10	Room 424 Bathroom East	2.9	2.7	4.4	<1.0	Consider Placard
11	Room 424 Bathroom West	5.5	2.5	5.2	<1.0	Placard
12	Staff Room Sink	3.7	4.4	<1.0	1.1	Consider Placard
13	Staff Room Bathroom	1.4	<1.0	10.00	<1.0	Placard
14	Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
15	Men's Room Sink	2.9	<1.0	<1.0	<1.0	No Action
16	Women's Room Sink	3.2	<1.0	1.00	<1.0	Consider Placard
17	Hall Staff Kitchen Sink	<1.0	<1.0	<1.0	1.1	Consider Placard

Results indicated in **red** exceed the 5 parts per billion (ppb) standard established by the City of Milwaukee Common Council in Resolution File Number 171520

The 2019 samples were collected by the City of Milwaukee Health Department and analyzed by the City of Milwaukee Health Department Laboratory

Definitions:

1 µg/L = 1 ppb

~ Samples collected by Milwaukee Water Works (MWW) and analyzed by Eurofins.
MWW utilized 15 ppb as the lead in drinking water standard.

--: No Sample Taken. Outlet Out of Service

* Outlet was not found. No Sample Taken.

Outlet replaced by the school.

Placard: City of Milwaukee May Contain Lead Not Safe For Drinking Sign

Central City Cyberschool Main Building 4301 North 44th Street		Lead Results (µg/L)		Lead Results (µg/L) 03/23/2019		MHD Recommendations as of 3/23/2019
Sample Number	Sample Description	~5/25/2017	9/22/2018	1st	30sec Flush	
	1st Floor Laundry Room Sink	--	3.5	--	--	Re-test before Back In Service
1	Meter Locker Room Bathroom (Long Run)	<1.0	<1.0	--	--	Re-test before Back In Service
2	Kitchen Custodial (Long Run)	--	19.0	1.3	3.6	Consider Placard
3	Kitchen Hand Wash	<1.0	1.1	1.5	<1.0	Consider Placard
4	Kitchen Back Sink	1.3	<1.0	<1.0	<1.0	No Action
5	Dish Wash Sink Back Right	1.8	1.8	1.7	<1.0	Consider Placard
6	Dish Wash Sink Back Left	1.5	<1.0	1.40	<1.0	Consider Placard
7	Right of Dishwasher Sink	3.7	<1.0	4.3	<1.0	Consider Placard
8	Dish Wash Prep Sink	<1.0	<1.0	2.10	<1.0	Consider Placard
9	Pot Sink	1.5	<1.0	1.00	<1.0	Consider Placard
10	Cafeteria Bubblers Tall	<1.0	<1.0	<1.0	<1.0	No Action
11	Cafeteria Bubblers Short	<1.0	<1.0	<1.0	<1.0	No Action
12	Main Office Bubblers Across From Cafeteria Tall	<1.0	<1.0	<1.0	<1.0	No Action
13	Main Office Bubblers Across From Cafeteria Short	<1.0	<1.0	<1.0	<1.0	No Action
14	Main Office Sink	1.8	<1.0	<1.0	<1.0	No Action
15	Main Office Women's Restroom Left	<1.0	<1.0	<1.0	<1.0	No Action
16	Main Office Women's Restroom Right	<1.0	<1.0	<1.0	<1.0	No Action
17	Main Office Men's Restroom Left	<1.0	<1.0	<1.0	<1.0	No Action
18	Main Office Men's Restroom Right	<1.0	<1.0	--	--	Re-test before Back In Service
19	Room 102 Sink	v	<1.0	<1.0	<1.0	No Action
20	Room 104 Sink	<1.0	<1.0	<1.0	<1.0	No Action
21	Room 110 Bathroom	<1.0	<1.0	<1.0	<1.0	No Action
22	Room 110 Kitchen Sink	<1.0	<1.0	<1.0	<1.0	No Action
23	Room 201 Sink Art Room Right	<1.0	<1.0	<1.0	<1.0	No Action
24	Room 201 Sink Art Room Left	<1.0	<1.0	1.9	<1.0	Consider Placard
25	Bubbler Outside Restroom Tall	<1.0	--	--	--	Re-test before Back In Service
26	Bubbler Outside Restroom Short	<1.0	--	--	--	Re-test before Back In Service
27	Men's Room Step Sink	--	<1.0	<1.0	<1.0	No Action
28	Women's Room Step Sink	<1.0	<1.0	<1.0	<1.0	No Action
29	Locked Restroom Southeast Corner Sink	<1.0	<1.0	<1.0	<1.0	No Action
30	Room 204 Sink	3.2	1.2	<1.0	<1.0	No Action
31	Room 204 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
32	Room 203 Sink	<1.0	<1.0	<1.0	<1.0	No Action
33	Room 203 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
34	Room 206 Sink	1.8	2.0	<1.0	<1.0	No Action
35	Room 206 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
36	Room 205 Sink	<1.0	<1.0	<1.0	<1.0	No Action
37	Room 205 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
38	Room 209 Sink	1.8	<1.0	<1.0	<1.0	No Action
39	Room 209 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
40	Room 210 Sink	<1.0	<1.0	<1.0	<1.0	No Action
41	Room 210 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
42	Room 211 Sink	<1.0	<1.0	<1.0	<1.0	No Action
43	Room 211 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
44	Room 212 Sink	<1.0	<1.0	<1.0	<1.0	No Action
45	Room 212 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
46	Room 301 Science Lab Wash Sink	20	23.0	1.5	<1.0	Consider Placard
47	Science Lab Station 1 Right	200	7.0	<1.0	<1.0	No Action
48	Science Lab Station 1 Left	9.9	3.7	<1.0	<1.0	No Action
49	Science Lab Station 2 Right	75	5.8	1.1	<1.0	Consider Placard
50	Science Lab Station 2 Left	15	18.0	13.0	<1.0	Placard
51	Science Lab Station 3 Right	27	23.0	21.0	<1.0	Placard
52	Science Lab Station 3 Left	21	17.0	<1.0	<1.0	No Action
53	Science Lab Station 4 Right	23	24.0	2.8	<1.0	Consider Placard
54	Science Lab Station 4 Left	34	19.0	<1.0	9.5	Placard
55	Science Lab Station 5 Right Sink #1	29	22.0	7.7	<1.0	Placard
56	Science Lab Station 5 Right Sink #2	24	22.0	4.1	<1.0	Consider Placard
57	Science Lab Station 5 Left Sink #1	16	14.0	<1.0	<1.0	No Action
58	Science Lab Station 5 Left Sink #2	25	30.0	11.0	<1.0	Placard
59	Science Lab Station 6 Right Sink #1	270	14.0	1.2	<1.0	Consider Placard
60	Science Lab Station 6 Right Sink #2	220	10.0	<1.0	<1.0	No Action
61	Science Lab Station 6 Left Sink #1	17	19.0	2.3	<1.0	No Action
62	Science Lab Station 6 Left Sink #2	4.5	56.0	18.0	<1.0	Placard
63	Science Lab Eye Wash	15	1.6	17.0	18.0	Placard
64	Science Lab Instructor Sink	130	2.2	2.8	<1.0	Consider Placard
65	Bubbler Next to Science Lab Tall	<1.0	<1.0	<1.0	<1.0	No Action
66	Bubbler Next to Science Lab Short	<1.0	<1.0	<1.0	<1.0	No Action
67	Men's Room Step Sink	<1.0	<1.0	<1.0	<1.0	No Action
68	Women's Room Step Sink	1.5	1.1	1.2	<1.0	Consider Placard
69	3rd Floor Mop Sink	--	<1.0	<1.0	<1.0	No Action
70	Room 304 Sink	5.2	3.8	3.2	<1.0	Consider Placard
71	Room 304 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
72	Room 303 Sink	1.5	1.0	<1.0	<1.0	No Action
73	Room 303 Bubbler	<1.0	<1.0	--	--	Re-test before Back In Service
74	Room 305 Sink	<1.0	1.1	<1.0	<1.0	No Action
75	Room 305 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
76	Room 306 Sink	<1.0	<1.0	1.7	<1.0	Consider Placard
77	Room 306 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
78	Room 308 Sink	<1.0	3.3	--	--	Re-test before Back In Service
79	Room 308 Bubbler	<1.0	<1.0	--	--	Re-test before Back In Service
80	Room 309 Sink	2.4	1.6	2.9	<1.0	Consider Placard
81	Room 309 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
82	Room 311 Sink	<1.0	<1.0	<1.0	<1.0	No Action
83	Room 311 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
84	Room 310 Sink	1.7	1.8	1.2	<1.0	Consider Placard
85	Room 310 Bubbler	--	--	--	--	Re-test before Back In Service

Results indicated in red exceed the 5 parts per billion (ppb) standard established by the City of Milwaukee Common Council in Resolution File Number 171520

The 2019 samples were collected by the City of Milwaukee Health Department and analyzed by the City of Milwaukee Health Department Laboratory

Definitions:

1 µg/L = 1 ppb

~ Samples collected by Milwaukee Water Works (MWW) and analyzed by Eurofins. MWW utilized 15 ppb as the lead in drinking water standard.

--- No Sample Taken. Outlet Out of Service

* Outlet was not found. No Sample Taken.

Outlet replaced by the school.

Placard: City of Milwaukee May Contain Lead Not Safe For Drinking Sign

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280033
LRN : 0000279444
Auxiliary ID : Sample #1
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Kitchen custodial (long run)

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.3			ug Pb/L	04/09/19 16:13
Test Method	*see below				04/09/19 16:13

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280034
LRN : 0000279444
Auxiliary ID : Sample #2
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301

DOB:

Age:

Sex:

Ord. Comm: Central City Cyberschool Main Building
Kitchen Custodial (long run) 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*3.6			ug Pb/L	04/09/19 16:13
Test Method	*see below				04/09/19 16:13

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280035
LRN : 0000279444
Auxiliary ID : Sample #3
Date Collected: 03/23/19
Date Received : 03/28/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Kitchen Hand Wash

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.5			ug Pb/L	04/09/19 16:13
Test Method	*see below				04/09/19 16:13

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280037
LRN : 0000279444
Auxiliary ID : Sample #4
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Kitchen Hand Wash 30 sec Flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/09/19 16:14
Test Method	*see below				04/09/19 16:14

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280041
LRN : 0000279444
Auxiliary ID : Sample #5
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Kitchen Back Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/09/19 16:14
Test Method	*see below				04/09/19 16:14

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280045
LRN : 0000279444
Auxiliary ID : Sample #6
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Kitchen Back Sink 30 sec Flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/09/19 16:14
Test Method	*see below				04/09/19 16:14

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280047
LRN : 0000279444
Auxiliary ID : Sample #7
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Dish Wash Sink Back Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.7			ug Pb/L	04/09/19 16:14
Test Method	*see below				04/09/19 16:14

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280052
LRN : 0000279444
Auxiliary ID : Sample #8
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Dish Wash Sink Back Right 30 sec Flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/09/19 16:14
Test Method	*see below				04/09/19 16:14

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280064
LRN : 0000279444
Auxiliary ID : Sample #9
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Dish wash sink back left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.4			ug Pb/L	04/09/19 16:14
Test Method	*see below				04/09/19 16:14

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280065
LRN : 0000279444
Auxiliary ID : Sample #10
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Dish wash sink back left 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/09/19 16:14
Test Method	*see below				04/09/19 16:14

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280066
LRN : 0000279444
Auxiliary ID : Sample #11
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Right of dishwasher sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*4.3			ug Pb/L	04/09/19 16:15
Test Method	*see below				04/09/19 16:15

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/09/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280068
LRN : 0000279444
Auxiliary ID : Sample #12
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Right of dishwasher sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/09/19 16:15
Test Method	*see below				04/09/19 16:15

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280071
LRN : 0000279444
Auxiliary ID : Sample #13
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Dish wash prep sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.1			ug Pb/L	04/09/19 16:15
Test Method	*see below				04/09/19 16:15

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280077
LRN : 0000279444
Auxiliary ID : Sample #14
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Dish wash prep sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/09/19 16:15
Test Method	*see below				04/09/19 16:15

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280080
LRN : 0000279444
Auxiliary ID : Sample #15
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Pot sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.0			ug Pb/L	04/09/19 16:15
Test Method	*see below				04/09/19 16:15

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/09/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280082
LRN : 0000279444
Auxiliary ID : Sample #16
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Pot sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:56
Test Method	*see below				04/11/19 15:56

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280088
LRN : 0000279444
Auxiliary ID : Sample #17
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Cafeteria bubbler tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/11/19 15:56
Test Method	*see below				04/11/19 15:56

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280090
LRN : 0000279444
Auxiliary ID : Sample #18
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Cafeteria bubbler tall 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/11/19 15:56
Test Method	*see below				04/11/19 15:56

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280091
LRN : 0000279444
Auxiliary ID : Sample #19
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Cafeteria bubbler short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/11/19 15:56
Test Method	*see below				04/11/19 15:56

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280092
LRN : 0000279444
Auxiliary ID : Sample #20
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Cafeteria bubbler short 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:56
Test Method	*see below				04/11/19 15:56

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280093
LRN : 0000279444
Auxiliary ID : Sample #21
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Main office bubbler across from cafeteria tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/11/19 15:56
Test Method	*see below				04/11/19 15:56

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280094
LRN : 0000279444
Auxiliary ID : Sample #22
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Main office bubbler across from cafeteria tall
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:56
Test Method	*see below				04/11/19 15:56

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280095
LRN : 0000279444
Auxiliary ID : Sample #23
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Main office bubbler across from cafeteria short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/11/19 15:57
Test Method	*see below				04/11/19 15:57

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280096
LRN : 0000279444
Auxiliary ID : Sample #24
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Main office bubbler across from cafeteria short
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:57
Test Method	*see below				04/11/19 15:57

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280112
LRN : 0000279444
Auxiliary ID : Sample #25
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Main office sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:57
Test Method	*see below				04/11/19 15:57

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280114
LRN : 0000279444
Auxiliary ID : Sample #26
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Main office sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/11/19 15:57
Test Method	*see below				04/11/19 15:57

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280116
LRN : 0000279444
Auxiliary ID : Sample #27
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Main office women's restroom left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:57
Test Method	*see below				04/11/19 15:57

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/11/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280117
LRN : 0000279444
Auxiliary ID : Sample #28
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Main office women's restroom 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:57
Test Method	*see below				04/11/19 15:57

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280123
LRN : 0000279444
Auxiliary ID : Sample #29
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Main office women's restroom right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:57
Test Method	*see below				04/11/19 15:57

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280124
LRN : 0000279444
Auxiliary ID : Sample #30
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Main office women's restroom right 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:57
Test Method	*see below				04/11/19 15:57

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280125
LRN : 0000279444
Auxiliary ID : Sample #31
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Main office men's restroom left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:57
Test Method	*see below				04/11/19 15:57

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9280126
LRN : 0000279444
Auxiliary ID : Sample #32
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Main office men's restroom left 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:57
Test Method	*see below				04/11/19 15:57

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290012
LRN : 0000279444
Auxiliary ID : Sample #33
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 102 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:57
Test Method	*see below				04/11/19 15:57

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290013
LRN : 0000279444
Auxiliary ID : Sample #34
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 102 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:58
Test Method	*see below				04/11/19 15:58

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/11/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290014
LRN : 0000279444
Auxiliary ID : Sample #35
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 104 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:58
Test Method	*see below				04/11/19 15:58

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290015
LRN : 0000279444
Auxiliary ID : Sample #36
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 104 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/11/19 15:58
Test Method	*see below				04/11/19 15:58

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290016
LRN : 0000279444
Auxiliary ID : Sample #37
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Room 110 bathroom

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:58
Test Method	*see below				04/11/19 15:58

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290017
LRN : 0000279444
Auxiliary ID : Sample #38
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 110 Bathroom 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:58
Test Method	*see below				04/11/19 15:58

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290018
LRN : 0000279444
Auxiliary ID : Sample #39
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 110 kitchen sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:58
Test Method	*see below				04/11/19 15:58

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290019
LRN : 0000279444
Auxiliary ID : Sample #40
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 110 kitchen sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/11/19 15:58
Test Method	*see below				04/11/19 15:58

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290020
LRN : 0000279444
Auxiliary ID : Sample #41
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 201 sink art rm right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/15/19 15:36
Test Method	*see below				04/15/19 15:36

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290021
LRN : 0000279444
Auxiliary ID : Sample #42
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 201 sink art rm right 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/15/19 15:36
Test Method	*see below				04/15/19 15:36

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290023
LRN : 0000279444
Auxiliary ID : Sample #43
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 201 sink art rm left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*1.9			ug Pb/L	04/15/19 15:36
Test Method	*see below				04/15/19 15:36

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290025
LRN : 0000279444
Auxiliary ID : Sample #44
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 201 sink art rm left 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/15/19 15:36
Test Method	*see below				04/15/19 15:36

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290059
LRN : 0000279444
Auxiliary ID : Sample #49
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Men's room step sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/15/19 15:36
Test Method	*see below				04/15/19 15:36

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/15/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290060
LRN : 0000279444
Auxiliary ID : Sample #50
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Men's room step sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/15/19 15:37
Test Method	*see below				04/15/19 15:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290061
LRN : 0000279444
Auxiliary ID : Sample #51
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Women's room step sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/15/19 15:37
Test Method	*see below				04/15/19 15:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290062
LRN : 0000279444
Auxiliary ID : Sample #52
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Women's room step sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/15/19 15:37
Test Method	*see below				04/15/19 15:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290066
LRN : 0000279444
Auxiliary ID : Sample #53
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Locked restroom southeast corner sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/15/19 15:37
Test Method	*see below				04/15/19 15:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/15/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290069
LRN : 0000279444
Auxiliary ID : Sample #54
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Locked restroom southeast corner sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/15/19 15:37
Test Method	*see below				04/15/19 15:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290071
LRN : 0000279444
Auxiliary ID : Sample #55
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 204 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/15/19 15:37
Test Method	*see below				04/15/19 15:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290073
LRN : 0000279444
Auxiliary ID : Sample #56
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 204 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/15/19 15:38
Test Method	*see below				04/15/19 15:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290076
LRN : 0000279444
Auxiliary ID : Sample #57
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 204 bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/15/19 15:38
Test Method	*see below				04/15/19 15:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290078
LRN : 0000279444
Auxiliary ID : Sample #58
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 204 bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/15/19 15:38
Test Method	*see below				04/15/19 15:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290079
LRN : 0000279444
Auxiliary ID : Sample #59
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 203 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/15/19 15:38
Test Method	*see below				04/15/19 15:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/15/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : R9290082
LRN : 0000279444
Auxiliary ID : Sample #60
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 203 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/15/19 15:39
Test Method	*see below				04/15/19 15:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0020149
LRN : 0000279444
Auxiliary ID : Sample #61
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 203 bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/15/19 15:39
Test Method	*see below				04/15/19 15:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0020154
LRN : 0000279444
Auxiliary ID : Sample #62
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 203 bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/15/19 15:39
Test Method	*see below				04/15/19 15:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0020158
LRN : 0000279444
Auxiliary ID : Sample #63
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 206 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/15/19 15:39
Test Method	*see below				04/15/19 15:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0020162
LRN : 0000279444
Auxiliary ID : Sample #64
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 206 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/15/19 15:39
Test Method	*see below				04/15/19 15:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0020165
LRN : 0000279444
Auxiliary ID : Sample #65
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 206 bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/15/19 15:39
Test Method	*see below				04/15/19 15:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0020166
LRN : 0000279444
Auxiliary ID : Sample #66
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 206 bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:22
Test Method	*see below				04/17/19 13:22

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0020168
LRN : 0000279444
Auxiliary ID : Sample #67
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 205 bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:22
Test Method	*see below				04/17/19 13:22

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0020169
LRN : 0000279444
Auxiliary ID : Sample #68
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 205 bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:22
Test Method	*see below				04/17/19 13:22

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0020174
LRN : 0000279444
Auxiliary ID : Sample #69
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 205 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:22
Test Method	*see below				04/17/19 13:22

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0020175
LRN : 0000279444
Auxiliary ID : Sample #70
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301

DOB:

Age:

Sex:

Ord. Comm: Central City Cyberschool Main Building
Rm 205 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:22
Test Method	*see below				04/17/19 13:22

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0020176
LRN : 0000279444
Auxiliary ID : Sample #71
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 209 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:22
Test Method	*see below				04/17/19 13:22

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0020184
LRN : 0000279444
Auxiliary ID : Sample #72
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 209 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:22
Test Method	*see below				04/17/19 13:22

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0040092
LRN : 0000279444
Auxiliary ID : Sample #73
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 209 Bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:23
Test Method	*see below				04/17/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0040093
LRN : 0000279444
Auxiliary ID : Sample #74
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 209 Bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:23
Test Method	*see below				04/17/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0040094
LRN : 0000279444
Auxiliary ID : Sample #75
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 210 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:23
Test Method	*see below				04/17/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0040095
LRN : 0000279444
Auxiliary ID : Sample #76
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 210 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:23
Test Method	*see below				04/17/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0040096
LRN : 0000279444
Auxiliary ID : Sample #77
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 210 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:23
Test Method	*see below				04/17/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0040098
LRN : 0000279444
Auxiliary ID : Sample #78
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 210 bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:23
Test Method	*see below				04/17/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0040099
LRN : 0000279444
Auxiliary ID : Sample #79
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 211 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:23
Test Method	*see below				04/17/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0040100
LRN : 0000279444
Auxiliary ID : Sample #80
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 211 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:23
Test Method	*see below				04/17/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050019
LRN : 0000279444
Auxiliary ID : Sample #81
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 211 bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/17/19 13:23
Test Method	*see below				04/17/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050021
LRN : 0000279444
Auxiliary ID : Sample #82
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 211 bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/17/19 13:23
Test Method	*see below				04/17/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050023
LRN : 0000279444
Auxiliary ID : Sample #83
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 212 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:24
Test Method	*see below				04/17/19 13:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050024
LRN : 0000279444
Auxiliary ID : Sample #84
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 212 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:24
Test Method	*see below				04/17/19 13:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050025
LRN : 0000279444
Auxiliary ID : Sample #85
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 212 bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:24
Test Method	*see below				04/17/19 13:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050026
LRN : 0000279444
Auxiliary ID : Sample #86
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 212 bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:24
Test Method	*see below				04/17/19 13:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050027
LRN : 0000279444
Auxiliary ID : Sample #87
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 301 science lab wash sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.5			ug Pb/L	04/17/19 13:24
Test Method	*see below				04/17/19 13:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050028
LRN : 0000279444
Auxiliary ID : Sample #88
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 301 science lab was sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:24
Test Method	*see below				04/17/19 13:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050029
LRN : 0000279444
Auxiliary ID : Sample #89
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 1 right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:24
Test Method	*see below				04/17/19 13:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050030
LRN : 0000279444
Auxiliary ID : Sample #90
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301

DOB:

Age:

Sex:

Ord. Comm: Central City Cyberschool Main Building
Science lab station 1 right 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/17/19 13:25
Test Method	*see below				04/17/19 13:25

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050031
LRN : 0000279444
Auxiliary ID : Sample #91
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 1 left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/18/19 15:27
Test Method	*see below				04/18/19 15:27

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050032
LRN : 0000279444
Auxiliary ID : Sample #92
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 1 left 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/18/19 15:28
Test Method	*see below				04/18/19 15:28

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050053
LRN : 0000279444
Auxiliary ID : Sample #93
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab ststion 2 right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*1.1			ug Pb/L	04/18/19 15:28
Test Method	*see below				04/18/19 15:28

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050054
LRN : 0000279444
Auxiliary ID : Sample #94
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station right 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/18/19 15:28
Test Method	*see below				04/18/19 15:28

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050077
LRN : 0000279444
Auxiliary ID : Sample #95
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 2 left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*13.0			ug Pb/L	04/18/19 15:28
Test Method	*see below				04/18/19 15:28

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050083
LRN : 0000279444
Auxiliary ID : Sample #96
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301

DOB:

Age:

Sex:

Ord. Comm: Central City Cyberschool Main Building
Science lab station 2 left 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/18/19 15:28
Test Method	*see below				04/18/19 15:28


Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290



Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050089
LRN : 0000279444
Auxiliary ID : Sample #97
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 3 right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*21.0			ug Pb/L	04/24/19 15:41
Test Method	*see below				04/24/19 15:41

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0050091
LRN : 0000279444
Auxiliary ID : Sample #98
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 3 right 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/18/19 15:29
Test Method	*see below				04/18/19 15:29

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080006
LRN : 0000279444
Auxiliary ID : Sample #99
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab 3 left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/18/19 15:29
Test Method	*see below				04/18/19 15:29

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080007
LRN : 0000279444
Auxiliary ID : Sample #100
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301 DOB: Age: Sex:

Ord. Comm: Central City Cyberschool Main Building
Science lab 3 left 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/18/19 15:29
Test Method	*see below				04/18/19 15:29

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080009
LRN : 0000279444
Auxiliary ID : Sample #101
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 4 right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.8			ug Pb/L	04/18/19 15:29
Test Method	*see below				04/18/19 15:29

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080011
LRN : 0000279444
Auxiliary ID : Sample #102
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 4 right 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/18/19 15:29
Test Method	*see below				04/18/19 15:29

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080012
LRN : 0000279444
Auxiliary ID : Sample #103
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 4 left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/18/19 15:29
Test Method	*see below				04/18/19 15:29

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080013
LRN : 0000279444
Auxiliary ID : Sample #104
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 4 left 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*9.5			ug Pb/L	04/18/19 15:30
Test Method	*see below				04/18/19 15:30

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080014
LRN : 0000279444
Auxiliary ID : Sample #105
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 5 right #1

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*7.7			ug Pb/L	04/18/19 15:30
Test Method	*see below				04/18/19 15:30

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080015
LRN : 0000279444
Auxiliary ID : Sample #106
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 5 right sink #1
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/18/19 15:30
Test Method	*see below				04/18/19 15:30

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080016
LRN : 0000279444
Auxiliary ID : Sample #107
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 5 right sink # 2

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*4.1			ug Pb/L	04/18/19 15:30
Test Method	*see below				04/18/19 15:30

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080019
LRN : 0000279444
Auxiliary ID : Sample #108
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 5 right sink #2
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/18/19 15:30
Test Method	*see below				04/18/19 15:30

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080023
LRN : 0000279444
Auxiliary ID : Sample #109
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 5 left sink #1

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/18/19 15:30
Test Method	*see below				04/18/19 15:30

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080024
LRN : 0000279444
Auxiliary ID : Sample #110
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 5 left sink #1
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/18/19 15:30
Test Method	*see below				04/18/19 15:30

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080025
LRN : 0000279444
Auxiliary ID : Sample #111
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/N/44THST, 4301**

DOB:

Age:

Sex:

Ord. Comm: Central City Cyberschool Main Building
Science lab station 5 left sink #2

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*11.0			ug Pb/L	04/18/19 15:31
Test Method	*see below				04/18/19 15:31

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080026
LRN : 0000279444
Auxiliary ID : Sample #112
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 5 left sink #2
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/18/19 15:31
Test Method	*see below				04/18/19 15:31

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080030
LRN : 0000279444
Auxiliary ID : Sample #113
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 6 right sink #1

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.2			ug Pb/L	04/18/19 15:31
Test Method	*see below				04/18/19 15:31

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080033
LRN : 0000279444
Auxiliary ID : Sample #114
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 6 right sink #1
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/18/19 15:31
Test Method	*see below				04/18/19 15:31

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080034
LRN : 0000279444
Auxiliary ID : Sample #115
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 6 right sink #2

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/18/19 15:31
Test Method	*see below				04/18/19 15:31

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080035
LRN : 0000279444
Auxiliary ID : Sample #116
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 6 right sink #2
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/18/19 15:31
Test Method	*see below				04/18/19 15:31

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080039
LRN : 0000279444
Auxiliary ID : Sample #117
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 6 left sink #1

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.3			ug Pb/L	04/18/19 15:31
Test Method	*see below				04/18/19 15:31

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080040
LRN : 0000279444
Auxiliary ID : Sample #118
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 6 left sink #1
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/18/19 15:32
Test Method	*see below				04/18/19 15:32

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080042
LRN : 0000279444
Auxiliary ID : Sample #119
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 6 left sink #2

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*18.0			ug Pb/L	04/18/19 15:32
Test Method	*see below				04/18/19 15:32

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080043
LRN : 0000279444
Auxiliary ID : Sample #120
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab station 6 left sink #2
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/18/19 15:32
Test Method	*see below				04/18/19 15:32

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080045
LRN : 0000279444
Auxiliary ID : Sample #121
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab eye wash

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*17.0			ug Pb/L	04/22/19 14:18
Test Method	*see below				04/22/19 14:18

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080046
LRN : 0000279444
Auxiliary ID : Sample #122
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab eye wash 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*18.0			ug Pb/L	04/22/19 14:18
Test Method	*see below				04/22/19 14:18

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080047
LRN : 0000279444
Auxiliary ID : Sample #123
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab instructor sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.8			ug Pb/L	04/22/19 14:18
Test Method	*see below				04/22/19 14:18

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080048
LRN : 0000279444
Auxiliary ID : Sample #124
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Science lab instructor sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 14:19
Test Method	*see below				04/22/19 14:19

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080049
LRN : 0000279444
Auxiliary ID : Sample #125
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Bubbler next to science lab tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 14:19
Test Method	*see below				04/22/19 14:19

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080050
LRN : 0000279444
Auxiliary ID : Sample #126
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Bubbler next to science lab tall
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/22/19 14:19
Test Method	*see below				04/22/19 14:19

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080051
LRN : 0000279444
Auxiliary ID : Sample #127
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Bubbler next to science lab short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 14:19
Test Method	*see below				04/22/19 14:19

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080052
LRN : 0000279444
Auxiliary ID : Sample #128
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Bubbler next to science lab short
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 14:19
Test Method	*see below				04/22/19 14:19

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080105
LRN : 0000279444
Auxiliary ID : Sample #129
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Men's room step sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 14:19
Test Method	*see below				04/22/19 14:19

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080106
LRN : 0000279444
Auxiliary ID : Sample #130
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Men's room step sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 14:21
Test Method	*see below				04/22/19 14:21

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080107
LRN : 0000279444
Auxiliary ID : Sample #131
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Women's room step sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*1.2			ug Pb/L	04/22/19 16:25
Test Method	*see below				04/22/19 16:25

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/22/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080108
LRN : 0000279444
Auxiliary ID : Sample #132
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Women's room step sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 16:26
Test Method	*see below				04/22/19 16:26

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080109
LRN : 0000279444
Auxiliary ID : Sample #133
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
3rd floor mop sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 16:17
Test Method	*see below				04/22/19 16:17

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080111
LRN : 0000279444
Auxiliary ID : Sample #134
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
3rd floor mop sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 16:17
Test Method	*see below				04/22/19 16:17

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080114
LRN : 0000279444
Auxiliary ID : Sample #135
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 304 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*3.2			ug Pb/L	04/22/19 16:17
Test Method	*see below				04/22/19 16:17

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080116
LRN : 0000279444
Auxiliary ID : Sample #136
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 304 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 16:18
Test Method	*see below				04/22/19 16:18

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080117
LRN : 0000279444
Auxiliary ID : Sample #137
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 304 bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/22/19 16:18
Test Method	*see below				04/22/19 16:18

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/22/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080118
LRN : 0000279444
Auxiliary ID : Sample #138
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 304 bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 16:18
Test Method	*see below				04/22/19 16:18

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080119
LRN : 0000279444
Auxiliary ID : Sample #139
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 303 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 16:18
Test Method	*see below				04/22/19 16:18

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080122
LRN : 0000279444
Auxiliary ID : Sample #140
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm303 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/22/19 16:18
Test Method	*see below				04/22/19 16:18

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080123
LRN : 0000279444
Auxiliary ID : Sample #141
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 305 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 16:18
Test Method	*see below				04/22/19 16:18

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080124
LRN : 0000279444
Auxiliary ID : Sample #142
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 305 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/22/19 16:18
Test Method	*see below				04/22/19 16:18

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080125
LRN : 0000279444
Auxiliary ID : Sample #143
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 305 bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/22/19 16:18
Test Method	*see below				04/22/19 16:18

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080126
LRN : 0000279444
Auxiliary ID : Sample #144
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 305 bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 16:18
Test Method	*see below				04/22/19 16:18

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080127
LRN : 0000279444
Auxiliary ID : Sample #145
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 306 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*1.7			ug Pb/L	04/22/19 16:19
Test Method	*see below				04/22/19 16:19

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080128
LRN : 0000279444
Auxiliary ID : Sample #146
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 306 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 16:19
Test Method	*see below				04/22/19 16:19

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080129
LRN : 0000279444
Auxiliary ID : Sample #147
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 306 bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 16:22
Test Method	*see below				04/22/19 16:22

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0080130
LRN : 0000279444
Auxiliary ID : Sample #148
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 306 bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 16:22
Test Method	*see below				04/22/19 16:22

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0090115
LRN : 0000279444
Auxiliary ID : Sample #149
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 309 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*2.9			ug Pb/L	04/22/19 16:30
Test Method	*see below				04/22/19 16:30

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0090116
LRN : 0000279444
Auxiliary ID : Sample #150
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 309 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/22/19 16:31
Test Method	*see below				04/22/19 16:31

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/22/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0090117
LRN : 0000279444
Auxiliary ID : Sample #151
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 309 bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/24/19 15:42
Test Method	*see below				04/24/19 15:42

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0090118
LRN : 0000279444
Auxiliary ID : Sample #152
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 309 bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/24/19 15:42
Test Method	*see below				04/24/19 15:42

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0090119
LRN : 0000279444
Auxiliary ID : Sample #153
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 311 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/24/19 15:42
Test Method	*see below				04/24/19 15:42

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0090120
LRN : 0000279444
Auxiliary ID : Sample #154
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 311 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/24/19 15:42
Test Method	*see below				04/24/19 15:42

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0090123
LRN : 0000279444
Auxiliary ID : Sample #155
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 311 bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/24/19 15:42
Test Method	*see below				04/24/19 15:42

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0090124
LRN : 0000279444
Auxiliary ID : Sample #156
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 311 bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/24/19 15:42
Test Method	*see below				04/24/19 15:42

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0090125
LRN : 0000279444
Auxiliary ID : Sample #157
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 310 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.2			ug Pb/L	04/24/19 15:42
Test Method	*see below				04/24/19 15:42

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/24/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0090126
LRN : 0000279444
Auxiliary ID : Sample #158
Date Collected: 03/23/19
Date Received : 03/27/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Central City Cyberschool Main Building
Rm 310 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/24/19 15:43
Test Method	*see below				04/24/19 15:43

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0250082
LRN : 0000279444
Auxiliary ID : Sample #1
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Laundry room slop sink (long run)

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*2.9			ug Pb/L	04/30/19 14:30
Test Method	*see below				04/30/19 14:30

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0250083
LRN : 0000279444
Auxiliary ID : Sample #2
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Laundry room slop sink (long run)
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/30/19 14:33
Test Method	*see below				04/30/19 14:33

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0250084
LRN : 0000279444
Auxiliary ID : Sample #3
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Laundry room middle sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/30/19 14:33
Test Method	*see below				04/30/19 14:33

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0250085
LRN : 0000279444
Auxiliary ID : Sample #4
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Laundry room middle sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/30/19 14:33
Test Method	*see below				04/30/19 14:33

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0260108
LRN : 0000279444
Auxiliary ID : Sample #5
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Kitchen middle sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*13.0			ug Pb/L	04/30/19 14:33
Test Method	*see below				04/30/19 14:33

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0260109
LRN : 0000279444
Auxiliary ID : Sample #6
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Kitchen middle sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*3.6			ug Pb/L	04/30/19 14:33
Test Method	*see below				04/30/19 14:33

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0260110
LRN : 0000279444
Auxiliary ID : Sample #7
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Kitchen wall sink- 45th street

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*44.0			ug Pb/L	04/30/19 14:33
Test Method	*see below				04/30/19 14:33

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0260111
LRN : 0000279444
Auxiliary ID : Sample #8
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: **CP/N/44THST, 4301**

DOB:

Age:

Sex:

Ord. Comm: Central City Cyberschool Preschool Building
Kitchen wall sink- 45th street
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*5.1			ug Pb/L	04/30/19 14:33
Test Method	*see below				04/30/19 14:33

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0260112
LRN : 0000279444
Auxiliary ID : Sample #9
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Kitchen sink east

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*13.0			ug Pb/L	04/30/19 14:34
Test Method	*see below				04/30/19 14:34

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0260113
LRN : 0000279444
Auxiliary ID : Sample #10
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Kitchen sink east 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.2			ug Pb/L	04/30/19 14:34
Test Method	*see below				04/30/19 14:34

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0260114
LRN : 0000279444
Auxiliary ID : Sample #11
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Room 423 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*4.7			ug Pb/L	04/30/19 14:34
Test Method	*see below				04/30/19 14:34

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0260115
LRN : 0000279444
Auxiliary ID : Sample #12
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Room 423 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/30/19 14:34
Test Method	*see below				04/30/19 14:34

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300115
LRN : 0000279444
Auxiliary ID : Sample #13
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Room 423 bathroom East

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*170.0			ug Pb/L	04/30/19 14:34
Test Method	*see below				04/30/19 14:34

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300116
LRN : 0000279444
Auxiliary ID : Sample #14
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Room 423 bathroom east 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.9			ug Pb/L	04/30/19 14:34
Test Method	*see below				04/30/19 14:34

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300117
LRN : 0000279444
Auxiliary ID : Sample #15
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Room 423 bathroom west

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.0			ug Pb/L	04/30/19 14:35
Test Method	*see below				04/30/19 14:35

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300118
LRN : 0000279444
Auxiliary ID : Sample #16
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Room 423 bathroom west 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/30/19 14:35
Test Method	*see below				04/30/19 14:35

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300119
LRN : 0000279444
Auxiliary ID : Sample #17
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
--	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Room 424 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*4.0			ug Pb/L	04/30/19 14:35
Test Method	*see below				04/30/19 14:35

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300120
LRN : 0000279444
Auxiliary ID : Sample #18
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Room 424 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/30/19 14:35
Test Method	*see below				04/30/19 14:35

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300121
LRN : 0000279444
Auxiliary ID : Sample #19
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Room 424 bathroom east

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*4.4			ug Pb/L	04/30/19 14:35
Test Method	*see below				04/30/19 14:35

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300122
LRN : 0000279444
Auxiliary ID : Sample #20
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Room 424 bathroom east 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/30/19 14:35
Test Method	*see below				04/30/19 14:35

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300123
LRN : 0000279444
Auxiliary ID : Sample #21
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Room 424 bathroom west

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*5.2			ug Pb/L	04/30/19 14:36
Test Method	*see below				04/30/19 14:36

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300124
LRN : 0000279444
Auxiliary ID : Sample #22
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Room 424 bathroom west 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/30/19 14:36
Test Method	*see below				04/30/19 14:36

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/30/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300125
LRN : 0000279444
Auxiliary ID : Sample #23
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Staff room bathroom

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/30/19 14:36
Test Method	*see below				04/30/19 14:36

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300127
LRN : 0000279444
Auxiliary ID : Sample #24
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Staff room bathroom 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.1			ug Pb/L	04/30/19 14:36
Test Method	*see below				04/30/19 14:36

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300128
LRN : 0000279444
Auxiliary ID : Sample #25
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Staff room sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*10.0			ug Pb/L	04/30/19 14:36
Test Method	*see below				04/30/19 14:36

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/30/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300129
LRN : 0000279444
Auxiliary ID : Sample #26
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Staff room sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/30/19 14:36
Test Method	*see below				04/30/19 14:36

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300130
LRN : 0000279444
Auxiliary ID : Sample #27
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/30/19 14:36
Test Method	*see below				04/30/19 14:36

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/30/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300131
LRN : 0000279444
Auxiliary ID : Sample #28
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Bubbler 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/30/19 14:37
Test Method	*see below				04/30/19 14:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300133
LRN : 0000279444
Auxiliary ID : Sample #29
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Men's room sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/30/19 14:37
Test Method	*see below				04/30/19 14:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300134
LRN : 0000279444
Auxiliary ID : Sample #30
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Men's room sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
Lead in Water					
Sample	*<1.0			ug Pb/L	04/30/19 14:37
Test Method	*see below				04/30/19 14:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300136
LRN : 0000279444
Auxiliary ID : Sample #31
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Women's room sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*1.0			ug Pb/L	04/30/19 14:37
Test Method	*see below				04/30/19 14:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

Printed: 04/30/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300142
LRN : 0000279444
Auxiliary ID : Sample #32
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Women's room sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/30/19 14:37
Test Method	*see below				04/30/19 14:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300144
LRN : 0000279444
Auxiliary ID : Sample #33
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Hall staff kitchen sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/30/19 14:37
Test Method	*see below				04/30/19 14:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director

City of Milwaukee-Public Health Laboratories
841 North Broadway, Room 205 Milwaukee, WI 53202-3653
Phone Number: (414)286-3526 Fax Number: (414)286-5098
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION
841 N. BROADWAY
THIRD FLOOR
MILWAUKEE, WI 53202

Order ID : S0300145
LRN : 0000279444
Auxiliary ID : Sample #34
Date Collected: 04/10/19
Date Received : 04/15/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/44THST, 4301	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Central City Cyberschool Preschool Building
Hall staff kitchen sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.1			ug Pb/L	04/30/19 14:37
Test Method	*see below				04/30/19 14:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme
Sanjib Bhattacharyya, Ph.D.
Laboratory Director