



# City of Milwaukee

## Health Department

Tom Barrett  
Mayor

Jeanette Kowalik, PhD, MPH, MCHES  
Commissioner of Health

[www.milwaukee.gov/health](http://www.milwaukee.gov/health)

Frank P. Zeidler Municipal Building, 841 North Broadway, 3rd Floor, Milwaukee, WI 53202-3653

phone (414) 286-3521

fax (414) 286-5990

September 27<sup>th</sup>, 2019

Darrell Lynn Hines Academy  
7151 North 86<sup>th</sup> Street  
Milwaukee, WI 53224

The City of Milwaukee Health Department (MHD) conducted water sampling as stated in Common Council Resolution File Number 171520. The collected water samples were analyzed for lead to determine if there were any detected lead levels in the water outlets. All sampling procedures were done according to the United States Environmental Protection Agency (EPA) *3Ts for Reducing Lead in Drinking Water in Schools Guidance* (3Ts).

### Sampling and Testing

The collection of the samples took place on the morning of April 09, 2019. A total of 37 water outlets were sampled in the school. After the water was stagnant for a minimum of 8 hours, 250 milliliter (mL) water samples were collected before the water was used in the building. At each outlet two 250mL samples were taken; the second sample was taken after a 30 second flush. Each sample was labeled with the location, date, and time sampled. After finishing the sample collection, the samples were submitted to the City of Milwaukee Health Department Laboratory, a certified drinking water laboratory (ID: 241311290) with the Wisconsin Department of Natural Resources, for lead analysis.

### Results

Please see the attached Water Sample Results Table for a summary of the water sample results. **Six** samples had detectable levels of lead ranging from 1.0 µg/L (micrograms per liter) to 4.9 µg/L. However, **one** other remaining sample had detectable levels of lead greater than 5.0 µg/L. The rest of the outlets had lead levels below 1.0 µg/L.

There is no safe level of lead in water. MHD provides recommendations for each outlet on the attached Water Sample Results Table. Any water outlet designed specifically for drinking (e.g. bubbler, water fountain, etc.) that has detectable levels of lead should be taken out of service, install a certified drinking water filter for lead removal, or provide bottled water from a lead-free source. Any water outlet that is not designed specifically for drinking (e.g., sink, washbasin, etc.) that has detectable levels of lead should be considered for placarding if the lead level is less than 5.0 µg/L, and must be placarded (or, alternatively, filtered or removed from service) for levels higher than 5.0 µg/L. Any remediation activities or additional water samples that may need to be completed will be done at the cost of the school and/or the property owner.

The only way to determine if a child has been lead poisoned is to have their blood tested. Parents/Guardians can have their child tested at their primary care physician. MHD recommends that a child be tested for lead three times before the age of three. If children weren't tested before the age of three, MHD recommends testing children up to the age of six. For older children, parents should talk to their medical provider about their child's exposure risk.

Please share these results with Parents/Guardians, staff, and students. As stated in the 3Ts, Parents/Guardians, staff, and students should be notified of the water testing and the testing results. If there are any questions regarding lead poisoning, please contact the MHD Childhood Lead Poisoning Prevention Program at 414-286-2165 or go to [www.lead-safe-MKE.com](http://www.lead-safe-MKE.com). If there are any questions or concerns about your results or remediation options, please call me at (414) 286-3451.

Sincerely,

Ofelia R. Mondragon, BBM

Home Environment Health Manager

Encl: Water Sample Results Table, Lead in Drinking Water Chain of Custody and Requisition Forms, and MHD Laboratory Results



Darrell Lynn Hines Academy 7151 North 86th Street		Lead Results (µg/L)				MHD Recommendations as of 4/30/2019
Sample Tap Number	Sample Description	~5/27/2017	9/20/2018	4/9/2019	4/9/2019 30 sec Flush	
1	Entrance Office Women's Bathroom North	0.10	<1.0	<1.0	<1.0	No Action
2	Entrance Office Women's Bathroom South	0.14	<1.0	<1.0	<1.0	No Action
3	Entrance Office Men's Bathroom North	0.12	<1.0	<1.0	<1.0	No Action
4	Entrance Office Men's Bathroom South	0.12	<1.0	<1.0	<1.0	No Action
5	Entrance Office Bubbler Tall	0.09	<1.0	<1.0	<1.0	No Action
6	Entrance Office Bubbler Short	0.09	<1.0	<1.0	<1.0	No Action
7	Gym Northeast Corner Bubbler Tall	0.08	<1.0	<1.0	<1.0	No Action
8	Gym Northeast Corner Bubbler Short	0.09	<1.0	<1.0	<1.0	No Action
9	Gym Men's Locker Room Shower Sink	0.25	<1.0	<1.0	<1.0	No Action
10	Gym Men's Locker Room Sink	0.11	<1.0	<1.0	<1.0	No Action
11	Gym Women's Locker Room Sink	0.15	<1.0	<1.0	<1.0	No Action
12	Gym Women's Locker Room Shower Sink	0.12	<1.0	<1.0	<1.0	No Action
13	Conference Room 122 Sink	0.25	<1.0	<1.0	<1.0	No Action
14	Classroom 130 Sink	0.34	<1.0	<1.0	<1.0	No Action
15	Classroom 131 Sink	0.52	<1.0	<1.0	<1.0	No Action
16	Classroom 132 Sink	0.53	<1.0	1.2	<1.0	Consider Placard
17	Restroom 133 Sink West	0.08	<1.0	<1.0	<1.0	No Action
18	Restroom 133 Sink East	0.12	<1.0	<1.0	<1.0	No Action
19	Room 135 Bubbler Tall	0.08	<1.0	<1.0	<1.0	No Action
20	Room 135 Bubbler Short	0.07	<1.0	<1.0	<1.0	No Action
21	Classroom 136 Sink	0.30	<1.0	1.0	<1.0	Consider Placard
22	Classroom 138 Sink	0.11	<1.0	<1.0	<1.0	No Action
23	Classroom 140 Sink	11	22.0	1.9	<1.0	Consider Placard
24	Classroom 88 Sink	0.22	<1.0	<1.0	<1.0	No Action
25	Classroom 86 Sink	0.15	<1.0	<1.0	<1.0	No Action
26	Classroom 84 Sink	0.12	<1.0	<1.0	<1.0	No Action
27	Classroom 82 Sink	0.1	<1.0	<1.0	<1.0	No Action
28	Women's Bathroom 83 Sink West	0.15	<1.0	<1.0	<1.0	No Action
29	Women's Bathroom 83 Sink East	0.10	<1.0	<1.0	<1.0	No Action
30	Men's Bathroom 81 Sink West	0.20	<1.0	<1.0	<1.0	No Action
31	Men's Bathroom 81 Sink East	0.2	--	<1.0	<1.0	No Action
32	81-79 Bubbler Next To Elevator	0.09	<1.0	<1.0	<1.0	No Action
33	Science Lab Sink	0.19	1.7	<1.0	<1.0	No Action
34	East Kitchen Cafeteria Wash Sink	0.70	<1.0	2.80	<1.0	Consider Placard
35	Long Run Tap in Meter Room	--	--	--	--	Re-test before Back In Service
36	West Kitchen Cafeteria Wash Sink West	3.2	2.6	3.0	<1.0	Consider Placard
37	West Kitchen Cafeteria Wash Sink Middle	1.6	2.5	3.4	<1.0	Consider Placard
38	West Kitchen Cafeteria Wash Sink East	1.6	2.2	15	<1.0	Placard

Results indicated in **red** exceed the 5 parts per billion (ppb) standard established by the City of Milwaukee Common Council in Resolution File Number 171520

The 2019 samples were collected by the City of Milwaukee Health Department and analyzed by the City of Milwaukee Health Department Laboratory

Definitions:

1 µg/L = 1 ppb

~ Samples collected by Milwaukee Water Works (MWW) and analyzed by Eurofins. MWW utilized 15 ppb as the lead in drinking water standard.

Results indicated in **blue** exceed this standard.

--: No Sample Taken. Outlet Out of Service

\* Outlet was not found. No Sample Taken.

# Outlet replaced by the school.

Placard: City of Milwaukee May Contain Lead Not Safe For Drinking Sign

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180006  
LRN : 0000279409  
Auxiliary ID : Sample #1  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

---

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

---

Ord. Comm: Darrell Lynn Hines Academy  
Entrance office women's bathroom right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/24/19 15:43
Test Method	*see below				04/24/19 15:43

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

---

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180007  
LRN : 0000279409  
Auxiliary ID : Sample #2  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Entrance office women's bathroom right  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/24/19 15:43
Test Method	*see below				04/24/19 15:43

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180008  
LRN : 0000279409  
Auxiliary ID : Sample #3  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Entrance office women's bathroom left

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/24/19 15:43
Test Method	*see below				04/24/19 15:43

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180009  
LRN : 0000279409  
Auxiliary ID : Sample #4  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Entrance office women's bathroom left  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/24/19 15:43
Test Method	*see below				04/24/19 15:43

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180010  
LRN : 0000279409  
Auxiliary ID : Sample #5  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Entrance office men's bathroom right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/24/19 15:43
Test Method	*see below				04/24/19 15:43

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180011  
LRN : 0000279409  
Auxiliary ID : Sample #6  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Entrance office men's bathroom right  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/24/19 15:44
Test Method	*see below				04/24/19 15:44

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180012  
LRN : 0000279409  
Auxiliary ID : Sample #7  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Entrance office men's bathroom left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/24/19 15:44
Test Method	*see below				04/24/19 15:44

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/24/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180013  
LRN : 0000279409  
Auxiliary ID : Sample #8  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Entrance office men's bathroom left  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/24/19 15:44
Test Method	*see below				04/24/19 15:44

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180014  
LRN : 0000279409  
Auxiliary ID : Sample #9  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Entrance Office Bubbler Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/24/19 15:44
Test Method	*see below				04/24/19 15:44

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180015  
LRN : 0000279409  
Auxiliary ID : Sample #10  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Entrance Office Bubbler Tall  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/24/19 15:44
Test Method	*see below				04/24/19 15:44

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180016  
LRN : 0000279409  
Auxiliary ID : Sample #11  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Entrance Office Bubbler Short

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/24/19 15:44
Test Method	*see below				04/24/19 15:44

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180017  
LRN : 0000279409  
Auxiliary ID : Sample #12  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

---

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

---

Ord. Comm: Darrell Lynn Hines Academy  
Entrance Office Bubbler  
Short 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/24/19 15:44
Test Method	*see below				04/24/19 15:44

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

---

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180018  
LRN : 0000279409  
Auxiliary ID : Sample #13  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Gym Northeast Corner  
Bubbler Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/24/19 15:45
Test Method	*see below				04/24/19 15:45

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180019  
LRN : 0000279409  
Auxiliary ID : Sample #14  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

---

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

---

Ord. Comm: Darrell Lynn Hines Academy  
Gym Northeast Corner  
Bubbler Tall  
30 sec flush

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/24/19 15:45
Test Method	*see below				04/24/19 15:45

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

---

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/24/2019 16:56

PAGE: 1 of 1



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180020  
LRN : 0000279409  
Auxiliary ID : Sample #15  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Gym Northeast Corner  
Bubbler Short

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/24/19 15:45
Test Method	*see below				04/24/19 15:45

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180021  
LRN : 0000279409  
Auxiliary ID : Sample #16  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Gym Northeast Corner  
Bubbler Short  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/24/19 15:45
Test Method	*see below				04/24/19 15:45

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180022  
LRN : 0000279409  
Auxiliary ID : Sample #17  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Gym Men's Locker Room  
Shower Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/24/19 15:45
Test Method	*see below				04/24/19 15:45

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180023  
LRN : 0000279409  
Auxiliary ID : Sample #18  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Gym Men's Locker Room  
Shower Sink 30 sec flush

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/24/19 15:45
Test Method	*see below				04/24/19 15:45

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180024  
LRN : 0000279409  
Auxiliary ID : Sample #19  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Gym Men's Locker Room  
Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/24/19 15:45
Test Method	*see below				04/24/19 15:45

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180025  
LRN : 0000279409  
Auxiliary ID : Sample #20  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Gym Men's Locker Room  
Sink 30 sec flush

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/24/19 15:45
Test Method	*see below				04/24/19 15:45

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/24/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180026  
LRN : 0000279409  
Auxiliary ID : Sample #21  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Gym Women's Locker Room  
Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/26/19 13:37
Test Method	*see below				04/26/19 13:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180027  
LRN : 0000279409  
Auxiliary ID : Sample #22  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Gym Women's Locker Room  
Sink 30 sec flush

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/26/19 13:37
Test Method	*see below				04/26/19 13:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180028  
LRN : 0000279409  
Auxiliary ID : Sample #23  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

---

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

---

Ord. Comm: Darrell Lynn Hines Academy  
Gym Women's Locker Room  
Shower Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/26/19 13:37
Test Method	*see below				04/26/19 13:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

---

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180029  
LRN : 0000279409  
Auxiliary ID : Sample #24  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Gym Women's Locker Room  
Shower Sink 30 sec flush

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

**Lead in Water**

Sample	*<1.0			ug Pb/L	04/26/19 13:37
Test Method	*see below				04/26/19 13:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180030  
LRN : 0000279409  
Auxiliary ID : Sample #25  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Conference Room 122 Sink

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

**Lead in Water**

Sample	*<1.0			ug Pb/L	04/26/19 13:37
Test Method	*see below				04/26/19 13:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180031  
LRN : 0000279409  
Auxiliary ID : Sample #26  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
CXonference Room 122 Sink  
30 sec flush

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

**Lead in Water**

Sample	*<1.0			ug Pb/L	04/26/19 13:37
Test Method	*see below				04/26/19 13:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180032  
LRN : 0000279409  
Auxiliary ID : Sample #27  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 130 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/26/19 13:37
Test Method	*see below				04/26/19 13:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180033  
LRN : 0000279409  
Auxiliary ID : Sample #28  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 130 Sink  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/26/19 13:37
Test Method	*see below				04/26/19 13:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180049  
LRN : 0000279409  
Auxiliary ID : Sample #29  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 131 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/26/19 13:37
Test Method	*see below				04/26/19 13:37

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180050  
LRN : 0000279409  
Auxiliary ID : Sample #30  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 131 Sink  
30 sec flush

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/26/19 13:38
Test Method	*see below				04/26/19 13:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/26/2019 16:56

PAGE: 1 of 1



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180051  
LRN : 0000279409  
Auxiliary ID : Sample #31  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

---

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

---

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 132 Sink

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.2			ug Pb/L	04/26/19 13:38
Test Method	*see below				04/26/19 13:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

---

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180054  
LRN : 0000279409  
Auxiliary ID : Sample #32  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 132 Sink  
30 sec flush

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/26/19 13:38
Test Method	*see below				04/26/19 13:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180056  
LRN : 0000279409  
Auxiliary ID : Sample #33  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Restroom 133 Sink Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/26/19 13:38
Test Method	*see below				04/26/19 13:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180057  
LRN : 0000279409  
Auxiliary ID : Sample #34  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

---

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

---

Ord. Comm: Darrell Lynn Hines Academy  
Restroom 133 Sink Right  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/26/19 13:38
Test Method	*see below				04/26/19 13:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

---

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180058  
LRN : 0000279409  
Auxiliary ID : Sample #35  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

---

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

---

Ord. Comm: Darrell Lynn Hines Academy  
Restroom ~~144~~ Sink Left

133  
R 4/29/19

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/26/19 13:38
Test Method	*see below				04/26/19 13:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

---

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180059  
LRN : 0000279409  
Auxiliary ID : Sample #36  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Restroom 133 Sink Left  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/26/19 13:38
Test Method	*see below				04/26/19 13:38

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180064  
LRN : 0000279409  
Auxiliary ID : Sample #37  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Room 135 Bubbler Tall

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/26/19 13:40
Test Method	*see below				04/26/19 13:40

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180065  
LRN : 0000279409  
Auxiliary ID : Sample #38  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Room 135 Bubbler Tall  
30 sec flush

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/26/19 13:41
Test Method	*see below				04/26/19 13:41

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/26/2019 16:56

PAGE: 1 of 1



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180067  
LRN : 0000279409  
Auxiliary ID : Sample #39  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Room 135 Bubbler Short

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

**Lead in Water**

Sample	*<1.0			ug Pb/L	04/26/19 13:42
Test Method	*see below				04/26/19 13:42

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/26/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180068  
LRN : 0000279409  
Auxiliary ID : Sample #40  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Room 135 Bubbler Short  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/26/19 13:42
Test Method	*see below				04/26/19 13:42

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180060  
LRN : 0000279409  
Auxiliary ID : Sample #41  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 136 Sink

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*1.0			ug Pb/L	04/26/19 13:39
Test Method	*see below				04/26/19 13:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/26/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180061  
LRN : 0000279409  
Auxiliary ID : Sample #42  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 136 Sink  
30 sec flush

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/26/19 13:39
Test Method	*see below				04/26/19 13:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/26/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180062  
LRN : 0000279409  
Auxiliary ID : Sample #43  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 138 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/26/19 13:39
Test Method	*see below				04/26/19 13:39

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180063  
LRN : 0000279409  
Auxiliary ID : Sample #44  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 138 Sink  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/26/19 13:40
Test Method	*see below				04/26/19 13:40

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180081  
LRN : 0000279409  
Auxiliary ID : Sample #45  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 140 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*1.9			ug Pb/L	04/26/19 13:42
Test Method	*see below				04/26/19 13:42

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/26/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180082  
LRN : 0000279409  
Auxiliary ID : Sample #46  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 140 Sink  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/29/19 14:04
Test Method	*see below				04/29/19 14:04

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/29/2019 16:56

PAGE: 1 of 1



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180084  
LRN : 0000279409  
Auxiliary ID : Sample @47  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 88 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/29/19 14:04
Test Method	*see below				04/29/19 14:04

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180085  
LRN : 0000279409  
Auxiliary ID : Sample #48  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 88 Sink  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/29/19 14:04
Test Method	*see below				04/29/19 14:04

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180086  
LRN : 0000279409  
Auxiliary ID : Sample #49  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 86 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/29/19 14:04
Test Method	*see below				04/29/19 14:04

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/29/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180089  
LRN : 0000279409  
Auxiliary ID : Sample #50  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 86 Sink  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/29/19 14:05
Test Method	*see below				04/29/19 14:05

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/29/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180090  
LRN : 0000279409  
Auxiliary ID : Sample #51  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 84 Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/29/19 14:05
Test Method	*see below				04/29/19 14:05

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180092  
LRN : 0000279409  
Auxiliary ID : Sample #52  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 84 Sink  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/29/19 14:05
Test Method	*see below				04/29/19 14:05

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180105  
LRN : 0000279409  
Auxiliary ID : Sample #53  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 82 sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/29/19 14:05
Test Method	*see below				04/29/19 14:05

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180106  
LRN : 0000279409  
Auxiliary ID : Sample #54  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Classroom 82 sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/29/19 14:05
Test Method	*see below				04/29/19 14:05

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/29/2019 16:56

PAGE: 1 of 1



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180107  
LRN : 0000279409  
Auxiliary ID : Sample #55  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Women's bathroom 83 sink right

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/29/19 14:05
Test Method	*see below				04/29/19 14:05

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180108  
LRN : 0000279409  
Auxiliary ID : Sample #56  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Women's bathroom 83 sink right  
30 sec flush

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

**Lead in Water**

Sample	*<1.0			ug Pb/L	04/29/19 14:05
Test Method	*see below				04/29/19 14:05

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180109  
LRN : 0000279409  
Auxiliary ID : Sample #57  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Women's bathroom 83 sink left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/29/19 14:05
Test Method	*see below				04/29/19 14:05

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180110  
LRN : 0000279409  
Auxiliary ID : Sample #58  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Women's bathroom 83 sink left  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/29/19 14:05
Test Method	*see below				04/29/19 14:05

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/29/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180111  
LRN : 0000279409  
Auxiliary ID : Sample #59  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Men's bathroom 81 sink right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/29/19 14:05
Test Method	*see below				04/29/19 14:05

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/29/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180112  
LRN : 0000279409  
Auxiliary ID : Sample #60  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Men's bathroom 81 sink right  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	04/29/19 14:06
Test Method	*see below				04/29/19 14:06

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/29/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180113  
LRN : 0000279409  
Auxiliary ID : Sample #61  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Men's bathroom 81 sink left

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/29/19 14:06
Test Method	*see below				04/29/19 14:06

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180114  
LRN : 0000279409  
Auxiliary ID : Sample #62  
Date Collected: 04/09/19  
Date Received : 04/18/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Men's bathroom 81 sink left  
30 sec flush

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

**Lead in Water**

Sample	*<1.0			ug Pb/L	04/29/19 14:06
Test Method	*see below				04/29/19 14:06

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/29/2019 16:56

PAGE: 1 of 1



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180115  
LRN : 0000279409  
Auxiliary ID : Sample #63  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
81-79 bubbler next to elevator

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/29/19 14:06
Test Method	*see below				04/29/19 14:06

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180116  
LRN : 0000279409  
Auxiliary ID : Sample #64  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
81-79 bubbler next to elevator  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/29/19 14:06
Test Method	*see below				04/29/19 14:06

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180117  
LRN : 0000279409  
Auxiliary ID : Sample #65  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Science lab sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/29/19 14:06
Test Method	*see below				04/29/19 14:06

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180118  
LRN : 0000279409  
Auxiliary ID : Sample #66  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
Science lab sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/29/19 14:06
Test Method	*see below				04/29/19 14:06

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180121  
LRN : 0000279409  
Auxiliary ID : Sample #67  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
East kitchen cafeteria wash sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*2.8			ug Pb/L	04/29/19 14:06
Test Method	*see below				04/29/19 14:06

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180123  
LRN : 0000279409  
Auxiliary ID : SAMPLE #68  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
East kitchen cafeteria wash sink  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	04/29/19 14:07
Test Method	*see below				04/29/19 14:07

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180126  
LRN : 0000279409  
Auxiliary ID : Sample #69  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
West kitchen cafeteria wash sink right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*3.0			ug Pb/L	04/29/19 14:07
Test Method	*see below				04/29/19 14:07

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180127  
LRN : 0000279409  
Auxiliary ID : Sample #70  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
West kitchen cafeteria wash sink right  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/29/19 14:07
Test Method	*see below				04/29/19 14:07

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180128  
LRN : 0000279409  
Auxiliary ID : Sample #71  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
West kitchen cafeteria wash sink middle

**C h e m i s t r y**

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*3.4			ug Pb/L	04/29/19 14:07
Test Method	*see below				04/29/19 14:07

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/29/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180129  
LRN : 0000279409  
Auxiliary ID : Sample #72  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
West kitchen cafeteria wash sink middle  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	04/29/19 14:07
Test Method	*see below				04/29/19 14:07

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 04/29/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180130  
LRN : 0000279409  
Auxiliary ID : Sample #73  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

Ord. Comm: Darrell Lynn Hines Academy  
West kitchen cafeteria wash sink left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*15.0			ug Pb/L	04/29/19 14:07
Test Method	*see below				04/29/19 14:07

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
**FINAL REPORT**

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S0180131  
LRN : 0000279409  
Auxiliary ID : Sample #74  
Date Collected: 04/09/19  
Date Received : 04/12/19

Requested by: SCHULTZ, JEAN

**FINAL**

---

Patient Name: CP/N/86THST, 7151	DOB:	Age:	Sex:
---------------------------------	------	------	------

---

**Ord. Comm:** Darrell Lynn Hines Academy  
West kitchen cafeteria wash sink left  
30 sec flush

**C h e m i s t r y**

---

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

---

**Lead in Water**

Sample	*<1.0			ug Pb/L	04/29/19 14:07
Test Method	*see below				04/29/19 14:07

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

---

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director