

Downtown Montessori Academy 2507 South Graham Street		Lead Results (µg/L)		Lead Results (µg/L)		MHD Recommendations as of 6/14/2019
Sample Number	Sample Description	~5/11/2017	9/28/2018	6/14/2019	6/14/2019 30 sec flush	
1	Room 2 Hallway Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
2	2nd Floor Room 9 Tap	17	5.5	5.0	<1.0	Placard
3	2nd Floor Room 9 Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
4	1st Floor Boys Room Sink Right	1.2	<1.0	<1.0	1.7	Consider Placard
5	1st Floor Boys Room Sink Middle Right	1.2	<1.0	1.3	<1.0	Consider Placard
6	1st Floor Boys Bathroom Middle Left	1.8	<1.0	<1.0	<1.0	No Action
7	1st Floor Boys Bathroom Left	1.8	<1.0	<1.0	<1.0	No Action
8	Hallway Wall Sink Left	1.1	<1.0	<1.0	<1.0	No Action
9	Hallway Wall Sink Middle	<1.0	<1.0	<1.0	2.0	Consider Placard
10	Hallway Sink Right	<1.0	<1.0	<1.0	1.5	Consider Placard
11	Room 4 Hallway Bubbler	<1.0	<1.0	<1.0	<1.0	No Action
12	Staff Kitchen Tap	<1.0	<1.0	1.5	<1.0	Consider Placard
13	Staff Bathroom	1.1	<1.0	<1.0	1.1	Consider Placard
14	1st Floor Girls Hallway Tap	<1.0	<1.0	<1.0	<1.0	No Action
15	1st Floor Girls Hallway Bubbler	1.2	<1.0	1.1	1.9	Consider Placard
16	1st Floor Girls Room Sink Right	4.4	<1.0	3.1	1.4	Consider Placard
17	1st Floor Girls Room Sink Middle Right	4.6	<1.0	2.0	1.7	Consider Placard
18	1st Floor Girls Room Sink Middle Left	4.6	<1.0	1.7	1.7	Consider Placard
19	1st Floor Girls Room Sink Left	4.5	<1.0	1.9	1.6	Consider Placard
20	2nd Floor Porcelain Bubbler	1.1	--	--	--	Re-test Before Back in Service
21	Basement Art Sink	<1.0	--	<1.0	<1.0	No Action
22	Room 1 Tap	--	<1.0	3.7	4.9	Consider Placard
23	Room 5 Tap	--	<1.0	1.7	<1.0	Consider Placard
24	Room 4 Tap	--	<1.0	<1.0	1.3	Consider Placard
25	Room 3 Tap	--	<1.0	<1.0	5.2	Placard
26	Room 2 Tap	--	<1.0	4.0	9.1	Placard
27	Basement Staff Bathroom	--	<1.0	1.1	<1.0	Consider Placard
28	Kitchen Tap	<1.0	<1.0	<1.0	<1.0	No Action
29	Filtered Kitchen Tap	<1.0	<1.0	<1.0	<1.0	No Action
30	1st Floor Bathroom New	--	<1.0	<1.0	<1.0	No Action
31	1st Floor Bathroom Middle	<1.0	<1.0	1.6	1.0	Consider Placard
32	2nd Floor Bathroom East	<1.0	<1.0	<1.0	<1.0	No Action
33	2nd Floor Bathroom West	<1.0	<1.0	<1.0	<1.0	No Action
34	2nd Floor Sink	<1.0	<1.0	<1.0	<1.0	No Action
35	2nd Floor Janitor Closet	--	3.8	16.0	1.0	Placard
36	Basement Hallway Sink West	<1.0	<1.0	<1.0	<1.0	No Action
37	Basement Hallway Sink East	<1.0	<1.0	<1.0	<1.0	No Action
38	Basement Bathroom	fstaff	<1.0	<1.0	<1.0	No Action
39	Basement Laundry Room South	11	<1.0	<1.0	<1.0	No Action
40	Basement Laundry Room East	12	61.0	--	--	Re-test Before Back in Service
41	Conference Room Sink	44	2.3	2.6	<1.0	Consider Placard

Results indicated in **red** exceed the 5 parts per billion (ppb) standard established by the City of Milwaukee Common Council in Resolution File Number 171520

The 2018 samples were collected by the City of Milwaukee Health Department and analyzed by the City of Milwaukee Health Department Laboratory

Definitions:

1 µg/L = 1 ppb

~ Samples collected by Milwaukee Water Works (MWW) and analyzed by Eurofins. MWW utilized 15 ppb as the lead in drinking water standard.

Results indicated in **blue** exceed this standard.

--: No Sample Taken. Outlet Out of Service or Newly Installed Outlet

\* Outlet was not found. No Sample Taken.

# Outlet replaced by the school.

Placard: City of Milwaukee May Contain Lead Not Safe For Drinking Sign

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270000  
LRN : 0000279605  
Auxiliary ID : Sample #1  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Kitchen tap

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/01/19 10:50
Test Method	*see below				07/01/19 10:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/01/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270001  
LRN : 0000279605  
Auxiliary ID : Sample #2  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Kitchen tap 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/01/19 10:50
Test Method	*see below				07/01/19 10:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/01/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270002  
LRN : 0000279605  
Auxiliary ID : Sample #3  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Filtered Kitchen tap

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/01/19 10:50
Test Method	*see below				07/01/19 10:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/01/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270003  
LRN : 0000279605  
Auxiliary ID : Sample #4  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Filtered Kitchen tap 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/01/19 10:50
Test Method	*see below				07/01/19 10:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270004  
LRN : 0000279605  
Auxiliary ID : Sample #5  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st floor bathroom new

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/01/19 10:50
Test Method	*see below				07/01/19 10:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270005  
LRN : 0000279605  
Auxiliary ID : Sample #6  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st floor bathroom new  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/01/19 10:50
Test Method	*see below				07/01/19 10:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/01/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270006  
LRN : 0000279605  
Auxiliary ID : Sample #7  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st floor bathroom middle

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.6			ug Pb/L	07/01/19 10:50
Test Method	*see below				07/01/19 10:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/01/2019 16:56

PAGE: 1 of 1



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270007  
LRN : 0000279605  
Auxiliary ID : Sample #8  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st floor bathroom middle  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.0			ug Pb/L	07/01/19 10:50
Test Method	*see below				07/01/19 10:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270008  
LRN : 0000279605  
Auxiliary ID : Sample #9  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Conference room sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.6			ug Pb/L	07/01/19 10:50
Test Method	*see below				07/01/19 10:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270009  
LRN : 0000279605  
Auxiliary ID : Sample #10  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Conference room sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/01/19 10:50
Test Method	*see below				07/01/19 10:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270010  
LRN : 0000279605  
Auxiliary ID : Sample #11  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
2nd floor janitor closet

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*16.0			ug Pb/L	07/02/19 13:11
Test Method	*see below				07/02/19 13:11

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270011  
LRN : 0000279605  
Auxiliary ID : Sample #12  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
2nd floor janitor closet  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.0			ug Pb/L	07/02/19 13:11
Test Method	*see below				07/02/19 13:11

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270019  
LRN : 0000279605  
Auxiliary ID : Sample #13  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
2nd floor bathroom east

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:11
Test Method	*see below				07/02/19 13:11

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270020  
LRN : 0000279605  
Auxiliary ID : Sample #14  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
2nd floor bathroom east  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:11
Test Method	*see below				07/02/19 13:11

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270021  
LRN : 0000279605  
Auxiliary ID : Sample #15  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
2nd floor bathroom west

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:11
Test Method	*see below				07/02/19 13:11

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098

FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270022  
LRN : 0000279605  
Auxiliary ID : Sample #16  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
2nd floor bathroom west  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:12
Test Method	*see below				07/02/19 13:12

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270023  
LRN : 0000279605  
Auxiliary ID : Sample #17  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
2nd floor sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	07/02/19 13:12
Test Method	*see below				07/02/19 13:12

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
INSTANT REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270024  
LRN : 0000279605  
Auxiliary ID : Sample #18  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
2nd floor sink 30 sec flush

C H E M I S T R Y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
COLLECTED 06/14/19 07:22 RECEIVED 06/18/19 10:06					

Lead in Water:

Sample 1	*<1.0	ug Pb/L	07/03/19 08:00
Test Method	*<1		07/02/19 13:36

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 08:00

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270025  
LRN : 0000279605  
Auxiliary ID : Sample #19  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Basement Laundry room south

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:12
Test Method	*see below				07/02/19 13:12

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S2270026  
LRN : 0000279605  
Auxiliary ID : Sample #20  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Basement Laundry room south  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:12
Test Method	*see below				07/02/19 13:12

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010064  
LRN : 0000279605  
Auxiliary ID : Sample #21  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Basement Hallway Sink West

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:21
Test Method	*see below				07/02/19 13:21

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/02/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010065  
LRN : 0000279605  
Auxiliary ID : Sample #22  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Basement Hallway Sink West  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:21
Test Method	*see below				07/02/19 13:21

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010066  
LRN : 0000279605  
Auxiliary ID : Sample #23  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Basement Hallway Sink East

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	07/02/19 13:21
Test Method	*see below				07/02/19 13:21

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme

Sanjib Bhattacharyya, Ph.D.

Laboratory Director

Printed: 07/02/2019 16:56

PAGE: 1 of 1



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010067  
LRN : 0000279605  
Auxiliary ID : sAMPLE #24  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
Basement Hallway Sink East  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:21
Test Method	*see below				07/02/19 13:21

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010068  
LRN : 0000279605  
Auxiliary ID : Sample #25  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Basement bathroom

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	07/02/19 13:21
Test Method	*see below				07/02/19 13:21

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010069  
LRN : 0000279605  
Auxiliary ID : Sample #26  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Basement bathroom 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	07/02/19 13:22
Test Method	*see below				07/02/19 13:22

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010070  
LRN : 0000279605  
Auxiliary ID : Sample #27  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
Basement Art Sink

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	07/02/19 13:22
Test Method	*see below				07/02/19 13:22

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/02/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010071  
LRN : 0000279605  
Auxiliary ID : Sample #28  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Basement Art Sink 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:22
Test Method	*see below				07/02/19 13:22

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010073  
LRN : 0000279605  
Auxiliary ID : Sample #29  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Basement Staff Bathroom

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.1			ug Pb/L	07/02/19 13:22
Test Method	*see below				07/02/19 13:22

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010074  
LRN : 0000279605  
Auxiliary ID : Sample #30  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Basement Staff Bathroom  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:23
Test Method	*see below				07/02/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010075  
LRN : 0000279605  
Auxiliary ID : Sample #31  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Room 1 Tap

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*3.7			ug Pb/L	07/02/19 13:23
Test Method	*see below				07/02/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010076  
LRN : 0000279605  
Auxiliary ID : Sample #32  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Room 1 Tap 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*4.9			ug Pb/L	07/02/19 13:23
Test Method	*see below				07/02/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010077  
LRN : 0000279605  
Auxiliary ID : Sample #33  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Room 2 Hallway Bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:23
Test Method	*see below				07/02/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/02/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010078  
LRN : 0000279605  
Auxiliary ID : Sample #34  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Room 2 Hallway Bubbler  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:23
Test Method	*see below				07/02/19 13:23

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010079  
LRN : 0000279605  
Auxiliary ID : Sample #35  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Room 2 Tap

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*4.0			ug Pb/L	07/02/19 13:24
Test Method	*see below				07/02/19 13:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010080  
LRN : 0000279605  
Auxiliary ID : Sample #36  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Room 2 Tap 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*9.1			ug Pb/L	07/02/19 13:24
Test Method	*see below				07/02/19 13:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010081  
LRN : 0000279605  
Auxiliary ID : Sample #37  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Room 3 Tap

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:24
Test Method	*see below				07/02/19 13:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010082  
LRN : 0000279605  
Auxiliary ID : Sample #38  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Room 3 Tap 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*5.2			ug Pb/L	07/02/19 13:24
Test Method	*see below				07/02/19 13:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010083  
LRN : 0000279605  
Auxiliary ID : Sample #39  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st Floor Boys Room Sink Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/02/19 13:24
Test Method	*see below				07/02/19 13:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3010084  
LRN : 0000279605  
Auxiliary ID : Sample #40  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st Floor Boys Room Sink Right  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.7			ug Pb/L	07/02/19 13:24
Test Method	*see below				07/02/19 13:24

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/02/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030069  
LRN : 0000279605  
Auxiliary ID : Sample #41  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
1st Floor Boys Room Sink Middle Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.3			ug Pb/L	07/03/19 14:50
Test Method	*see below				07/03/19 14:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030070  
LRN : 0000279605  
Auxiliary ID : Sample #42  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
1st Floor Boys Room Sink Middle Right  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/03/19 14:50
Test Method	*see below				07/03/19 14:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030071  
LRN : 0000279605  
Auxiliary ID : Sample #43  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
1st Floor Boys Bathroom Middle Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<b>Lead in Water</b>					
Sample	*<1.0			ug Pb/L	07/03/19 14:50
Test Method	*see below				07/03/19 14:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030072  
LRN : 0000279605  
Auxiliary ID : Sample #44  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
1st Floor Boys Bathroom Middle Left  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
-----------	--------	----	------------	-------	-----------

Lead in Water

Sample	*<1.0			ug Pb/L	07/03/19 14:50
Test Method	*see below				07/03/19 14:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030073  
LRN : 0000279605  
Auxiliary ID : Sample #45  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
1st Floor Boys Bathroom Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/03/19 14:51
Test Method	*see below				07/03/19 14:51

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030074  
LRN : 0000279605  
Auxiliary ID : Sample #46  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st Floor Boys Bathroom Left  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/03/19 14:51
Test Method	*see below				07/03/19 14:51

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030075  
LRN : 0000279605  
Auxiliary ID : Sample #47  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Hallway Wall Sink Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/03/19 14:51
Test Method	*see below				07/03/19 14:51

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030076  
LRN : 0000279605  
Auxiliary ID : Sample #48  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Hallway Wall Sink Left  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/03/19 14:51
Test Method	*see below				07/03/19 14:51

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030128  
LRN : 0000279605  
Auxiliary ID : Sample #49  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Hallway Wall Sink Middle

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/03/19 14:52
Test Method	*see below				07/03/19 14:52

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030130  
LRN : 0000279605  
Auxiliary ID : Sample #50  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Hallway Wall Sink Middle  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.0			ug Pb/L	07/03/19 14:52
Test Method	*see below				07/03/19 14:52

Reference Method of Analysis: SM 3113B  
LOD: 0.31 ppb (ug/L)  
LOQ: 1.03 ppb (ug/L)  
EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030136  
LRN : 0000279605  
Auxiliary ID : Sample #51  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Hallway Sink Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/03/19 14:53
Test Method	*see below				07/03/19 14:53

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030137  
LRN : 0000279605  
Auxiliary ID : Sample #52  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Hallway Sink Right 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.5			ug Pb/L	07/03/19 14:53
Test Method	*see below				07/03/19 14:53

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030138  
LRN : 0000279605  
Auxiliary ID : Sample #53  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Room 4 Hallway Bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/03/19 14:53
Test Method	*see below				07/03/19 14:53

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030140  
LRN : 0000279605  
Auxiliary ID : Sample #54  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
Room 4 Hallway Bubbler  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/03/19 14:53
Test Method	*see below				07/03/19 14:53

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030141  
LRN : 0000279605  
Auxiliary ID : Sample #55  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
Staff Bathroom

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/03/19 14:53
Test Method	*see below				07/03/19 14:53

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030142  
LRN : 0000279605  
Auxiliary ID : Sample #56  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
Staff Bathroom 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.1			ug Pb/L	07/03/19 14:54
Test Method	*see below				07/03/19 14:54

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030141  
LRN : 0000279605  
Auxiliary ID : Sample #55  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Staff Bathroom

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/03/19 14:53
Test Method	*see below				07/03/19 14:53

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/03/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3030142  
LRN : 0000279605  
Auxiliary ID : Sample #56  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Staff Bathroom 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.1			ug Pb/L	07/03/19 14:54
Test Method	*see below				07/03/19 14:54

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050006  
LRN : 0000279605  
Auxiliary ID : Sample #57  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Staff Kitchen Tap

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.5			ug Pb/L	07/09/19 10:45
Test Method	*see below				07/09/19 10:45

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/09/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050007  
LRN : 0000279605  
Auxiliary ID : Sample #58  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
Staff Kitchen Tap 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/09/19 10:45
Test Method	*see below				07/09/19 10:45

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/09/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050008  
LRN : 0000279605  
Auxiliary ID : Sample #59  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Room 4 Tap

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/09/19 10:46
Test Method	*see below				07/09/19 10:46

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/09/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050009  
LRN : 0000279605  
Auxiliary ID : Sample #60  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Room 4 Tap 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.3			ug Pb/L	07/09/19 10:46
Test Method	*see below				07/09/19 10:46

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050012  
LRN : 0000279605  
Auxiliary ID : Sample #61  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

---

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

---

Ord. Comm: Downtown Montessori Academy  
Room 5 Tap

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.7			ug Pb/L	07/09/19 10:47
Test Method	*see below				07/09/19 10:47

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

---

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050013  
LRN : 0000279605  
Auxiliary ID : Sample #62  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
Room 5 Tap 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/09/19 10:47
Test Method	*see below				07/09/19 10:47

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/09/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050014  
LRN : 0000279605  
Auxiliary ID : Sample #63  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
1st Floor Girls Hallway Tap

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/09/19 10:47
Test Method	*see below				07/09/19 10:47

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050015  
LRN : 0000279605  
Auxiliary ID : Sample #64  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st Floor Girls Hallway Tap  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/09/19 10:47
Test Method	*see below				07/09/19 10:47

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/09/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050018  
LRN : 0000279605  
Auxiliary ID : Sample #65  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st Floor Girls Hallway Bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.1			ug Pb/L	07/09/19 10:47
Test Method	*see below				07/09/19 10:47

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050021  
LRN : 0000279605  
Auxiliary ID : Sample #66  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st Floor Girls Hallway Bubbler  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.9			ug Pb/L	07/09/19 10:47
Test Method	*see below				07/09/19 10:47

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/09/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050023  
LRN : 0000279605  
Auxiliary ID : Sample #67  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st Floor Girls Room Sink Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*3.1			ug Pb/L	07/09/19 10:48
Test Method	*see below				07/09/19 10:48

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050024  
LRN : 0000279605  
Auxiliary ID : Sample #68  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
1st Floor Girls Room Sink Right  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.4			ug Pb/L	07/09/19 10:48
Test Method	*see below				07/09/19 10:48

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/09/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050025  
LRN : 0000279605  
Auxiliary ID : Sample #69  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st Floor Girls Room Sink Middle Right

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*2.0			ug Pb/L	07/09/19 10:48
Test Method	*see below				07/09/19 10:48

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/09/2019 16:56

PAGE: 1 of 1



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050026  
LRN : 0000279605  
Auxiliary ID : Sample #70  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
1st Floor Girls Room Sink Middle Right  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.7			ug Pb/L	07/09/19 10:48
Test Method	*see below				07/09/19 10:48

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050029  
LRN : 0000279605  
Auxiliary ID : Sample #71  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st Floor Girls Room Sink Middle Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.7			ug Pb/L	07/09/19 10:49
Test Method	*see below				07/09/19 10:49

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050030  
LRN : 0000279605  
Auxiliary ID : Sample #72  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st Floor Girls Room Sink Middle Left  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.7			ug Pb/L	07/09/19 10:49
Test Method	*see below				07/09/19 10:49

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/09/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050107  
LRN : 0000279605  
Auxiliary ID : Sample #73  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
1st Floor Girls Room Sink Left

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.9			ug Pb/L	07/09/19 10:49
Test Method	*see below				07/09/19 10:49

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050108  
LRN : 0000279605  
Auxiliary ID : Sample #74  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507	DOB:	Age:	Sex:
-----------------------------------	------	------	------

Ord. Comm: Downtown Montessori Academy  
1st Floor Girls Room Sink Left  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*1.6			ug Pb/L	07/09/19 10:49
Test Method	*see below				07/09/19 10:49

Reference Method of Analysis: SM 3113B  
LOD: 0.31 ppb (ug/L)  
LOQ: 1.03 ppb (ug/L)  
EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)  
  
DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050109  
LRN : 0000279605  
Auxiliary ID : Sample #75  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
2nd Floor Room 9 Bubbler

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/09/19 10:49
Test Method	*see below				07/09/19 10:49

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050112  
LRN : 0000279605  
Auxiliary ID : Sample #76  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
2nd Floor Room 9 Bubbler  
30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/09/19 10:50
Test Method	*see below				07/09/19 10:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT) Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/09/2019 16:56

PAGE: 1 of 1

City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050114  
LRN : 0000279605  
Auxiliary ID : Sample #77  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
2nd Floor Room 9 Tap

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*5.0			ug Pb/L	07/09/19 10:50
Test Method	*see below				07/09/19 10:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/09/2019 16:56

PAGE: 1 of 1



City of Milwaukee-Public Health Laboratories  
841 North Broadway, Room 205 Milwaukee, WI 53202-3653  
Phone Number: (414)286-3526 Fax Number: (414)286-5098  
FINAL REPORT

Submitter copy to:

DCEH-ENVIRONMENTAL HEALTH SECTION  
841 N. BROADWAY  
THIRD FLOOR  
MILWAUKEE, WI 53202

Order ID : S3050115  
LRN : 0000279605  
Auxiliary ID : Sample #78  
Date Collected: 06/14/19  
Date Received : 06/18/19

Requested by: SCHULTZ, JEAN

FINAL

Patient Name: CP/S/GRAHAMST, 2507

DOB:

Age:

Sex:

Ord. Comm: Downtown Montessori Academy  
2nd Floor Room 9 Tap 30 sec flush

C h e m i s t r y

TEST-NAME	RESULT	AB	NRML-RANGE	UNITS	DATE-TIME
<u>Lead in Water</u>					
Sample	*<1.0			ug Pb/L	07/09/19 10:50
Test Method	*see below				07/09/19 10:50

Reference Method of Analysis: SM 3113B

LOD: 0.31 ppb (ug/L)

LOQ: 1.03 ppb (ug/L)

EPA Treatment technique (TT)Action Level: 15 ppb (ug/L)

DNR Certification Number: 241311290

Legends: L-Low, H-High, AB-Abnormal, P-Panic, C-Critical, X-Extreme  
Sanjib Bhattacharyya, Ph.D.  
Laboratory Director

Printed: 07/09/2019 16:56

PAGE: 1 of 1