

Milwaukee Historic Preservation Commission Staff Report

LIVING WITH HISTORY

HPC meeting date: 7/6/2020 Ald. Robert Bauman District: 4 Staff reviewer: Tim Askin PTS #114975 CCF #200240

Property 2051 W. WISCONSIN AV.

Owner/Applicant WOMEN'S SUPPORT CENTERS OF

MILWAUKEE INC 2051 W WISCONSIN AVE

MILWAUKEE WI 53233

Community Roofing & Restoration 1928 E Park Pl.

1928 E Park Pl. Milwaukee, WI 53211

Proposal

- 1. Re-roof with Certainteed Landmark Burnt Sienna color
- Rebuild built-in gutters on front structure with new soldered copper over new ice and water shield
- 3. Replace K-type gutters on rear section in-kind
- 4. Remove one chimney from rear section

Staff comments

The project meets all standards work for roofing and gutters. K-type tends to look more appropriate on hipped roofs where there is no evidence of an architecturally detailed cornice line, so staff recommends permitting the in-kind replacement.

The issue of consequence before you is the removal of one chimney. It is not street visible because of the very tight west property line.

Recommendation

Recommend HPC Approval with standard roof project conditions

Conditions

No dormers, chimneys, moldings parapets, or other permanent features will be altered or removed. No box vents, if used, will be visible from the street. If they are installed, they must be on a rear slope not visible from the street and they must be painted to blend with the color of the roofing material. A continuous ridge vent can be installed in place of box vents, but the vent must extend across the entire ridge and not stop short. Built-in rain gutters will be retained and sealed where needed. Valleys must be metal W-shape with no interweaving of shingles. Valleys and flashing must be painted or factory-finished to match the roofing color, unless copper. When installing new flashing at a masonry feature, the flashing must be stepped or cut into the mortar joints. The bricks may not be cut to install flashing at an angle.

We strongly recommend that that the Wisconsin Historical Society's best practices for re-roofing be used to extend the life of your new roof. (Synthetic underlayment is an acceptable alternative to 30lb felt.)

https://www.wisconsinhistory.org/Records/Article/CS4260

Previous HPC action

Previous Council action