

Askin, Tim

From: Historic Preservation Commission
Sent: Monday, April 26, 2021 8:33 AM
To: Lindsey Hansen; Pagacz, Staci
Cc: Jodi Daane; Angie Kochanski; Jacob Willadsen
Subject: ESPV-21-00036

With this additional information, I'm approving as submitted. I'm backlogged on processing formal approvals, but I have put a note on the electrical permit record to continue their review and issue the permit without me.

Tim Askin, Senior Planner
Historic Preservation Commission
City of Milwaukee
414-286-5712
Tim.Askin@Milwaukee.gov

From: Lindsey Hansen <lindsey@archelec.com>
Sent: Friday, April 23, 2021 10:18 AM
To: Historic Preservation Commission <HPC@milwaukee.gov>
Cc: Jodi Daane <jodi@archelec.com>; Angie Kochanski <angie@archelec.com>; Jacob Willadsen <jacob@archelec.com>
Subject: RE: Hanel FW: Historic Home Permit

Good morning Tim,

Please see attached the *Certificate of Appropriateness Application Form* along with the engineering documents.

The additional information is as follows:

Mounting method/system: IronRidge XR100 rail, hardware, and flashfeet
Proposed height above roof plane: 1"-6" off roof. This is a flush mount system
Distance from roof front edge: 2'-3'
Any difference in angle between the roof plane and the installation: No difference in panel/roof angle. This is a flush mount system so the panels are parallel to the roof surface.

If there is anything else you need let me know! Thank you and have a great weekend!!

Lindsey Hansen
Business Operations Specialist
Arch Electric, Inc. | The Solar + Energy Storage Experts
SOLAR POWER MAGAZINE'S #1 WI RESIDENTIAL SOLAR CONTRACTOR
Mobile: 920-838-5137 Office: 920-893-8388
1237 Pilgrim Road, Plymouth, WI 53073
Web: www.archelec.com
Email: lindsey@archelec.com



From: Historic Preservation Commission <HPC@milwaukee.gov>
Sent: Thursday, April 22, 2021 2:58 PM
To: Lindsey Hansen <lindsey@archelec.com>