



Legislation Details (With Text)

File #: 991066 **Version:** 0
Type: Ordinance **Status:** Passed
File created: 10/19/1999 **In control:** ZONING, NEIGHBORHOODS & DEVELOPMENT COMMITTEE
On agenda: **Final action:** 11/9/1999
Effective date:
Title: An ordinance relating to building code requirements for roof drainage conductors and water leaders.
Sponsors: THE CHAIR
Indexes: BUILDING CODE, WATER
Attachments:

Date	Ver.	Action By	Action	Result	Tally
10/19/1999	0	COMMON COUNCIL	ASSIGNED TO		
10/25/1999	0	ZONING, NEIGHBORHOODS & DEVELOPMENT COMMITTEE	HEARING NOTICES SENT		
11/2/1999	0	ZONING, NEIGHBORHOODS & DEVELOPMENT COMMITTEE	RECOMMENDED FOR PASSAGE	Pass	5:0
11/9/1999	0	COMMON COUNCIL	PASSED	Pass	17:0
11/18/1999	0	MAYOR	SIGNED		
11/23/1999	0	CITY CLERK	PUBLISHED		

991066
ORIGINAL

THE CHAIR
An ordinance relating to building code requirements for roof drainage conductors and water leaders.
225-4-2-d am
225-4-2-h cr
- Analysis -

This ordinance modifies city building code requirements for exterior rain gutters and roof water leaders for previous and new construction. The ordinance permits downspouts to discharge to finished grade when the roof area is no more than 300 square feet and specified conditions are met.

The Mayor and Common Council of the City of Milwaukee do ordain as follows:

Part 1. Section 225-4-2-d of the code is amended to read:

225-4. Drainage of Yard Areas and Roofs.

2. ROOF RAINWATER LEADERS (CONDUCTORS).

d. Outside Rainwater Leaders. All outside roof leaders (conductors) installed under or in the ground shall be installed as regulated in s. Comm. 82.36, Wis. Adm. Code. Conductors shall terminate with [[a cast iron hub]] >>an approved pipe<< above grade. The sheet metal conductors shall be connected and sealed to the [[cast iron hub]] >>pipe<< in an approved manner. Roof leaders (conductors) connecting to the storm building drain in the basement shall be [[cast iron pipe]] >>of an approved pipe material<< to a point at least 2 feet inside the basement foundation wall. Roof leaders (conductors) shall be maintained in good repair and free of stoppages.

Part 2. Section 225-4-2-h of the code is created to read:

h. Previous and New Construction. Roof water leaders on all buildings or structures with a roof area of 300 square feet or less may discharge to finished grade when all the following conditions are met:

h-1. If the discharge water is not contained on the owner's property, written permission shall be obtained from each affected abutting property owner.

h-2. The discharge water shall not create a nuisance.

h-3. The discharge water shall not discharge to a street, alley or other public way.

h-4. The discharge water shall not create an icy condition.

APPROVED AS TO FORM

Legislative Reference Bureau

Date: _____

IT IS OUR OPINION THAT THE ORDINANCE
IS LEGAL AND ENFORCEABLE

Office of the City Attorney

Date: _____

Department of Neighborhood Services

99329-2

CW

10/1/99