



## Legislation Details (With Text)

**File #:** 080345 **Version:** 0

**Type:** Ordinance **Status:** Passed

**File created:** 7/1/2008 **In control:** ZONING, NEIGHBORHOODS & DEVELOPMENT COMMITTEE

**On agenda:** **Final action:** 7/30/2008

**Effective date:**

**Title:** An ordinance relating to installation and operation of category I, II, IIIA and IIIB equipment in dry cleaning establishments.

**Sponsors:** THE CHAIR

**Indexes:** BUILDING CODE, FIRE PREVENTION

**Attachments:** 1. Fiscal Note, 2. Notice List, 3. Notice Published on 8-15-08

Date	Ver.	Action By	Action	Result	Tally
7/1/2008	0	COMMON COUNCIL	ASSIGNED TO		
7/15/2008	0	ZONING, NEIGHBORHOODS & DEVELOPMENT COMMITTEE	HEARING NOTICES SENT		
7/22/2008	0	ZONING, NEIGHBORHOODS & DEVELOPMENT COMMITTEE	RECOMMENDED FOR PASSAGE	Pass	5:0
7/30/2008	0	COMMON COUNCIL	PASSED	Pass	14:0
8/6/2008	0	MAYOR	SIGNED		
8/15/2008	0	CITY CLERK	PUBLISHED		

080345  
ORIGINAL

### THE CHAIR

An ordinance relating to installation and operation of category I, II, IIIA and IIIB equipment in dry cleaning establishments.

76-20-8-p cr

This ordinance revises excessive ventilation requirements for the installation of new category IIIA and IIIB dry cleaning equipment resulting from the adoption of the 2006 International Fire Code, ch. 12. The ordinance also allows existing category IIIA and IIIB dry cleaning installations to discontinue maintaining the exhaust requirements of s. 76-20 if the installation is in compliance with the 2006 International Fire Code, ch. 12.

The Mayor and Common Council of the City of Milwaukee do ordain as follows:

Part 1. Section 76-20-8-p of the code is created to read:

### **76-20. Dry Cleaning Establishments with Category I, II, IIIA and IIIB Equipment.**

#### **8. INSTALLATION AND OPERATION.**

p. Category IIIA and category IIIB machines installed on or after March 1, 2008, are exempt from the requirements of pars. n and o, but must comply with the provisions of the 2006 International Fire Code, ch. 12. Category IIIA and category IIIB machines installed before March 1, 2008, which are

already in compliance with the requirements of the International Fire Code, ch. 12, are exempt from the requirements of pars. n and o.

APPROVED AS TO FORM

\_\_\_\_\_  
Legislative Reference Bureau

Date: \_\_\_\_\_

IT IS OUR OPINION THAT THE ORDINANCE  
IS LEGAL AND ENFORCEABLE

\_\_\_\_\_  
Office of the City Attorney

Date: \_\_\_\_\_

Department of Neighborhood Services

MET

6/17/08

LRB08223-1