



## Legislation Details (With Text)

**File #:** 170818 **Version:** 1  
**Type:** Ordinance **Status:** Passed  
**File created:** 9/6/2017 **In control:** COMMON COUNCIL  
**On agenda:** **Final action:** 11/7/2017  
**Effective date:**  
**Title:** A substitute ordinance relating to permeable pavement systems.  
**Sponsors:** ALD. BOHL  
**Indexes:** PUBLIC IMPROVEMENTS, STREET IMPROVEMENTS  
**Attachments:** 1. 169781-170818 SUB1 ORD Permeable pavement systems.pdf, 2. Notice Published 11-27-17

Date	Ver.	Action By	Action	Result	Tally
9/6/2017	0	COMMON COUNCIL	ASSIGNED TO		
9/13/2017	0	PUBLIC WORKS COMMITTEE	HELD TO CALL OF THE CHAIR	Pass	5:0
10/25/2017	0	PUBLIC WORKS COMMITTEE	SUBSTITUTED	Pass	5:0
10/25/2017	0	PUBLIC WORKS COMMITTEE	RECOMMENDED FOR PASSAGE	Pass	4:0
11/7/2017	1	COMMON COUNCIL	PASSED	Pass	15:0
11/21/2017	1	MAYOR	SIGNED		
11/27/2017	1	CITY CLERK	PUBLISHED		

### 170818 PROPOSED SUBSTITUTE

ALD. BOHL

A substitute ordinance relating to permeable pavement systems.

225-4-3-b am

225-4-3-d rc

This ordinance:

- Requires perforated underdrain piping for the full length of all permeable pavement applications greater than 1,000 square feet where permeable pavement is being used in lieu of a catch basin or storm inlet.
- Requires that catch basins or storm inlets are located so that no point of an impervious paved area is further than 300 feet from a catch basin, storm inlet, trench drain or permeable pavement surface with subsurface drainage.

The Mayor and Common Council of the City of Milwaukee do ordain as follows:

Part 1. Section 225-4-3-b of the code is amended to read:

### 225-4. Drainage of Yard Areas and Roofs.

### 3. NEWLY PAVED AREAS OR PARKING LOTS.

b. Permeable Paving. The commissioner may allow the use of permeable paving as regulated in s. 252-74. For newly paved areas or parking lots, the storm sewer requirement under this section may be waived by the commissioner if adequate drainage is provided. >>Perforated underdrain piping shall be required for the full length of all permeable pavement applications greater than 1,000 square feet where permeable pavement is being used in lieu of a catch basin or storm inlet.<<

Part 2. Section 225-4-3-d of the code is repealed and recreated to read:

d. Catch Basins and Storm Inlets. A catch basin or storm inlet shall be located so that no point of an impervious paved area is further than 300 feet from a catch basin, storm inlet, trench drain or permeable pavement surface with subsurface drainage. Every catch basin shall be connected to a combined sewer and every storm inlet shall be connected to a storm sewer.

APPROVED AS TO FORM

\_\_\_\_\_  
Legislative Reference Bureau

Date: \_\_\_\_\_

IT IS OUR OPINION THAT THE ORDINANCE  
IS LEGAL AND ENFORCEABLE

\_\_\_\_\_  
Office of the City Attorney

Date: \_\_\_\_\_

Dana J. Zelazny  
LRB169781-2  
October 23, 2017